

FIRE STRATEGY LEGEND

- █ 240 Minute Fire Rated Wall/Door
- █ 120 Minute Fire Rated Wall/Door
- █ 60 Minute Fire Rated Wall/Door
- █ 30 Minute Fire Rated Wall/Door
- SC Self closing device
- VP Vision Panel (fire resistant glazing to fire doors)
- PB Push bar ironmongery
- S12 Fire Action Sign
- S13 Fire Door Keep Shut' signage
- S14 Fire Door Keep Locked Shut' signage
- S20 Fire Escape Keep Clear' signage
- S22 Fire Exit' signage
- S25 Push Bar to Open' signage
- S26 Directional arrow fire exit signage
- S27 Fire Exit Keep Clear' signage
- S40 Refuge - Keep Clear' signage
- - - Ceiling cavity fire barrier
- Wall Cavity barrier
- 60 minute FR roof 3m to the side as per HTM 05-02 figure 24.

FIRE STRATEGY TO BE REVIEWED BY THE BUILDING CONTROL OFFICER

SEE ELECTRICAL ENGINEERS DETAILS FOR FIRE ALARM ALTERNATION AND NBS REF P12 FOR FURTHER DETAILS.

P03	Omit two additional roof lights and move back green wall by 1m	20/10/2023	NSL
P02	Link Corridor planning set update to earlier option	19/10/2023	NSL
P01	First Issue	26/07/2023	NSL
No.	Revision	Date	Initis

PROJECT ORIEL, 66 WIGMORE STREET & 18 BENTINCK STREET
Drawing
FIRE STRATEGY - SECOND FLOOR

Client
FORTIUS CLINIC

**FRANK
SHAW
ASSOCIATES
LIMITED
ARCHITECTS**

