



your energy assessor


Fenton Energy Ltd.  
Ground Floor  
Parker Court  
Knapp Lane  
Cheltenham  
GL50 3QJ

01242 506150  
info@fentonenergy.co.uk  
www.fentonenergy.co.uk



**PROJECT NAME**  
Pier View Hotel Flats 1-5

**DATE**  
26<sup>th</sup> July 2023



# ENERGY STRATEGY

Compliance with Policy ES1



# Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

## Contents

Executive Summary.....	3
Total CO <sub>2</sub> Emissions Savings.....	3
Design Principles to Reduce Energy Consumption and Carbon Emissions.....	4
Fabric.....	4
Fenestration and Solar Gain.....	4
Mechanical Services.....	4
Lighting.....	5
Renewables.....	5
Overall performance.....	5
Proposed Fabric and Services Specification.....	6
Table 1 – Baseline Compliance.....	6
Table 2 – Additional Energy Efficiency Measures.....	7
Selecting Renewables.....	8
Table 3 – Feasibility Matrix of Appropriate Renewables.....	8
Fig. 1 – Aerial Image of the Site – Overshading Risk.....	9
Feasibility of Appropriate Renewables - Conclusion.....	10
Appropriate Solution(s).....	10
Table 4 – Proposed Renewables.....	11
Table 5 – Renewables Specification.....	11
Table 6 – Summary Table.....	12
Appendix A – Plot Detail.....	13
Appendix B – Possible Solar Panel.....	14
Appendix C – Photovoltaic Panels.....	16
What are Photovoltaic Panels?.....	16
Space Requirements.....	16
Installation Costs, Funding, Maintenance and Payback.....	17
Advantages of Photovoltaic Panels.....	17
Disadvantages of Photovoltaic Panels.....	17
Appendix D – Solar Thermal Panels.....	18
What is Solar Thermal Energy?.....	18
Space Requirements.....	18
Installation Costs, Funding, Maintenance and Payback.....	19
Planning Requirements.....	19
Advantages.....	19
Disadvantages.....	19
Appendix E – Air Source Heat Pumps.....	20
What are Air Source Heat Pumps?.....	20
Space Requirements.....	21
Installation Costs, Funding, Maintenance and Payback.....	21



# Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

Planning .....	21
Advantages.....	21
Disadvantages.....	21
Appendix F – Ground Source Heat Pumps.....	22
What are Ground Source Heat Pumps?.....	22
Space Requirements .....	22
Installation Costs, Funding, Maintenance and Payback .....	23
Planning Requirements.....	23
Advantages.....	23
Disadvantages.....	23
Appendix G – Biomass.....	24
What is Biomass? .....	24
Space Requirements .....	24
Installation Costs, Funding, Maintenance and Payback .....	25
Planning .....	25
Advantages.....	25
Disadvantages.....	25
Appendix H – Combined Heat and Power .....	26
What is Combine Heat and Power? .....	26
Space Requirements .....	26
Installation Costs, Funding, Maintenance and Payback .....	27
Advantages.....	27
Disadvantages.....	27
Appendix I – District Heating .....	28
What is District Heating? .....	28
Space Requirements .....	28
Installation Costs, Funding, Maintenance and Payback .....	29
Advantages.....	29
Disadvantages.....	29



# Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

## Executive Summary

This Energy Assessment has been compiled to demonstrate compliance with the Stroud District Council Policy ES1 (from the Supplementary Planning Document (SPD)).

The proposal is for the re-development of a former hotel into 5 flats at Pier View Hotel, Sharpness. The development will consist of four 2-bed flats and one 3-bed flat.

SAP calculations have been completed in stages to demonstrate the compliance with the Energy Hierarchy as stated in the Sustainable Construction & Design Checklist (Stroud District Council, SPD).

Firstly, SAP calculations were modelled to provide 'baseline' energy demand and emissions. Then, additional measures were applied to provide 'residual' energy demand and emissions. Finally, appropriate decentralised renewables were included in the SAP calculations to provide the final energy demand and emissions figures for comparison. More detail is provided in the following sections.

To summarize the results, the total reduction in carbon emissions from energy efficiency measures and on-site renewables is as follows:

### Total CO<sub>2</sub> Emissions Savings

26.32%
--------



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Design Principles to Reduce Energy Consumption and Carbon Emissions

#### Fabric

Any new or upgraded thermal elements will utilise low U-values and good detailing. This will help to limit heat losses through the fabric of the proposed development.

#### Fenestration and Solar Gain

Careful consideration will be given to the fenestration, for any new glazing. Low U-values will need to be specified to limit heat losses through these areas. The glazing design allows for passive heating of the flats from solar gains. However, to minimise the risk of overheating within the flats, the glazing will be operable where practical and internal shading will be employed.

The positioning of the glazed openings will also maximise the available daylight into most of the proposed flats. This will not only improve comfort levels for the occupants but also reduce the energy consumption through artificial lighting.

#### Mechanical Services

A well-designed building envelope must be supplemented by appropriate services within the building.

It is proposed that the heating and hot water to the dwellings are provided by highly efficient gas boilers.

Additionally, efficient mechanical extract fans will be installed to the wet rooms.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Lighting

It is proposed that only energy efficient lighting will be installed. This means that all light fittings should have lamps with a luminous efficacy of greater than 85 lamp lumens per circuit-watt.

### Renewables

Different forms of renewable technologies have been considered as part of this assessment. Please refer to the section on 'Selecting Renewables'.

### Overall performance

The following tables detail how the proposed development has been specified at this stage, incorporating the above principles. Also displayed is how the building performs in relation to the building regulations and the planning requirements for ES1/SPD.

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

### Proposed Fabric and Services Specification

Table 1 – Baseline Compliance

Showing the minimum specification required to achieve compliance with Part L.

Category	Item	Value/Details	Part L Minimum Standard
Building Fabric (W/m <sup>2</sup> K)	Ground Floor	0.25	0.25
	External Walls	0.30	0.30
	Corridor Walls	0.30	0.30
	Dormer Walls	0.18	0.26
	Warm Pitched Roof	0.17	0.16
	Cold Pitched Roof	0.15	0.16
Fenestration (W/m <sup>2</sup> K)	Solid Doors	1.00/1.40	1.40
	Windows	1.40	1.40
Ventilation	Mechanical Ventilation	Natural Ventilation (Extract fans fitted to wet rooms)	Natural Ventilation
Heating	Primary Heating System	Mains gas boiler: Vaillant ecoTEC exclusive 835	Programmer, room thermostat & TRVs
	Controls	Programmer, room thermostat & TRVs	-
	Heat Distribution	Radiators	-
	Water Heating	From main heating system	-
	Secondary Heating System	None	None
Additional Features	Low Energy Lighting	85lm/W	75lm/W
	SAP Appendix Q	None	None
	Renewables	None	None
	Regulation 36 Compliance	125 litres/person/day	125 litres/person/day

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

Table 2 – Additional Energy Efficiency Measures

Showing updates to the baseline specification to further reduce energy demand.

Category	Item	Value/Details	Part L Minimum Standard
Building Fabric (W/m <sup>2</sup> K)	External Walls	0.28	0.30
Heating	Controls	Time and temperature zone controls	Programmer, room thermostat & TRVs
	Heat Distribution	Radiators	-
	Water Heating	Electric instant hot water	-



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

### Selecting Renewables

Table 3 – Feasibility Matrix of Appropriate Renewables

Showing the considerations in choosing a renewable technology for this site.

Technology	Requirements	Requirements Met?	Appropriate?
Photovoltaic panels	Roof facing east to west (through south)	Yes	Yes
	Little/no or modest overshading	Yes*	
	Flat roof or pitched roof not greater than 45°	Yes	
	Any size development	Yes	
Solar thermal	All requirements as for photovoltaic panels	Yes	Yes
	Hot water tank possible	Yes	
Air source heat pumps	Suitable external wall or other location on-site for equipment	Yes	No
	Aesthetic considerations	No	
	Noise impact	No	
	Any size development	Yes	
Ground source heat pumps	External space for horizontal trench or vertical borehole	No	No
	Medium to large sized development	No	
	Archaeology	Unknown	
	Best suited to underfloor heating	No	
Biomass	Space needed for plant, fuel storage and deliveries	No	No
	Medium to large sized development	No	
	Minimal impact on residents (air quality, deliveries)	No	
Combined heat and power	Space need for plant, access and servicing	No	No
	Large sized development (large heat demand)	No	
District heating	Available network	No	No
	Very large sized development (substantial heat demand)	No	

\*See the following aerial image demonstrating that the overshading risk is low for the likely location of any solar panels.

Please refer to Appendices B through I for more in-depth information on these technologies.

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

Fig. 1 – Aerial Image of the Site – Overshading Risk



Note: the blue arrow shows the location of the proposed development at Pier View Hotel. As can be seen, there are minimal obstructions that are likely to create overshading to any potential solar panels.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Feasibility of Appropriate Renewables - Conclusion

Due to the location, size and type of development most renewable technologies are not appropriate for this site.

As a standalone technology, solar thermal panels would not provide a sufficient carbon reduction for this scheme.

Air source heat pumps would not be appropriate for this development for multiple reasons. Firstly, the flats are not designed to have underfloor heating, this would reduce the efficiency of heat pumps. Further to this, there is an aesthetic consideration given the heat pumps would each require an external condensing unit and positioning would be limited given the design of the roof and the requirement for them not to be too close to the flats due to noise issue.

However, photovoltaic panels (PV) are feasible. It is proposed that panels could be installed on the main roofs of the development. This will need to be confirmed by survey before installation.

### Appropriate Solution(s)

Photovoltaic Panels
---------------------

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

**Table 4 – Proposed Renewables**

Showing renewables added to the specification to generate energy on site and reduce carbon emissions.

Category	Item	Value/Details	Part L Minimum Standard
Additional Features	Renewables	4kWp of solar panels	-

Please note the following:

Arrays totalling 4.00kWp of photovoltaic panels has been recommended for this building. The proposed set up is as follows:

**Table 5 – Renewables Specification**

Total Array Size	Connection	Orientation	Inclination	Overshading
2.00kWp to Plot 3	Direct Supply	South west/ south east	45°	None or very little
2.00kWp to Plot 5	Direct Supply	South west/ south east	45°	None or very little

Please note: The SAP calculation accepts 0°, 30°, 45°, 60° and 90°. The angle given is the nearest of these values to the true pitch of the PV.

This amount of PV could be achieved with two arrays of e.g. 5 × 400W panels (10 x panels total) and take up an area of approximately 20m<sup>2</sup> of roof space. The top two flats (Flats 3 and 5) have been selected to receive the benefit of the PV panels directly.

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

### Table 6 – Summary Table

Showing how energy demand and carbon emissions can be reduced by implementing the measures detailed in the preceding steps.

Assessment Stage	Site Total
Baseline Emissions	12,250.66 kg CO <sub>2</sub> /m <sup>2</sup>
Emissions after Energy Efficiency and Low Carbon Measures	9,443.23 kg CO <sub>2</sub> /m <sup>2</sup>
CO <sub>2</sub> Reduction from Energy Efficiency Measures	22.92 %
Emissions After Renewables are Added to the Energy Efficiency Measures	9,026.27 kg CO <sub>2</sub> /m <sup>2</sup>
Further CO <sub>2</sub> Reduction from Renewables Element	4.42 %
CO <sub>2</sub> Savings from all Measures – Renewable and Energy Efficiency	3,224.39 kg CO <sub>2</sub> /m <sup>2</sup>
Total CO <sub>2</sub> Reduction from all Measures.	26.32 %

For further details please refer to the SAP Reports and the appendices.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Appendix A – Plot Detail

Plot	Baseline CO <sub>2</sub> (kg pa)	Additional Measures CO <sub>2</sub> (kg pa)	Renewables CO <sub>2</sub> (kg pa)
Flat 1	2,805.50	2,279.92	2,279.92
Flat 2	3,222.49	2,591.52	2,591.52
Flat 3	2,258.71	1,630.93	1,422.59
Flat 4	1,880.51	1,421.32	1,421.32
Flat 5	2,083.46	1,519.55	1,310.93
Total	12,250.66	9,443.23	9,026.27

# Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)


## Appendix B – Possible Solar Panel



### VITOVOLT 300

Photovoltaic modules  
Type M395WE, M400WE  
standard and blackframe

Datasheet



#### VITOVOLT 300 Type M395WE, M400WE


Monocrystalline photovoltaic modules in **standard** and **blackframe** versions with 395/400 W<sub>p</sub> rated output for generating power from solar energy

- Module efficiency up to 20.4 %
- Shingled PERC cell technology
- Corrosion-resistant aluminium frame with excellent mechanical load bearing capacity for high snow (5400 Pa) and wind/suction (2400 Pa) loads
- Additional output of up to 5 W<sub>p</sub> due to positive output tolerance
- 3.2 mm anti-reflective glass for high solar yields
- High operational reliability: 2 bypass diode bridges for dependable operation
- Tested for resistance to salt spray and ammonia. Consequently suitable for use in coastal regions and areas with intensive agricultural operations
- Certified to IEC 61215, IEC 61730, IEC 61701 and IEC 62716 to guarantee compliance with international quality standards.

6169122 GB 11/2020

# Energy Strategy


Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)



## Specification

Vitovolt 300	Typ	MQ35WE	MA30WE	MA40WE
<b>Performance data under STC</b>				
Rated output P <sub>max</sub>	Wp	395	400	400
Output tolerance	W	0/+5	0/+5	0/+5
MPP voltage U <sub>MPP</sub>	V	38.5	38.6	38.6
MPP current I <sub>MPP</sub>	A	10.26	10.36	10.36
Open circuit voltage U <sub>oc</sub>	V	46.3	46.4	46.4
Short circuit current I <sub>sc</sub>	A	10.92	10.97	10.97
Module efficiency	%	20.15	20.4	20.4
<b>Temperature coefficients</b>				
Output	%/K	-0.34	-0.34	-0.34
Open circuit voltage	%/K	-0.27	-0.27	-0.27
Short circuit current	%/K	0.04	0.04	0.04
<b>Vitovolt 300</b>				
Cell temperature at NOCT	°C	42.3	42.3	42.3
Max. system voltage	V	1500	1500	1500
Reverse current resist-ance	A	20	20	20
<ul style="list-style-type: none"> <li>■ STC: Irradiation 1000 W/m<sup>2</sup>; cell temperature 25 °C; air mass AM 1.5; measuring tolerance: ±3 % (P<sub>max</sub>)</li> <li>■ MPP: maximum power point (maximum output under STC)</li> <li>■ NOCT: Irradiation 800 W/m<sup>2</sup>; ambient temperature 20 °C; air mass AM 1.5; wind speed 1 m/s; measuring tolerance: ±3 % (P<sub>max</sub>)</li> </ul>				

## Connection dimensions



- A Junction box
- B Connecting cables
- C 4 drilled holes 9 x 14 mm
- D 4 holes for equipotential bonding ∅ 6 mm

a	mm	1176
b	mm	1116
c	mm	1080
d	mm	1031
e	mm	35
f	mm	35
g	mm	35

Type of cell: Monocrystalline PERC silicon cell  
 Number of cells: 340 (string)  
 Cell embedding: Ethylene vinyl acetate (EVA)  
 Frame: Anodized aluminum alloy, black/silver  
 Front glass: Tempered borosilicate safety glass 3.2 mm with anti-reflective coating  
 Weight: 22 kg  
 Max. load due to pressure/suction: 5400 Pa/2400 Pa  
 Junction box: IP 67, 3 slots  
 Connection: Cables 1.25 m long, with 4 mm<sup>2</sup> cross-section and Blue-Contact (MC4)  
 Protection class: II  
 Application class: A  
 Shipping unit: 31 pcs per pallet

## Guarantee

**Product guarantee**  
 5 year e. Viessmann warranty  
 12 years. Viessmann product guarantee

**Output guarantee**  
 Min. 87 % after one year  
 Min. 80 % linear after 25 years

Viessmann Werke GmbH & Co. KG  
 D-35107 Aldenrade  
 Phone: +49 (0)52 70-432 70 0  
 Fax: +49 (0)52 70-22780  
 www.viessmann.com

2. **VIEMANN**

Subject to technical modifications.

Viessmann Limited  
 Hedonwood 30, Hedon  
 East Yorkshire YO21 2JG  
 Telephone: +44 1962 875000  
 Fax: +44 1962 875040  
 Email: info-uk@viessmann.com  
 0169122



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Appendix C – Photovoltaic Panels

#### What are Photovoltaic Panels?

Photovoltaic Panels (PV) panels convert the energy in light received from the Sun into electricity. There are two types of system – grid connected systems are the most common and allow electricity to be drawn from the national grid during times when the panels are not generating enough electricity to provide all the power needs. This setup also allows any surplus electricity to be sold back to the grid. Conversely, standalone systems are not connected to the grid and so require supplementing with other power generating systems or batteries to ensure that the supply of electricity is not interrupted.



#### Space Requirements

PV Panels are composed of a series of small solar cells that are connected together. They come in a variety of shapes, sizes and outputs and ideally will be installed on an inclined south-facing roof to maximise the power generated. Larger arrays will result in more power being generated, up to the limits of available roof space. If space is limited, solar tiles can be installed as these can fit more capacity into the same area. However, these are more expensive than traditional panel installations.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Installation Costs, Funding, Maintenance and Payback

The average cost for a solar panel installation for a small-scale building is approximately £5,000-£9,000, although this is highly dependent on the size of array being installed. Planning permission is not usually required unless the panels are to be installed on a listed building or the property is situated in a conservation area.

The photovoltaic array can be expected to last for up to 25 years, depending on the manufacturer.

On January 1<sup>st</sup> 2020, a new government incentive scheme was introduced, known as the Smart Export Guarantee (SEG). For those installing small scale renewable technologies, with a maximum capacity of 5MW, the SEG will pay for each unit of electricity fed into the National Grid. It is anticipated that payback for a PV system could be achieved in approximately 12 years.

### Advantages of Photovoltaic Panels

- Electricity bills reduced
- Source of renewable energy
- Reduced carbon footprint
- Low maintenance

### Disadvantages of Photovoltaic Panels

- Relatively high upfront cost
- Energy generation varies with the average annual amount of radiation received
- Power output highly weather dependent
- No electricity produced at night
- Requires a lot of roof space for an effective array.

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Appendix D – Solar Thermal Panels

#### What is Solar Thermal Energy?

A solar thermal system uses energy from the Sun to heat water which is then stored in a hot water cylinder.



#### Space Requirements

For a small scale solar thermal setup, it is suggested that approximately five square meters of south facing space will be required, to ensure that as much solar energy as possible can be collected. A sloping roof is not required as the panels can be fitted to a frame mounted on a flat roof or even hung from a wall.

Before installing a solar thermal system, it is important to check if your current setup is suitable – solar thermal systems require a hot water cylinder to store the heated water and are therefore not compatible with combination boilers or direct acting water heaters. If the cylinder present prior to the installation of the solar thermal system is not a solar cylinder, it will be necessary to either replace the cylinder with one which has a solar heating coil fitted or to add an extra cylinder with a solar coil to ensure that the system works correctly.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Installation Costs, Funding, Maintenance and Payback

The initial cost of installing a typical small scale solar thermal system is generally between £5,000 and £9,000. There are currently no financial schemes available for solar thermal panels.

Very little maintenance is usually required after the system is installed, although it is important to have the system inspected every three to seven years by a qualified solar panel expert.

The payback costs for solar panels depend greatly on the installation costs. For example, a system costing between £5,000 and £7,000 to install has a typical payback time between 13 and 17 years.

### Planning Requirements

Planning permission is generally not required for the installation of a solar thermal system. However, restrictions may apply if the building is listed or sited within a conservation area – it is advisable to check with the local council prior to installation.

### Advantages

- Clean and efficient water heating
- Easy to maintain
- Quiet
- Low carbon footprint

### Disadvantages

- High initial cost
- Effectiveness depends on the number of hours of sunshine your area gets during the day
- The system is limited to only heating water – no electricity is produced
- Only useful if there is meaningful hot water demand

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Appendix E – Air Source Heat Pumps

#### What are Air Source Heat Pumps?

Air source heat pumps (ASHPs) extract thermal energy from outside air (using the principles of vapour compression refrigeration), which can then be used to heat the building as well as to provide hot water. Heat pumps can also be run in reverse, cooling the building and transferring the excess heat to the outside.

There are two types of air source heat pump systems:

1. Air to air systems transfer the warmed air throughout the building using fans
2. Air to water systems transfer heat to water, which is then distributed via plumbing similar to that used in a conventional heating system with a boiler

Air source heat pumps operate at lower temperatures than traditional gas boilers. This means that these systems can be utilised more effectively with an underfloor heating setup compared to using radiators, as with underfloor heating the warmth is distributed more evenly and thus more efficiently. It is vital that the building fabric be well insulated if the benefits of an air source heat pump are to be fully utilised.





## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Space Requirements

An area on the exterior of the building, such as on a wall or roof, will be required for the external unit. This ideally should be in a warmer location which not only has enough space for the unit but is also clear of obstructions to allow air to flow freely.

Additionally, space will be required for the internal unit. Typically, these are no larger than a standard hot water cylinder or boiler unit, depending on the exact setup used. However, with many setups a separate hot water cylinder, along with the space for this, is also required.

### Installation Costs, Funding, Maintenance and Payback

The cost of purchasing and installing an air source heat pump system is generally between £3,000 and £11,000, depending on the size and complexity of the setup. Additional costs may be incurred if your property is particularly large. However, it may be possible to obtain payments from the Government's Renewable Heat Incentive (RHI), which will offset some of the costs incurred with installing the heat pump.

Air source heat pumps can be expected to last for up to 20 years as long as they are inspected every three to five years by a qualified technician. A typical payback period for ASHPs is around 12 years, once RHI is taken into account.

### Planning

It is advisable to consult your local planning authority prior to purchasing the heat pump to establish whether there are any restrictions as to the positioning of the external unit.

### Advantages

- Lower fuel bills
- Can provide heating in winter and cooling in the summer as well as hot water year-round
- Low maintenance
- Low carbon footprint

### Disadvantages

- Works more efficiently with underfloor heating, or larger radiators
- The outdoor unit produces noise so careful siting is required
- Less efficient in winter due to the need to extract heat from colder air, resulting in lower Coefficient of Performance (COP) values.

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Appendix F – Ground Source Heat Pumps

#### What are Ground Source Heat Pumps?

Ground source heat pumps (GSHPs) use pipes, buried in available land close to the building, to extract heat from the ground. Water and antifreeze are circulated around the pipes absorbing heat, which is then transferred through a heat exchanger in the heat pump into the building. From this point, the heat can be used to provide space or hot water heating, or the system can be run in reverse to provide cooling.

Ground source heat pumps operate at lower temperatures than traditional gas boilers. This means that these systems can be utilised more efficiently with an underfloor heating setup than with radiators. It is particularly vital that the building be well insulated to fully take advantage of the benefits of a ground source heat pump.



#### Space Requirements

There are two types of ground source heat pump systems:

1. Horizontal systems, which require an area of approximately 700m<sup>2</sup>
2. Vertical systems, which have a borehole approximately a quarter of a metre across and up to 100m deep.

Larger sites will require either a larger area or more boreholes. Whichever system is chosen, suitable access must be available for the machinery required to install the pipework, especially in the case of the drill rig required for the vertical systems.

Space must also be available for the internal unit. These are typically larger than a standard gas boiler, approximately the size of a domestic hot water cylinder.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Installation Costs, Funding, Maintenance and Payback

Installing ground source heat pumps can cost between £10,000 and £18,000. The horizontal system is often cheaper as the expensive drill rig required to drill the borehole is unnecessary.

It may be possible to obtain payments from the Government's Renewable Heat Incentive (RHI), which will help to offset some of the costs involved with installing the heat pump. Additionally, the heat pump, if inspected regularly by a qualified servicer, can be expected to last for up to twenty years.

With low running costs and possible income from the RHI, the payback period can typically be between 8 and 12 years.

### Planning Requirements

Ground source heat pumps are generally permitted, but some restrictions apply, such as with listed buildings. Consulting your local authority prior to installation is recommended.

### Advantages

- Lower fuel bills, especially if used to replace direct electric heating
- Can provide both space and hot water heating
- Can provide heating in winter and cooling in summer as well as hot water year-round
- Lower carbon footprint
- Low maintenance
- More efficient in winter than air source heat pumps due to ground temperatures remaining more constant throughout the year

### Disadvantages

- More expensive to install than air source heat pumps
- Suitable land must be available for the pipework or boreholes
- The building must be very well insulated
- Works most efficiently with underfloor heating or warm air distribution



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Appendix G – Biomass

#### What is Biomass?

Biomass is any fuel obtained from natural or organic material, such as manure, forest debris or agricultural or horticultural waste. The most common biomass energy source is wood in the form of pellets, wood chips or logs. Biomass boilers can be used as a replacement for a fossil fuel-based heat source, and are best suited to medium to large scale sites.



#### Space Requirements

Typically, biomass boilers are contained in a single plant room serving the whole site. This room needs to be big enough for the boiler or boilers themselves, along with water tanks and space for fuel storage.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Installation Costs, Funding, Maintenance and Payback

The cost of a biomass boiler depends on a number of factors, including the type of boiler used, the fuel type and storage size. For example, the cost, including installation, of an automatically-fed pellet boiler can be as much as £20,000. It is important to note that biomass boilers are also eligible for the Government Renewable Heat Incentive (RHI) scheme, which provides payments to those using renewable heating systems. Therefore, despite the high initial cost, biomass boilers can have relatively short payback times of around 5-7 years.

Biomass boilers should be serviced every 12 months to ensure continued efficiency and to prevent any breakdowns.

### Planning

There may be restrictions on the installation of biomass systems, due to concerns over local pollution and disruption to residents caused by deliveries.

### Advantages

- Sustainable energy source
- Reduces dependence on fossil fuels
- Carbon-neutral – the carbon produced is absorbed by plants which can then be used as future biomass fuel
- Reduces waste sent to landfill
- Abundant availability of fuel

### Disadvantages

- The burning of biomass fuels produces various gases that can contribute to local air pollution
- Space is required on-site for a plant room and fuel storage, as well as a designated fuel delivery area
- Constructing and operating biomass energy plants are often more expensive than more traditional power plants

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Appendix H – Combined Heat and Power

#### What is Combined Heat and Power?

Combined Heat and Power (CHP), sometimes referred to as cogeneration, is a setup in which heat and power are generated simultaneously.

Energy which is lost at various steps in producing electricity in a conventional power plant can be captured and used to provide warmth. For example, water which has condensed from the steam used to turn the generating turbine is typically cooled in large cooling towers, with all the energy lost to the air. In a CHP plant, this 'waste' heat is instead used to produce hot water, hot air or steam, which can then be distributed to heat local buildings.



#### Space Requirements

Significant space is required for the power plant itself, as well as the additional space required for the recovery of the otherwise wasted heat. Additionally, to use this energy effectively, a large pipe network is needed to distribute the heat around the local area.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Installation Costs, Funding, Maintenance and Payback

The costs involved with setting up a CHP system, especially if the power plant is being constructed along with it rather than converted, are relatively high. As a result of this, these schemes tend to be large-scale long-term projects.

The network must be kept well maintained to avoid loss of service and to ensure continued operation. However, a large-scale network can heat a wide area more efficiently than with individual building heating systems, providing good long-term return on investments.

### Advantages

- The CHP process can be applied to power plants that use either renewable or fossil fuels as well as those which use a combination of the two

- Emissions are generally lower than other electricity and heat producing systems

- A variety of energy consumers can benefit from the installation of a CHP plant, including hospitals, schools and industrial sites

### Disadvantages

- CHP plants need to be local to their users to ensure as little energy is lost in the transmission as possible.

- The technology needed is expensive and more complex. Maintenance costs can also be greater

- Considerable amount of space is required for a full-size CHP setup, making it suitable only for larger sites

## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Appendix I – District Heating

#### What is District Heating?

Instead of relying on one boiler for each unit on site, district heating utilises hot water or steam from a single communal heat source and distributes that energy to a variety of consumers through a network of insulated pipes. This network can be as large as desired, allowing entire communities to benefit, as well as reducing the need for additional energy to be produced specifically for heating buildings in the local area.

In the individual property or building, a heat interface unit (HIU) gives the consumer control over the hot water they use in a similar manner to that provided by a traditional boiler.



#### Space Requirements

An energy centre or large plant room would be required for this type of system. Depending on the scale of the heat network, pipework may need to be laid underground to distribute the hot water across the site or to the local area.



## Energy Strategy

Project: 5000KJ - 2023.03 SAP (Pier View Hotel - Frank Coletto)

---

### Installation Costs, Funding, Maintenance and Payback

The initial cost of setting up district heating, including the plant and infrastructure needed to deliver the heat, is relatively high and so these large-scale schemes tend to be a long-term investment.

Regular maintenance is essential to ensure continued efficiency and to prevent any breakdowns.

### Advantages

- More energy efficient as energy which is otherwise wasted can be used
- Lower carbon emissions
- Has the potential to reduce heating costs

### Disadvantages

- If the main fuel source experiences problems, whole areas could potentially be without heating or hot water
- Can in some cases be more expensive than traditional heating
- A large network is required to gain full benefit – it is only suitable for use on very large sites or where there is a network already present