


Full SAP Calculation Printout



Property Reference	Flat 1		Issued on Date	26/07/2023	
Assessment Reference	Flat 1 - Baseline	Prop Type Ref			
Property	Flat 1, Pier View Hotel, 34 Oldminster Road, Sharpness, Berkeley, GL13 9NA				
SAP Rating	73 C	DER	31.28	TER	14.78
Environmental	73 C	% DER < TER			-111.64
CO ₂ Emissions (t/year)	2.43	DFEE	107.99	TFEE	50.39
Compliance Check	See BREL	% DFEE < TFEE			-114.31
% DPER < TPER	-119.65	DPER	171.15	TPER	77.92
Assessor Details				Assessor ID	AW87-0001
Client					

SAP 10 WORKSHEET FOR New Build (As Designed) (Version 10.2, February 2022)
 CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE

1. Overall dwelling characteristics

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor			
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)... (1n)	89.6900	3.2000 (2b)	287.0080 (1b) - (4)
Dwelling volume			(3a)+(3b)+(3c)+(3d)+(3e)... (3n) = 287.0080 (5)

2. Ventilation rate


	Value	Reference
Number of open chimneys	0 * 80 =	0.0000 (6a)
Number of open flues	0 * 20 =	0.0000 (6b)
Number of chimneys / flues attached to closed fire	0 * 10 =	0.0000 (6c)
Number of flues attached to solid fuel boiler	0 * 20 =	0.0000 (6d)
Number of flues attached to other heater	0 * 35 =	0.0000 (6e)
Number of blocked chimneys	0 * 20 =	0.0000 (6f)
Number of intermittent extract fans	2 * 10 =	20.0000 (7a)
Number of passive vents	0 * 10 =	0.0000 (7b)
Number of flueless gas fires	0 * 40 =	0.0000 (7c)
Infiltration due to chimneys, flues and fans	(6a)+(6b)+(6c)+(6d)+(6e)+(6f)+(7a)+(7b)+(7c) =	20.0000 / (5) = 0.0697 (8)
Pressure test		No
Pressure Test Method		Blower Door
Measured/design AP50		15.0000 (17)
Infiltration rate		0.8197 (18)
Number of sides sheltered		1 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] =	0.9250 (20)
Infiltration rate adjusted to include shelter factor	(21) = (18) x (20) =	0.7582 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.9667	0.9478	0.9288	0.8340	0.8151	0.7203	0.7203	0.7013	0.7582	0.8151	0.8530	0.8909 (22b)
Effective ac	0.9673	0.9491	0.9313	0.8478	0.8322	0.7594	0.7594	0.7459	0.7874	0.8322	0.8638	0.8968 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Door			1.5700	1.4000	2.1980		(26)
New Windows (Uw = 1.40)			17.0200	1.3258	22.5644		(27)
Ground Floor			89.6900	0.2500	22.4225	110.0000	9865.9000 (28a)
External Wall	107.9000	17.0200	90.8800	0.3000	27.2640	110.0000	9996.8000 (29a)
Corridor Wall	21.7600	1.5700	20.1900	0.3000	6.0570	9.0000	181.7100 (29a)
Total net area of external elements Aum(A, m ²)			219.3500				(31)
Fabric heat loss, W/K = Sum (A x U)					(26)... (30) + (32) =	80.5059	(33)
Party Wall			27.1000	0.0000	0.0000	180.0000	4878.0000 (32)

Full SAP Calculation Printout



Party Ceiling		89.6900		30.0000	2690.7000 (32b)
Internal Wall		207.5300		9.0000	1867.7700 (32c)

Heat capacity Cm = Sum(A x k)	(28)...(30) + (32) + (32a)...(32e) =	29480.8800 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m2K		328.6975 (35)
Thermal bridges (Default value 0.200 * total exposed area)		43.8700 (36)
Point Thermal bridges	(36a) =	0.0000
Total fabric heat loss	(33) + (36) + (36a) =	124.3759 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)												
(38)m	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Heat transfer coeff	91.6126	89.8941	88.2096	80.2976	78.8173	71.9261	71.9261	70.6500	74.5805	78.8173	81.8119	84.9427 (38)
Average = Sum(39)m / 12 =	215.9885	214.2700	212.5855	204.6735	203.1932	196.3020	196.3020	195.0259	198.9564	203.1932	206.1878	209.3186 (39)
												204.6664
HLP	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP (average)	2.4082	2.3890	2.3702	2.2820	2.2655	2.1887	2.1887	2.1744	2.2183	2.2655	2.2989	2.3338 (40)
Days in mont	31	28	31	30	31	30	31	31	30	31	30	31

4. Water heating energy requirements (kWh/year)

Assumed occupancy													2.6215 (42)	
Hot water usage for mixer showers														119.9577 (42a)
Hot water usage for baths	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (42b)	
Hot water usage for other uses	41.4763	39.9681	38.4598	36.9516	35.4434	33.9352	33.9352	35.4434	36.9516	38.4598	39.9681	41.4763 (42c)	148.7281 (43)	
Average daily hot water use (litres/day)														
Daily hot water use	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
Energy conte	161.8954	158.5775	154.4322	147.8785	142.6468	136.9862	134.6260	138.7513	143.1284	149.0950	155.7571	161.4340 (44)		
Energy content (annual)	256.4027	225.8122	237.3566	202.4383	192.0300	168.4406	162.8185	171.8032	176.4916	202.3205	221.9045	252.7666 (45)		
Distribution loss (46)m = 0.15 x (45)m													Total = Sum(45)m = 2470.5853	
Water storage loss:	38.4604	33.8718	35.6035	30.3657	28.8045	25.2661	24.4228	25.7705	26.4737	30.3481	33.2857	37.9150 (46)		
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)		
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)		
Primary loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (59)		
Combi loss	0.5893	0.5639	0.6518	0.6355	0.6631	0.6389	0.6406	0.6334	0.6044	0.6204	0.5917	0.5879 (61)		
Total heat required for water heating calculated for each month	256.9920	226.3762	238.0084	203.0738	192.6932	169.0794	163.4591	172.4366	177.0960	202.9409	222.4962	253.3546 (62)		
WWHRS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63a)		
PV diverter	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63b)		
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63c)		
FGHRS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63d)		
Output from w/h	256.9920	226.3762	238.0084	203.0738	192.6932	169.0794	163.4591	172.4366	177.0960	202.9409	222.4962	253.3546 (64)		
12Total per year (kWh/year)													Total per year (kWh/year) = Sum(64)m = 2478.0062 (64)	
Electric shower(s)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (64a)		
Heat gains from water heating, kWh/month	85.4012	75.2235	79.0840	67.4696	64.0158	56.1662	54.2973	57.2829	58.8346	67.4267	73.9312	84.1919 (65)		
													Total Energy used by instantaneous electric shower(s) (kWh/year) = Sum(64a)m = 0.0000 (64a)	


5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts												
(66)m	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	131.0727	131.0727	131.0727	131.0727	131.0727	131.0727	131.0727	131.0727	131.0727	131.0727	131.0727	131.0727 (66)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	121.9131	134.9752	121.9131	125.9769	121.9131	125.9769	121.9131	121.9131	125.9769	121.9131	125.9769	121.9131 (67)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	238.5063	240.9812	234.7444	221.4670	204.7067	188.9544	178.4308	175.9559	182.1927	195.4701	212.2304	227.9827 (68)
Pumps, fans	36.1073	36.1073	36.1073	36.1073	36.1073	36.1073	36.1073	36.1073	36.1073	36.1073	36.1073	36.1073 (69)
Losses e.g. evaporation (negative values) (Table 5)	3.0000	3.0000	3.0000	3.0000	3.0000	0.0000	0.0000	0.0000	0.0000	3.0000	3.0000	3.0000 (70)
Water heating gains (Table 5)	-104.8581	-104.8581	-104.8581	-104.8581	-104.8581	-104.8581	-104.8581	-104.8581	-104.8581	-104.8581	-104.8581	-104.8581 (71)
Total internal gains	114.7866	111.9398	106.2957	93.7078	86.0427	78.0086	72.9803	76.9932	81.7147	90.6272	102.6822	113.1611 (72)
	540.5278	553.2181	528.2751	506.4735	477.9843	455.2617	435.6460	437.1840	452.2060	473.3322	506.2113	528.3788 (73)

6. Solar gains

[Jan]	Area	Solar flux	g	FF	Access	Gains
-------	------	------------	---	----	--------	-------

Full SAP Calculation Printout



	m2	Table 6a W/m2	Specific data or Table 6b	Specific data or Table 6c	factor Table 6d	W
North	1.4000	10.6334	0.6300	0.7000	0.7700	4.5496 (74)
South	1.0200	46.7521	0.6300	0.7000	0.7700	14.5738 (78)
Southwest	2.1700	36.7938	0.6300	0.7000	0.7700	24.4009 (79)
West	10.2600	19.6403	0.6300	0.7000	0.7700	61.5838 (80)
Northwest	2.1700	11.2829	0.6300	0.7000	0.7700	7.4826 (81)

Solar gains	112.5908	209.8285	327.8874	462.9772	561.8927	574.6300	547.1791	472.3063	375.2848	243.5931	138.3170	94.0222 (83)
Total gains	653.1185	763.0466	856.1625	969.4507	1039.8770	1029.8917	982.8251	909.4903	827.4909	716.9254	644.5282	622.4010 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)													21.0000 (85)
Utilisation factor for gains for living area, ni1,m (see Table 9a)													
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	37.9147	38.2188	38.5216	40.0107	40.3022	41.7170	41.7170	41.9900	41.1604	40.3022	39.7169	39.1228	
alpha	3.5276	3.5479	3.5681	3.6674	3.6868	3.7811	3.7811	3.7993	3.7440	3.6868	3.6478	3.6082	
util living area	0.9980	0.9963	0.9925	0.9802	0.9471	0.8614	0.7370	0.7862	0.9344	0.9876	0.9966	0.9984 (86)	
MIT	18.6103	18.8200	19.1860	19.7463	20.2552	20.6932	20.8842	20.8484	20.5035	19.8434	19.1773	18.6372 (87)	
Th 2	19.0751	19.0866	19.0979	19.1520	19.1622	19.2105	19.2105	19.2196	19.1918	19.1622	19.1415	19.1201 (88)	
util rest of house	0.9970	0.9944	0.9883	0.9674	0.9057	0.7370	0.4991	0.5658	0.8608	0.9773	0.9946	0.9976 (89)	
MIT 2	17.0211	17.2377	17.6095	18.1988	18.6893	19.0891	19.1923	19.1902	18.9428	18.3069	17.6318	17.0780 (90)	
Living area fraction	fLA = Living area / (4) =												
MIT	17.7541	17.9676	18.3367	18.9126	19.4116	19.8290	19.9727	19.9550	19.6627	19.0156	18.3447	17.7972 (92)	
Temperature adjustment	0.0000												
adjusted MIT	17.7541	17.9676	18.3367	18.9126	19.4116	19.8290	19.9727	19.9550	19.6627	19.0156	18.3447	17.7972 (93)	


8. Space heating requirement

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Utilisation	0.9960	0.9928	0.9858	0.9651	0.9131	0.7895	0.6155	0.6736	0.8865	0.9760	0.9932	0.9968 (94)
Useful gains	650.5004	757.5210	844.0149	935.6060	949.5117	813.1243	604.9094	612.6168	733.5513	699.7438	640.1544	620.3816 (95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000 (96)
Heat loss rate W	2905.9355	2799.9857	2516.3109	2049.3067	1566.9432	1026.4635	662.0673	693.3245	1106.7293	1709.9914	2318.5189	2846.1473 (97)
Space heating kWh	1678.0437	1372.5363	1244.1882	801.8645	459.3691	0.0000	0.0000	0.0000	0.0000	751.6242	1208.4224	1655.9696 (98a)
Space heating requirement - total per year (kWh/year)	9172.0180											
Solar heating kWh	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (98b)
Solar heating contribution - total per year (kWh/year)	0.0000											
Space heating kWh	1678.0437	1372.5363	1244.1882	801.8645	459.3691	0.0000	0.0000	0.0000	0.0000	751.6242	1208.4224	1655.9696 (98c)
Space heating requirement after solar contribution - total per year (kWh/year)	9172.0180											
Space heating per m2	(98c) / (4) = 102.2636 (99)											

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													89.1000 (206)
Efficiency of main space heating system 2 (in %)													0.0000 (207)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	1678.0437	1372.5363	1244.1882	801.8645	459.3691	0.0000	0.0000	0.0000	0.0000	751.6242	1208.4224	1655.9696 (98)	
Space heating efficiency (main heating system 1)	89.1000	89.1000	89.1000	89.1000	89.1000	0.0000	0.0000	0.0000	0.0000	89.1000	89.1000	89.1000 (210)	
Space heating fuel (main heating system)	1883.3263	1540.4448	1396.3953	899.9601	515.5657	0.0000	0.0000	0.0000	0.0000	843.5737	1356.2541	1858.5518 (211)	
Space heating efficiency (main heating system 2)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (212)	
Space heating fuel (main heating system 2)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (213)	
Space heating fuel (secondary)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (215)	
Water heating													
Water heating requirement	256.9920	226.3762	238.0084	203.0738	192.6932	169.0794	163.4591	172.4366	177.0960	202.9409	222.4962	253.3546 (64)	
Efficiency of water heater	88.5328	88.4956	88.4152	88.2399	87.8478	85.0000	85.0000	85.0000	85.0000	88.1956	88.4367	88.5333 (217)	
Fuel for water heating, kWh/month	290.2787	255.8049	269.1940	230.1383	219.3489	198.9170	192.3049	202.8666	208.3482	230.1032	251.5881	286.1685 (219)	
Space cooling fuel requirement													
(221)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (221)	
Pumps and Fa	7.3041	6.5973	7.3041	7.0685	7.3041	7.0685	7.3041	7.3041	7.0685	7.3041	7.0685	7.3041 (231)	
Lighting	31.0860	24.9383	22.4542	16.4509	12.7071	10.3818	11.5919	15.0676	19.5713	25.6786	29.0039	31.9499 (232)	

Full SAP Calculation Printout



2. Ventilation rate

	m3 per hour												
Number of open chimneys												0 * 80 = 0.0000 (6a)	
Number of open flues												0 * 20 = 0.0000 (6b)	
Number of chimneys / flues attached to closed fire												0 * 10 = 0.0000 (6c)	
Number of flues attached to solid fuel boiler												0 * 20 = 0.0000 (6d)	
Number of flues attached to other heater												0 * 35 = 0.0000 (6e)	
Number of blocked chimneys												0 * 20 = 0.0000 (6f)	
Number of intermittent extract fans												3 * 10 = 30.0000 (7a)	
Number of passive vents												0 * 10 = 0.0000 (7b)	
Number of flueless gas fires												0 * 40 = 0.0000 (7c)	
												Air changes per hour	
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(6c)+(6d)+(6e)+(6f)+(6g)+(7a)+(7b)+(7c) =												30.0000 / (5) = 0.1045 (8)	
Pressure test												Yes	
Pressure Test Method												Blower Door	
Measured/design AP50												5.0000 (17)	
Infiltration rate												0.3545 (18)	
Number of sides sheltered												1 (19)	
Shelter factor												(20) = 1 - [0.075 x (19)] = 0.9250 (20)	
Infiltration rate adjusted to include shelter factor												(21) = (18) x (20) = 0.3279 (21)	
Wind speed	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000	(22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750	(22a)
Adj infil rate	0.4181	0.4099	0.4017	0.3607	0.3525	0.3115	0.3115	0.3033	0.3279	0.3525	0.3689	0.3853	(22b)
Effective ac	0.5874	0.5840	0.5807	0.5651	0.5621	0.5485	0.5485	0.5460	0.5538	0.5621	0.5681	0.5742	(25)

3. Heat losses and heat loss parameter

Element	Gross m2	Openings m2	NetArea m2	U-value W/m2K	A x U W/K	K-value kJ/m2K	A x K kJ/K						
TER Opaque door			1.5700	1.0000	1.5700		(26)						
TER Opening Type (Uw = 1.20)			17.0200	1.1450	19.4885		(27)						
Ground Floor			89.6900	0.1300	11.6597		(28a)						
External Wall	107.9000	17.0200	90.8800	0.1800	16.3584		(29a)						
Corridor Wall	21.7600	1.5700	20.1900	0.1800	3.6342		(29a)						
Total net area of external elements Aum(A, m2)			219.3500				(31)						
Fabric heat loss, W/K = Sum (A x U)					(26)...(30) + (32) = 52.7108		(33)						
Party Wall			27.1000	0.0000	0.0000		(32)						
Thermal mass parameter (TMP = Cm / TFA) in kJ/m2K							338.6975 (35)						
Thermal bridges (User defined value 0.050 * total exposed area)							10.9675 (36)						
Point Thermal bridges						(36a) = 0.0000							
Total fabric heat loss						(33) + (36) + (36a) = 63.6783	(37)						
Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)													
(38)m	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	55.6354	55.3139	54.9988	53.5186	53.2417	51.9526	51.9526	51.7139	52.4492	53.2417	53.8019	54.3876	(38)
Heat transfer coeff	119.3137	118.9922	118.6771	117.1970	116.9201	115.6310	115.6310	115.3922	116.1275	116.9201	117.4803	118.0660	(39)
Average = Sum(39)m / 12 =												117.1957	
HLP	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	1.3303	1.3267	1.3232	1.3067	1.3036	1.2892	1.2892	1.2866	1.2948	1.3036	1.3098	1.3164	(40)
HLP (average)												1.3067	
Days in mont	31	28	31	30	31	30	31	31	30	31	30	31	

4. Water heating energy requirements (kWh/year)

Assumed occupancy													2.6215 (42)
Hot water usage for mixer showers												87.5775 86.2614 84.3435 80.6741 77.9661 74.9462 73.2297 75.1331 77.2195 80.4619 84.2102 87.2420 (42a)	
Hot water usage for baths												0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 (42b)	
Hot water usage for other uses												41.4763 39.9681 38.4598 36.9516 35.4434 33.9352 33.9352 35.4434 36.9516 38.4598 39.9681 41.4763 (42c)	
Average daily hot water use (litres/day)												118.4493 (43)	
Daily hot water use	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	129.0538	126.2295	122.8034	117.6257	113.4095	108.8814	107.1649	110.5765	114.1711	118.9218	124.1783	128.7183	(44)
Energy content	204.3897	179.7491	188.7442	161.0237	152.6710	133.8824	129.6067	136.9167	140.7844	161.3757	176.9147	201.5417	(45)
Energy content (annual)												Total = Sum(45)m = 1967.6000	
Distribution loss (46)m = 0.15 x (45)m												30.6585 26.9624 28.3116 24.1536 22.9007 20.0824 19.4410 20.5375 21.1177 24.2064 26.5372 30.2313 (46)	
Water storage loss:													
Total storage loss													

Full SAP Calculation Printout



Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000 (96)
Heat loss rate W	1758.5709	1705.6049	1546.4136	1293.2479	997.3603	665.8878	436.7796	458.8065	720.3241	1088.7884	1446.3712	1749.5542 (97)
Space heating kWh	828.1613	640.0625	526.5578	272.5428	96.3737	0.0000	0.0000	0.0000	0.0000	294.5774	582.4200	843.7685 (98a)
Space heating requirement - total per year (kWh/year)												4084.4642
Solar heating kWh	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (98b)
Solar heating contribution - total per year (kWh/year)												0.0000
Space heating kWh	828.1613	640.0625	526.5578	272.5428	96.3737	0.0000	0.0000	0.0000	0.0000	294.5774	582.4200	843.7685 (98c)
Space heating requirement after solar contribution - total per year (kWh/year)												4084.4642
Space heating per m2										(98c) / (4) =		45.5398 (99)

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 1)												0.0000 (201)
Fraction of space heat from main system(s)												1.0000 (202)
Efficiency of main space heating system 1 (in %)												92.4000 (206)
Efficiency of main space heating system 2 (in %)												0.0000 (207)
Efficiency of secondary/supplementary heating system, %												0.0000 (208)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Space heating requirement	828.1613	640.0625	526.5578	272.5428	96.3737	0.0000	0.0000	0.0000	0.0000	294.5774	582.4200	843.7685 (98)
Space heating efficiency (main heating system 1)	92.4000	92.4000	92.4000	92.4000	92.4000	0.0000	0.0000	0.0000	0.0000	92.4000	92.4000	92.4000 (210)
Space heating fuel (main heating system)	896.2785	692.7084	569.8678	294.9598	104.3006	0.0000	0.0000	0.0000	0.0000	318.8068	630.3247	913.1694 (211)
Space heating efficiency (main heating system 2)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (212)
Space heating fuel (main heating system 2)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (213)
Space heating fuel (secondary)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (215)
Water heating												
Water heating requirement	215.3118	190.3676	202.6250	179.6366	175.0166	158.7129	157.6151	163.4702	164.7667	182.4701	192.3969	213.2052 (64)
Efficiency of water heater (217)m	86.9779	86.7697	86.3308	85.2720	83.1567	80.3000	80.3000	80.3000	80.3000	85.4015	86.5970	80.3000 (216)
Fuel for water heating, kWh/month	247.5478	219.3941	234.7078	210.6632	210.4662	197.6499	196.2829	203.5743	205.1889	213.6615	222.1749	245.0069 (219)
Space cooling fuel requirement (221)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (221)
Pumps and Fa	7.3041	6.5973	7.3041	7.0685	7.3041	7.0685	7.3041	7.3041	7.0685	7.3041	7.0685	7.3041 (231)
Lighting	25.3311	20.3216	18.2973	13.4054	10.3547	8.4599	9.4459	12.2782	15.9481	20.9248	23.6345	26.0352 (232)
Electricity generated by PVs (Appendix M) (negative quantity) (233a)m	-30.1031	-43.5947	-64.3449	-74.3431	-81.8683	-77.0119	-76.0448	-70.9402	-62.2336	-50.7204	-33.4950	-25.8910 (233a)
Electricity generated by wind turbines (Appendix M) (negative quantity) (234a)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (234a)
Electricity generated by hydro-electric generators (Appendix M) (negative quantity) (235a)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (235a)
Electricity used or net electricity generated by micro-CHP (Appendix N) (negative if net generation) (235c)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (235c)
Electricity generated by PVs (Appendix M) (negative quantity) (233b)m	-13.6716	-29.0854	-58.4225	-88.6544	-118.1208	-119.0305	-117.6524	-99.2250	-72.1993	-41.9197	-18.3565	-10.7887 (233b)
Electricity generated by wind turbines (Appendix M) (negative quantity) (234b)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (234b)
Electricity generated by hydro-electric generators (Appendix M) (negative quantity) (235b)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (235b)
Electricity used or net electricity generated by micro-CHP (Appendix N) (negative if net generation) (235d)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (235d)
Annual totals kWh/year												
Space heating fuel - main system 1												4420.4158 (211)
Space heating fuel - main system 2												0.0000 (213)
Space heating fuel - secondary												0.0000 (215)
Efficiency of water heater												80.3000
Water heating fuel used												2606.3184 (219)
Space cooling fuel												0.0000 (221)
Electricity for pumps and fans:												
Total electricity for the above, kWh/year												86.0000 (231)
Electricity for lighting (calculated in Appendix L)												204.4368 (232)
Energy saving/generation technologies (Appendices M, N and O)												
PV generation												-1477.7177 (233)
Wind generation												0.0000 (234)
Hydro-electric generation (Appendix N)												0.0000 (235a)
Electricity generated - Micro CHP (Appendix N)												0.0000 (235)
Appendix Q - special features												
Energy saved or generated												-0.0000 (236)
Energy used												0.0000 (237)
Total delivered energy for all uses												5839.4534 (238)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
-----------------	----------------------------	-----------------------

Full SAP Calculation Printout



Space heating - main system 1	4420.4158	0.2100	928.2873 (261)
Total CO2 associated with community systems			0.0000 (373)
Water heating (other fuel)	2606.3184	0.2100	547.3269 (264)
Space and water heating			1475.6142 (265)
Pumps, fans and electric keep-hot	86.0000	0.1387	11.9293 (267)
Energy for lighting	204.4368	0.1443	29.5065 (268)
Energy saving/generation technologies			
PV Unit electricity used in dwelling	-690.5909	0.1340	-92.5605
PV Unit electricity exported	-787.1268	0.1256	-98.8551
Total			-191.4157 (269)
Total CO2, kg/year			1325.6343 (272)
EPC Target Carbon Dioxide Emission Rate (TER)			14.7800 (273)

 13a. Primary energy - Individual heating systems including micro-CHP

	Energy kWh/year	Primary energy factor kg CO2/kWh	Primary energy kWh/year
Space heating - main system 1	4420.4158	1.1300	4995.0699 (275)
Total CO2 associated with community systems			0.0000 (473)
Water heating (other fuel)	2606.3184	1.1300	2945.1398 (278)
Space and water heating			7940.2097 (279)
Pumps, fans and electric keep-hot	86.0000	1.5128	130.1008 (281)
Energy for lighting	204.4368	1.5338	313.5720 (282)
Energy saving/generation technologies			
PV Unit electricity used in dwelling	-690.5909	1.4953	-1032.6574
PV Unit electricity exported	-787.1268	0.4610	-362.8547
Total			-1395.5121 (283)
Total Primary energy kWh/year			6988.3704 (286)
Target Primary Energy Rate (TPER)			77.9200 (287)