

From: Katie Wesley-Smith <[REDACTED]>
Sent: Monday, November 27, 2023 11:19 AM
To: Amy Lang <[REDACTED]>
Subject: 23/01510/FUL: 139 Marine Parade East, Clacton-On-Sea

Good Morning Amy – with reference to the above application, please see below for comments from the EP Team:

Demolition & Construction Method Statement: In order to minimise potential nuisance to nearby existing residents caused by construction and demolition works, Environmental Protection ask that the following is submitted: Prior to the commencement of any construction or demolition works, the applicant (or their contractors) shall submit a full method statement to, and receive written approval from, the Environmental Protection Team. This should at minimum include the following where applicable.

o Noise Control

- 1) The use of barriers to mitigate the impact of noisy operations will be used where possible. This may include the retention of part(s) of the original buildings during the demolition process to act in this capacity.
- 2) No vehicle connected with the works to arrive on site before 07:30 or leave after 19:00(except in the case of emergency). Working hours to be restricted between 08:00 and 18:00 Monday to Saturday (finishing at 13:00 on Saturday) with no working of any kind permitted on Sundays or any Public/Bank Holidays.
- 3) The selection and use of machinery to operate on site, and working practices to be adopted will, as a minimum requirement, be compliant with the standards laid out in British Standard 5228.
- 4) Mobile plant to be resident on site during extended works shall be fitted with non-audible reversing alarms (subject to HSE agreement).
- 5) Prior to the commencement of any piling works which may be necessary, a full method statement shall be agreed in writing with the Planning Authority (in consultation with Pollution and Environmental Control). This will contain a rationale for the piling method chosen and details of the techniques to be employed which minimise noise and vibration to nearby residents.
- 6) If there is a requirement to work outside of the recommended hours the applicant or contractor must submit a request in writing for approval by Pollution and Environmental Control prior to the commencement of works.

o Emission Control

- 1) All waste arising from the demolition process, ground clearance and construction processes to be recycled or removed from the site subject to agreement with the Local Planning Authority and other relevant agencies.
- 2) No materials produced as a result of the site development or clearance shall be burned on site.
- 3) All reasonable steps, including damping down site roads, shall be taken to minimise dust and litter emissions from the site whilst works of construction and demolition are in progress.
- 4) All bulk carrying vehicles accessing the site shall be suitably sheeted to prevent nuisance from dust in transit.

Adherence to the above condition will significantly reduce the likelihood of public complaint and potential enforcement action by Pollution and Environmental Control. The condition gives the best practice for Demolition and Construction sites. Failure to follow them may result in enforcement action under nuisance legislation (Environmental Protection Act 1990), or the imposition of controls on working hours (Control of Pollution Act 1974).

REASON: to protect the amenity of nearby residential dwellings

Should you have any queries concerning this, or if there is something I have missed on this application, please do let me know.

Many Thanks

Katie

Katie W Smith BSc (Hons) MCIEH CEnvH
Chartered Environmental Health Practitioner
Environmental Protection Team Manager

Tel: [REDACTED]

Email: [REDACTED]