

#EAS-LET-23028

SURREY HEATH BOROUGH COUNCIL PLANNING DEPARTMENT

Surrey Heath House
Knoll Road
Camberley
Surrey GU15 3HD

23 November 2023

Re. 14a PILGRIMS WAY, BISLEY, WOKING GU24 9DQ - PP-12626165

To Whom it may concern,

We write to confirm the details for Electric Vehicle Charging as required under condition 8 of allowed appeal decision APP/D3640/W/21/3289233 in relation to application ref. 21/0547/FFU.


Electric Vehicle Charging will, as a minimum, meet the requirements of Building Regulations Approved Document (BR AD) S, Requirement S1 and Regulation 44D: Electric vehicle charging provisions for new residential buildings and must be designed and installed by a specialist to meet BS EN 61851 and BS 7671. Other minimum regulations may also apply.

The proposed dwelling features two parking spaces. In this instance, Requirement S1 (2)(b) requires one charging point to be provided although S1 (3)(b) requires cable routes laid for the second parking space and must meet requirements set out in BR AD S and BS EN 61386-24.

As per BR AD S, (6.2)(b), a charging point will have a minimum output rate of **7kW**

We trust the minimum standards set out above satisfy the requirement to adhere to details required under the relevant condition and said condition can now be discharged.

Yours Sincerely,



Ryan Godfrey
Director, Founder

