



Notes

This drawing has been produced electronically and can be printed at different paper sizes. The scale given in the title plate is only accurate if the drawing is printed at the stated ISO paper size.

The scale given in the title plate applies unless stated otherwise on the drawing page.

The PV system is comprised of 242 x 410 W panels with a total output of 99.22 kW. Panel dimensions: 1722 x 1134 x 30 mm.

Panels are not to be placed within 1m of the roof edges.

Panels are not to protrude more than 1m from the surface of the flat roofs and 200mm from the surface of the pitched roofs.

Northumbria University
Coach Lane Campus

Revision History

No.	Date	Comments
A	12/10/2023	First issue.
B	26/10/2023	Flat roof section removed.

Project

Coach Lane
Newcastle upon Tyne
NE7 7XA

Client

Equans

Drawing description

Proposed Site Plan

Status Information only	Job reference C3069
Scale 1:750	Original size A4
Drawn by AD	Date 26/10/2023

