

## The Commercial Kitchen Filtration Experts

### Specification & EMAQ Report

Project: MORLEY'S INLINE STORE

Prepared for: M&E Pro

Prepared by: Gary McLean

Date: 14<sup>th</sup> November 2023

Contact details:  
e: [gary@mandepro.co.uk](mailto:gary@mandepro.co.uk)



We are pleased to provide an equipment selection for an odour control solution.

As with any project we get involved in we always recommend to our clients that they should closely follow the EMAQ guide for guidance on odour control equipment selection.

This ensures that what they propose will be in line with local authority's requirements and if the system is maintained correctly they will not exhaust nuisance odours leading to complaints from nearby residents.

With this in mind I carried out a risk assessment as detailed in Appendix 3 of the EMAQ Guide. Taking into consideration the level of discharge, proximity of receptors, size of kitchen and cooking type your project requires a high level of odour control to comply.

We have scored as below and as taken from Appendix 3: Risk Assessment for Odour;

Dispersion = 15

Proximity of receptors = 5

Size of kitchen = 5

Cooking type = 10

Total score = 35

The type of odour abatement system that complies is as below, taken directly from the EMAQ Guide and must be to a very high level of control;

**Odour arrestment plant performance**

Very High-level odour control may include:

1. Fine filtration or ESP followed by carbon filtration (carbon filters rated with a 0.4 – 0.8 residence time).
2. Fine filtration or ESP followed by UV ozone system to achieve the same level of control as 1.

| CRITERIA   | SCORE     | SCORE | DETAILS   |
|--|-----------|-------|---|
| <b>Dispersion</b>                                  | Very Poor | 20    | Low level discharge into courtyard or restriction on stack  |
|  | Poor      | 15    | Not low level but below eaves, or discharge at below 10 m/s   |
|  | Moderate  | 10    | Discharging 1m above eaves at 10 – 15 m/s   |
|  | Good      | 5     | Discharging 1m above ridge at 15 m/s  |
| <b>Proximity of receptors</b>                      | Close     | 10    | Closest sensitive receptor less than 20m from kitchen discharge   |
|  | Medium    | 5     | Closest sensitive receptor between 20 and 100m from kitchen discharge   |
|  | Far       | 1     | Closest sensitive receptor more than 100m from kitchen discharge  |
| <b>Size of Kitchen</b>                             | Large     | 5     | More than 100 covers or large sized take away   |
|  | Medium    | 3     | Between 30 and 100 covers or medium sized take away   |
|  | Small     | 1     | Less than 30 covers or small sizes take away  |
| <b>Cooking type<br/>(odour and grease loading)</b> | Very High | 10    | Pub (high level of fried food), fried chicken, burgers or fish and chips.<br><i>Turkish, Middle Eastern, or any premises cooking with solid fuel.</i> |
|  | High      | 7     | Vietnamese, Thai or Indian, <i>Japanese, Chinese or Steakhouse</i>  |
|  | Medium    | 4     | <i>Cantonese, Italian, French, Pizza (gas fired)</i>  |
|  | Low       | 1     | Most pubs, ( <i>no fried food, mainly reheating and sandwiches etc..</i> ), <i>Tea rooms..</i>  |

The first stage of control should be either our Electrostatic Precipitator ESP4500 units.

As the ESP's have been specifically designed for kitchen extract and not modified from industrial use, they have integral sumps to collect the oil, grease and smoke particles filtered out of the exhaust; this not only simplifies servicing but eradicates potentially dangerous spillage from the bottom of the units and greatly cuts down on flammable build-ups within the duct run.

The ionisation voltage has been designed to run at a negative potential which enhances the ionisation of particles and also produces more Ozone which is helpful in reducing odours in kitchen applications.

The ESP units fit in-line with the kitchen ducting and can be configured modularly to cope with all extract volume requirements.

The Electrostatic Precipitator is a very efficient means for separating the particulate phase; operating efficiency when clean can be as high as 98% at particle sizes down to 0.01 micron.

The Electrostatic Precipitator does not present a high-pressure loss (175PA approx. dependant on air flow). This gives a specific advantage in that most standard Kitchen extractor fans will have the capability of overcoming this small differential.

This is particularly advantageous when it is considered that if the pressure loss were high larger noisier fans would probably be necessary resulting in potential noise pollution.

The next stage of control should be either our UV system.

Our UVO1000 unit uses UV technology by producing Ozone to neutralise the cooking odours.

This will be designed and installed with a 2 second dwell time ensuring the system designed meets EMAQ guidelines.

Unlike other UV-C systems, our UV-O units are located outside of the kitchen extract duct and are connected via a spigot and small diameter ducting.

The UV-O range uses UV-C technology to produce ozone and hydroxyl free radicals to oxidise cooking odours through a process of ozonolysis.

Although it is widely accepted that the best way to apply UV-C is directly in-line with the air stream itself, this can incur the problem of the lamps getting dirty and thus greatly reducing their effectiveness. With our UV-O units the air flow does not come from the exhaust duct but from the ambient air around the unit, which is filtered on entry. This means that it is able to provide a uniform supply of ozone and hydroxyl free radicals into the extract system with an extremely low-pressure loss.

As with our UV-C range, for optimum performance we would recommend 2 seconds of dwell time to allow the ozone to work effectively upon the malodorous gasses within the duct.

As you can see the system is in line with EMAQ guidance.

### **Specification**

2No. ESP 4500E Units.

**Specification per unit**

|                             |                      |
|-----------------------------|----------------------|
| Air Volume Max*             | 2.1m <sup>3</sup> /s |
| Electrical Supply           | 220/240V 50Hz 1ph    |
| Power Consumption           | 50 W                 |
| Weight each                 | 115kg                |
| Min/Max Working Temperature | 4/56°C               |
| Max Relative Humidity       | 75%                  |

3No. UV-O 1000 Unit.

**Specification per unit**

|                             |                    |
|-----------------------------|--------------------|
| Air Volume Max              | 2m <sup>3</sup> /s |
| Electrical Supply           | 220/240V 50HV 1ph  |
| Power Consumption           | 700W               |
| Weight                      | 50 Kg              |
| Min/Max Working Temperature | 4/56°C             |
| Max Relative Humidity       | 75%                |