

Good Afternoon,

Scottish Water has no objection to this planning application; however, the applicant should be aware that this does not confirm that the proposed development can currently be serviced and would advise the following:

For all extensions that increase the hard-standing area within the property boundary, you must look to limit an increase to your existing discharge rate and volume. Where possible we recommend that you consider alternative rainwater options. All reasonable attempts should be made to limit the flow.

No new connections will be permitted to the public infrastructure. The additional surface water will discharge to the existing private pipework within the site boundary.

I trust the above is acceptable however if you require any further information regarding this matter please contact me on 0800 389 0379 or via the e-mail address below or at planningconsultations@scottishwater.co.uk.

Kind regards,

Angela Allison

Technical Analyst
Scottish Water

Dedicated Freephone Helpline : 0800 389 0379

Business Email: Angela.Allison@scottishwater.co.uk

Team Mailbox: DevelopmentOperations@scottishwater.co.uk

Business Weblink: <https://www.scottishwater.co.uk/Business-and-Developers/Connecting-to-Our-Network>

The Bridge
Buchanan Gate Business Park
Cumbernauld Road
Stepps
Glasgow G33 6FB

Scottish Water

Trusted to serve Scotland

Please consider the environment before printing this e-mail.

----- Original Message -----

From: Local Planner <developmentmanagement@pkc.gov.uk>;

Received: Fri Dec 01 2023 15:31:14 GMT+0000 (Greenwich Mean Time)

To: <planningconsultations@scottishwater.co.uk>;

Subject: Planning Application Consultation Request for Application No 23/01936/FLL

****EXTERNAL MAIL**** - Think Before You Click

Please see attached.

The information in this email is solely for the intended recipients.

If you are not an intended recipient, you must not disclose, copy, or distribute its contents or use them in any way; please advise the sender immediately and delete this email.

Perth & Kinross Council does not warrant that this email or any attachments are virus-free and does not accept any liability for any loss or damage resulting from any virus infection. Perth & Kinross Council may monitor or examine any emails received by its email system.

The information contained in this email may not be the views of Perth & Kinross Council. It is possible for email to be falsified and the sender cannot be held responsible for the integrity of the information contained in it.

General enquiries to Perth & Kinross Council should be made to enquiries@pkc.gov.uk or 01738 475000.

Privileged/Confidential information may be contained in this Email and any files transmitted with it. If you are not the intended recipient you should not retain, copy or use this Email for any purpose or disclose all or part of its contents to any person. If you have received this Email in error please notify the sender immediately and delete this Email from your system.

Opinions, conclusions and other information in this message that do not relate to the official business of Scottish Water ("SW"), Scottish Water Horizons Ltd ("SWH"), Scottish Water International Ltd ("SWI") or Scottish Water Solutions 2 Ltd ("SWS2") shall be understood as neither given nor endorsed by them. The contents of Emails sent and received by SW, SWH, SWI and SWS2 are monitored.

WARNING: Although SW, SWH, SWI and SWS2 have taken reasonable precautions to ensure no viruses or other malicious software are present, SW, SWH, SWI and SWS2 cannot accept responsibility for any loss or damage arising from the use of this Email or attachments how ever caused. The recipient should therefore check this Email and any attachments for the presence of viruses or other malicious software.

Scottish Water

www.scottishwater.co.uk