

Babergh Mid Suffolk District
Council
Planning Department
Endeavour House
Russell Road
Ipswich
IP1 2BX

Fire Business Support Team
Floor 3, Block 2
Endeavour House
8 Russell Road
Ipswich, Suffolk
IP1 2BX

Your Ref:
Our Ref: FS/F310840
Enquiries to: Water Officer
Direct Line: 01473 260588
E-mail: Fire.BusinessSupport@suffolk.gov.uk
Web Address: <http://www.suffolk.gov.uk>

Date: 25/09/2023

Dear Sirs

Norton Pre-School, Honeywood Corner, Ixworth Road, Norton IP31 3LE
Planning Application No: DC/23/03866/FUL

I refer to the above application.

The plans have been inspected by the Water Officer who has the following comments to make.

Access and Fire Fighting Facilities

Access to buildings for fire appliances and firefighters must meet with the requirements specified in Building Regulations Approved Document B, (Fire Safety), 2019 Edition, Volume 1 - Part B5, Section 11 dwelling houses, and, similarly, Volume 2, Part B5, Sections 16 and 17 in the case of buildings other than dwelling houses. These requirements may be satisfied with other equivalent standards relating to access for firefighting, in which case those standards should be quoted in correspondence.

Suffolk Fire and Rescue Service also requires a minimum carrying capacity for hard standing for pumping/high reach appliances of 15/26 tonnes, not 12.5 tonnes as detailed in the Building Regulations 2000 Approved Document B, 2019 Edition.

Water Supplies

Suffolk Fire and Rescue Service records show that the nearest fire hydrant in this location is over 268m from the proposed build site and we therefore recommend that consideration is given to the provision of water for firefighting purposes.

/continued

OFFICIAL

Should you need any further advice or information on access and firefighting facilities, you are advised to contact your local Building Control or appoint Approved Inspector in the first instance. For further advice and information regarding water supplies, please contact the Water Officer at the above headquarters.

Yours faithfully

Water Officer

Suffolk Fire and Rescue Service

Copy: Mr A Burt, Sussex House, Prospect Road, Norton, Bury St Edmunds IP31 3NH