

---

## Chapel Cottage Window Schedule 06-06-23

---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm	Image
			Fixed single glazed window c40 years old. Very poor thermally and acoustically. Room is cold in winter and traffic noise is very loud.

W-01  
Ground  
Floor Lobby  
(Road  
Noise)

1650

1040



---

Casement window, c40 years old. Rotten sill and windows. Have been significantly filled. Not watertight or draughtproof and acoustically very poor. Road noise is a problem.

W-02  
Lounge  
(Road  
Noise)

970

1160



---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm	Image
---	------------------------------------	-----------------	-------

---

Casement window, c40 years old. Rotten sill and windows. Have been significantly filled. Not watertight or draughtproof.

W-03  
Dining Room

975

1050



Casement window, c40 years old. Rotten sill and windows. Have been significantly filled. Not watertight or draughtproof.

W-04  
Study

1050

910



---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm
---	------------------------------------	-----------------

---

Image

Casement window with fixed centre panel c40 years old. Rotten sill and windows. Have been significantly filled, needs new internal sill. Very draughty. Difficult to access as behind worksurface.

W-05  
Utility

1010

1670



---

Sliding window c40 years old. Difficult to access from outside for cleaning. Draughty.

W-06  
Study  
(Obscure)

750

580



---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm
---	------------------------------------	-----------------

---

Image

Sliding window c 40years old, no internal sill. Painted shut.

W-07  
Lounge  
(Obscure)

750

535



---

Casement window c 40 years old. Very draughty, poor security.

W-08  
Downstairs  
WC  
(Obscure)

720

550



---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm
---	------------------------------------	-----------------

---

Image

Casement window c40 years old, not airtight. Difficult to access as behind sink.

W-11  
Kitchen  
(Facing Rear Garden)

992

866



---

Casement window, c40 years old. Rotten sill and windows. Have been significantly filled. Not watertight or draughtproof.

W-14  
Dressing Room/  
Bedroom 5  
(Road Noise)

880

1055



Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm	Image
---	------------------------------------	-----------------	-------

Casement window, c40 years old. Rotten sill and windows. Have been significantly filled. Not watertight, soundproof or draughtproof.

W-15  
Bedroom 1  
(Road Noise)  
790  
1030



Casement window, c40 years old. Rotten sill and windows. Have been significantly filled. Not watertight, soundproof or draughtproof.

W-16  
Dressing Room/  
Bedroom 4  
830  
1210



---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm	Image
---	------------------------------------	-----------------	-------

---

Casement window, c40 years old. Rotten sill and windows. Have been significantly filled. Not watertight, soundproof or draughtproof.

W-17  
Bathroom      790      1040



Casement window, c40 years old. Rotten sill and windows. Have been significantly filled. Not watertight, soundproof or draught proof.

W-18  
Bedroom 3      880      890



---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm	Image
---	------------------------------------	-----------------	-------

---

Casement window, c20 years old. Has been significantly filled.  
Not soundproof or draught proof.

W-19  
Study/  
Dressing  
Room  
(Road  
Noise)

1000

608



Casement window, c20 years old. Has been significantly filled.  
Not soundproof or draught proof.

W-21  
Bedroom 2

806

606





---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm
--	---------------------------------------	--------------------

---

Image

Door leafs are very narrow and difficult to get through, rotten  
doorstep and doors. Very draughty with poor thermal  
retainment.

D-05 French Window/ Door
-----------------------------------

1821

967



---

Window Number (See drawing for location)	Approx Height mm (Not inc sill)	Approx Width mm
--	---------------------------------------	--------------------

---

Image

---

Casement window c 20 years old. Poor thermal retainment.

W-09  
Music  
Room  
Front

1016      1169



---

Casement window c 10 years old. Poor thermal retainment.

W-10  
Music  
Room  
(Facing VH)

1009      1168



---

Casement window c 20 years old. Poor thermal retainment.

W-12  
Kitchen      926      1013



---

Casement window c 20 years old. Poor thermal retainment.

W-13  
Music  
Room      857      1176



---

Casement window, c20 years old. Poor Thermal retainment

W-20  
Bedroom 2      1152      858



---