

12/12/2023

Telephone No: 07989 701 275
Applicant's reference: 4767022

To: Chief Planning Officer, Shropshire Council

Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009


It is proposed to undertake the following work that is considered to be exempted from Section 37 of the Electricity Act 1989 by falling within the Overhead Lines (Exemption)(England and Wales) Regulations 2009:
Particulars of proposed development:-

- Replace six spans of open wire conductor with bunched ABC conductor totalling 290m.
- Replace five existing poles within the existing line.

National Grid are to replace six spans of existing open wire conductor with a bunched ABC conductor at Lower Heath, Whitchurch, Shropshire. SY13 2BH. This consists of 290m of conductor and five existing poles will also be replaced on a like for like basis. The apparatus in question is highlighted yellow on the attached plan.

The Council is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

Yours faithfully



For and on behalf of the Applicant

CERTIFICATE 4767022

TO BE COMPLETED BY THE LOCAL PLANNING AUTHORITY AND RETURNED TO THE APPLICANT ELECTRICITY NETWORK COMPANY WITHIN SIX WEEKS OF RECEIPT

Shropshire Council

* (i) objects/does not object for the proposed development detailed above to be undertaken under the exemptions laid down in the Overhead Lines (Exemption)(England and Wales) Regulations 2009

* (ii) wishes/does not wish the Secretary of State to consider the application using the full section 37 process under the Electricity Act 1989

*The reasons for requesting the full section 37 process are:

Dated:

Signed:

Designation

(on behalf of Shropshire Council)

Yours sincerely,

David Ford
Wayleave Specialist
Dford1@nationalgrid.co.uk

01782403695
079897010275