



DRAINAGE LEGEND:-

- EXISTING COMBINED SEWER.
- EXISTING SURFACE WATER SEWER.
- PROPOSED SURFACE WATER SEWER & MANHOLE TO BE ADOPTED BY SCOTTISH WATER
- PROPOSED FOUL WATER SEWER & MANHOLE TO BE ADOPTED BY SCOTTISH WATER
- PROPOSED FOUL WATER SEWER & MANHOLE TO BE PRIVATELY MAINTAINED
- PROPOSED ROAD GULLY TO BE PRIVATELY MAINTAINED
- PROPOSED PRIVATE FILTER TRENCH WITH POROUS COLLECTOR PIPE BELOW.
- PROPOSED LINEAR CHANNEL DRAIN

NOTE:
 ALL EXISTING SEWERS TO BE CHECKED AND INVERT LEVELS TO BE ADVISED TO ENGINEER PRIOR TO WORK COMMENCING ON SITE.
 REFER TO G3 DRAWING J5194-042 FOR ADOPTIONS AND SERVITUDE LAYOUT

- Notes**
1. THIS DRAWING IS COPYRIGHT, RESERVED AND REMAINS THE PROPERTY OF G3 CONSULTING ENGINEERS LIMITED.
 2. THE CONTRACTOR AND HIS SUBCONTRACTORS/SUPPLIERS ARE TO VERIFY ALL DIMENSIONS AND LEVELS ON SITE BEFORE MAKING SHOP DRAWINGS OR COMMENCING MANUFACTURE.
 3. DO NOT SCALE THIS DRAWING. ONLY USE FIGURED DIMENSIONS. THE CONTRACTOR IS TO BRING TO THE NOTICE OF THE ENGINEER ANY DISCREPANCIES CONTAINED IN THIS DRAWING PRIOR TO WORK COMMENCING. WHERE REQUIRED THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGN DRAWINGS AND SPECIFICATIONS.
 4. ALL WORK TO CONFORM TO THE RELEVANT BRITISH STANDARDS.
 5. THE CONTRACTOR SHALL NOTIFY SCOTTISH WATER AND THE LOCAL AUTHORITY PRIOR TO COMMENCING WORK ON SEWERS.
 6. ALL SEWERS TO BE CONSTRUCTED TO THE SATISFACTION OF THE LOCAL AUTHORITY AND SCOTTISH WATER INSPECTORS.
 7. NO SEWERS TO BE BACKFILLED UNTIL TESTED TO THE SATISFACTION OF SCOTTISH WATER.
 8. CONTRACTOR TO CHECK THE LEVEL AND CONDITION OF ALL EXISTING SEWERS. INVERT LEVELS TO BE ADVISED TO ENGINEER PRIOR TO WORKS COMMENCING ON SITE.
 9. POSITION OF GULLIES ARE APPROXIMATE ONLY AND ARE TO BE POSITIONED AT LOW POINTS ON HARDSTANDING OR ROADS TO AVOID PONDING. ACTUAL POSITION TO BE AGREED ON SITE.
 10. ALL DRAINAGE TO BE CONSTRUCTED IN ACCORDANCE WITH SEWERS FOR SCOTLAND 3rd EDITION AS PUBLISHED BY SCOTTISH WATER.
 11. ALL PIPES TO BE UPVC STRUCTURED WALL TO WIS 4-35-01 UNLESS NOTED OTHERWISE.
 12. MINIMUM PIPE DIAMETER TO BE 150MM.
 13. DMS TO BE 930MM DEEP UNLESS NOTED OTHERWISE. REFER TO DWG J5098-856 FOR DETAILS.
 14. ALL LAYOUTS AND EXTENT OF ATTENUATION IS PROVISIONAL. PENDING SUBMISSION / APPROVAL FROM SCOTTISH WATER.
 15. FOR SITE LAYOUT REFER TO DRAWING J5194-32
 16. FOR DRAINAGE DETAILS REFER TO DRAWINGS J5194-45 & 46
 17. FOR LONGITUDINAL SECTIONS REFER TO DRAWING J5194-47&48.
 18. FOR MANHOLE SCHEDULE REFER TO DRAWING J5194-050.
 19. YARD GULLIES TO BE PROVIDED IN REAR PATIO AREAS.
 20. FOR BUILDING DRAINAGE REFER TO ARCHITECTS DRAWINGS.
 21. REFER TO ARCHITECTS DRAWING FOR THRESHOLD DRAIN DETAILS.
 22. THE PRINCIPAL CONTRACTOR SHOULD REVIEW THE IPSUM CCTV REPORT DATED DECEMBER 2021 AND CONFIRM THAT ALL TALLS DRAINING INTO EXISTING SEWERS TO BE ABANDONED OR DIVERTED WILL NOT HAVE AN IMPACT ON THE EXISTING SURROUNDING PROPERTIES.

A	REVISED TO SUIT UPDATED LAYOUT	JBu	SN	13/12/23
---	--------------------------------	-----	----	----------

DOCQUET
 We hereby certify this is a true and fair copy of the plan/drawing referred to in the Application.
 Dated _____ Signed _____

client
COLLECTIVE ARCHITECTURE

project
**KILDONAN STREET
 COATBRIDGE**

title
DRAINAGE LAYOUT

Orion House, 7 Robroyston Oval, Nova Business Park, Glasgow, G33 1AP
 T: 0141-558-3256, E: enquiries@g3eng.co.uk

ace
 The Scottish Government

FQM
 ISO 9001:2008 REGISTERED FIRM

FQM
 ISO 14001:2004 REGISTERED FIRM

drawn	checked	date
MS		21/01/22
scales	1:200	sheet size A1
Drawing Number	J5194-CP041	Revision
		A