

Consultee Comments for Planning Application 23/03489/PLF

Application Summary

Application Number: 23/03489/PLF

Address: Land North West Of Brookdale 31 Dale Road Elloughton East Riding Of Yorkshire HU15 1HY

Proposal: Erection of a dwelling with solar panels, construction of vehicular access and associated infrastructure

Case Officer: Mrs Sarah Lamming

Consultee Details

Name: . Yorkshire Water Services Ltd Developer Services

Address: Yorkshire Water Services Ltd, Developer Services Pre Development Team PO Box 52, Bradford BD3 7AY

Email: Not Available

On Behalf Of: Yorkshire Water Services Limited (YWSCA)

Comments

Details reviewed - Latest proposed site layout plan shows foul water only to be drained and connected to manhole for T2011 public combined sewer located to the side of no.31 and surface water shown going to crate soakaway, on this basis, no observation comments required. Please note, if surface water disposal changes from crate soakaway to the T2011 public sewer, YW will need to be re-consulted as further details maybe required.