

From: BMSDC Planning Area Team Yellow <planningyellow@babberghmidsuffolk.gov.uk>

Sent: 22 Dec 2023 01:57:33

To:

Cc:

Subject: FW: DC/23/04828

Attachments:

From: Richard Divey <Richard.Divey@babberghmidsuffolk.gov.uk>

Sent: Friday, December 22, 2023 1:48 PM

To: Grace Waspe <Grace.Waspe@babberghmidsuffolk.gov.uk>; BMSDC Planning Area Team Yellow <planningyellow@babberghmidsuffolk.gov.uk>

Subject: DC/23/04828

APPLICATION FOR PLANNING PERMISSION - DC/23/04828 Proposal: Householder Application - Erection of garden room and domestic pool with associated plant room Location: Benningham Grange Barn, Benningham Green, Occold, Eye Suffolk IP23 7PJ

Heating and ventilation plant and equipment for swimming pools can cause noise issues therefore the following condition/s are relevant.

The application shall not be determined/ the development shall not commence until full and details of all plant to be installed including precise acoustic specification, as well as a noise assessment, to include details of the current existing background level, to be based on methodology as given in British Standard BS4142:2014 have been submitted to an approved by the LPA, in order to allow the likelihood of loss of amenity to be determined.

Reason: to minimise detriment to nearby residential amenity

Regards

Richard Divey,

Senior Environmental Protection Officer

Babergh and Mid Suffolk District Council - Working Together

Tel: 01473 296315

Email: richard.divey@babberghmidsuffolk.gov.uk

www.babergh.gov.uk www.midsuffolk.gov.uk