



**PLEASE SIGN  
FOR APPROVAL**

RETURN BY EMAIL TO:  
[ptauk-approval@premiertech.com](mailto:ptauk-approval@premiertech.com)

Ref: P210906-WOODSIDE

SIGNATURE: .....

NAME: .....

DATE: .....

Premier Tech Water & Environment Limited

ALL TANKS SHOWN ARE AVAILABLE AS:

CLASS 1 - CONCRETE/GRANULAR SURROUND

CLASS 2 - CONCRETE SURROUND ONLY

THIS DRAWING IS ISSUED FOR REFERENCE  
PURPOSES ONLY. OTHER CONFIGURATIONS ARE  
AVAILABLE. PLEASE CONTACT OUR TECHNICAL  
TEAM FOR FURTHER INFORMATION

- Notes**
1. This drawing is provided for indicative purposes only and without prejudice.
  2. Please refer to attached quotation for further details.
  3. Levels and depths of installation to be confirmed by client.
  4. All standard concrete design by others.
  5. All interconnecting pipework and manholes by others.
  6. Unless stated otherwise all tanks are designed for backfill with concrete surround, (surround not shown for clarity).
  7. Concrete base and surround to be designed by others to suit local ground conditions.
  8. See individual tank drawings for further details.
  9. Minimum distance between tanks 450mm

A	22.10.21	CW	PS	DE	ISSUED FOR INFORMATION/APPROVAL				
REV.	DATE	BY	CHKD.	APPD.	DESCRIPTION				
				<b>GENERAL TOLERANCES (unless noted otherwise)</b> GRP FABRICATED MACHINED    LINEAR    ± 5mm / ± 2mm / ± 0.5mm    ANGLE    ± 0.5° / ± 0.2° / ± 0.1°			<b>IMPORTANT INVERT LEVEL NOTE (RIBBED TANKS ONLY):</b> The inlet and outlet Invert Level(IL) shown on this drawing is to internals of the shell unless otherwise stated. For Invert level to the outside of the shell ribs, see the conversion below: ø1.5m, 1.8m, 2.5m    IL+50mm ('X') ø3.0m, 4.0m    IL+75mm ('X')		
FOR INTERNAL USE ONLY				TANKS SUPPLIED WITH LOOSE SHAFTS DO NOT COME SUPPLIED WITH A FIXING KIT. THIS IS THE RESPONSIBILITY OF THE SITE CONTRACTOR.					
A3	DO NOT SCALE IF IN DOUBT ASK ALL DIMENSIONS IN MM		THIS DRAWING IS THE PROPERTY OF PREMIER TECH WATER AND ENVIRONMENT LTD AND IS NOT TO BE COPIED IN PART OR WHOLE WITHOUT WRITTEN PERMISSION						

TITLE <b>GA FOR CSAF250N20 SEWAGE TREATMENT SCHEME WITH ECOFLO 6 – CLASS 2</b>					
DRAWN BY CW	CHKD. PS	APPD. DE	SCALE NTS	DRAWING No. CSAF250N20 + ECO SCHEME	PAGE 1/1
DATE 27.09.21	DATE 27.09.21	DATE 27.09.21			