



- 21: Please provide cavity tray and lead flashing at roof/wall abutments. 22: 100mm gutter and 63mm down pipe. All drainage details to be agreed on site between building control and contractor. 23: Provide mechanical ventilation to bathrooms utilities kitchens giving min 15ltrs per second extraction to bathrooms 30ltrs per second extraction to utilities and kitchens. 24:Provide mains operated smoke detection as shown linked together with battery backup. this drawing is to used only for planning/building regulation submission not as a "working drawing" if used as such all dimensions to be checked on site by contractor. all work to be carried out to satisfaction of local authority. prior to commencement of work on site principal contractor/building owner to produce a method statement with regard to saftey of occupiers/ employees during building operations builder to allow for safe support of existing/new structure during contract. Any structure being used for support must be checked to determine suitability. if found not suitable please contact PCE Designs Ltd for
- All electrical work to be carried out to BS7671:2001 and be installed and tested by a competent person. The Local Authority may request a test certificate under the above BS.

further instruction

20: If necessary contact manufactures of products.

