



DO NOT SCALE

NOTES

IF THIS DRAWING HAS BEEN RECEIVED ELECTRONICALLY IT IS THE RECIPIENTS RESPONSIBILITY TO PRINT THE DOCUMENT TO THE CORRECT SCALE.


ALL DIMENSIONS ARE IN MILLIMETERS UNLESS STATED OTHERWISE IT IS RECOMMENDED THAT INFORMATION IS NOT SCALED OFF THIS DRAWING.

THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS FORMING THE EXTENT OF THIS WORKS PACKAGE.

CROSS REFERENCE SHOULD BE MADE TO ARCHITECTS & STRUCTURAL ENGINEERING DRAWINGS WHERE APPLICABLE.

THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ARCHITECTS FIRE STRATEGY DRAWING FOR COMPARTMENTATION WHERE APPLICABLE.

LEGEND

-  8W, REALTA WALL MOUNTED LED, WIDE DISTRIBUTION BY THORLUX, PHOTOCCELL, IP66, 4000K

- NOTES**
1. THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH DSSR MECHANICAL SERVICES LAYOUTS AND ARCHITECTURAL LAYOUTS
 2. DO NOT SCALE FROM THIS DRAWING.
 3. ELECTRICAL INSTALLATION SHALL BE IN ACCORDANCE WITH BS 7671, THE 18TH EDITION WIRING REGULATIONS AND ALL RELEVANT HTM DOCUMENTS.
 4. EXTERNAL LIGHTING SHALL BE CONTROLLED BY PHOTOCCELL AND TIMECLOCK ARRANGEMENT.

P03	15.12.23	FITTINGS UPDATED	MK
P02	23.11.23	STAGE 3 ISSUE	MK
P01	30.08.23	STAGE 2 ISSUE	MK
PO	MAY 23	ISSUED FOR COMMENTS	JK
REV	DATE	DESCRIPTION	ISSUED BY

Drawing Status: **RIBA STAGE 3** **S3**

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

READERS OF THIS DRAWING:
 ALL EFFORTS HAVE BEEN TAKEN BY DSSR TO DESIGN OUT SIGNIFICANT HAZARDS WITHIN THE DESIGN RISK ASSESSMENT PROCESS. IT IS OUR OPINION THAT THE HAZARDS DETAILED BELOW CANNOT BE DESIGNED OUT BY US GIVEN THE CONSTRAINTS OF THE BRIEF AND ARE HIGHLIGHTED SO THAT OTHER MEANS CAN BE DEVELOPED TO MITIGATE THE RESIDUAL RISKS IDENTIFIED.

IT IS ASSUMED THAT A COMPETENT M&E CONTRACTOR OR USER WILL BE AWARE OF THE STANDARD FORESEEABLE RISKS ASSOCIATED WITH WORKING WITH THE TYPE OF SERVICES DETAILED WITHIN THE DRAWING.

DSSR | CONSULTING ENGINEERS
 Glasgow Harrogate London Manchester

Manchester Office
 Trafford House
 Chester Road
 Stretford
 Manchester
 M32 0RS

Tel: +44 (0)161 872 4811
 manchester@dssr.co.uk
 www.dssr.co.uk

MTX Contracts LTD
 Innovation House
 Brooke Court
 Lower Meadow Road
 Handforth
 Cheshire
 SK9 3HD
 T: 0161 694 0123
 info@mtxcontracts.co.uk
 www.mtxcontracts.co.uk

PROJECT:
 SKEGNESS CDC

TITLE:
 EXTERNAL BUILDING MOUNTED LIGHTING LAYOUT LEVEL 00

Designed By	SM	Checked By	NC	DSSR Ref	M5302
Drawn By	SM	Date	JUN 23	Size & Scale(s)	A1 1:75

Project - Originator - Volume - Level - Type - Role - Number
 DRAWING No: **P23-0012-DSSR-XX-00-DR-E-90601** **P03**

EXTERNAL BUILDING MOUNTED LIGHTING LAYOUT