

DRAIN SERVICES UK

7 Sunbury Green, Leicester, LE5 2QL
Tel 07468412697, E paulflear@aol.com

DRAIN REPORT

Date 12/10/22

page 1

Site the Greendale Oak

Pipe size 100mm

F1 up stream	3.69	end of run
F1 br1	4.11	gents wc
F1 br2	1.53	urinal trap
F1 down stream	5.24	enters f2
F2 br1	1.43	enters gully
F2 br2	8.81	junction enters
F2 br2	8.81	bar drain end
F2 br3	5.98	ladies wc
F2 br4	6.69	ladies wc
F2 br5	4.97	ladies wc
F2 br6	2.78	enters gully
F2 down stream	7.27	double junction enters
	8.74	displaced open joint
	10.00	enters manhole
F4 up stream	0.51	hole in drain
	6.91	radial crack
	8.27	large displacement
	11.96	radial crack
	12.28	drain broken
	12.60	multiple breaks
	13.13	multiple breaks
	13.34	junction enters broken
	13.77	multiple breaks
	14.20	multiple breaks
	14.94	end of breaks
This run needs extensive jetting and further investigating		
F4 br1	0.20	large displacement
	1.74	open joint
	2.57	root ingress
	3.60	open joint

DRAIN SERVICES UK

7 Sunbury Green, Leicester, LE5 2QL
Tel 07468412697, E paulflear@aol.com

Continued

The Greendale Oak

page 2

	4.01	enters gully
F4 down stream	0.61	open joint
	1.12	drain drops down
	1.73	very large displacement open joint
	1.73	unable to pass
F3 br1	0.31	open joint
	0.83	open joint
	5.48	enters gully
F3 br2	0.20	large displacement open joint
	0.31	open joint
	3.92	junction enters
	4.95	staff wc
F3 down stream 150mm	0.83	displaced open joint
	1.44	radial crack
	4.13	radial crack
	5.06	open joint
	6.94	open joint
	7.68	radial crack
	9.04	junction enters from right
	11.80	junction enters from left
	14.04	scale on bottom of drain
	14.47	enters f5
F5 down stream	0.03	open joint
	2.37	medium displacement root ingress slight
	5.59	radial crack
	6.64	enters main sewer
F5 br1	0.83	large displacement
	3.82	large displacement
	4.02	enters gully scaled
F5 br2	3.20	large displacement
	10.43	end of run badly scaled hole run
F5 br3	2.37	very large displacement
	2.68	enters soil pipe
F5 br4	0.52	large displacement
	1.24	very large displacement
	2.58	displaced radial crack
	3.09	radial crack

DRAIN SERVICES UK

7 Sunbury Green, Leicester, LE5 2QL
Tel 07468412697, E paulflear@aol.com

Continued	3.82	large displacement unable to pass	page 3
S1 up stream	9.38	full of stone have high pressure jetted but just keeps	
filling with stone have taken out 4 buckets of		stone out suspect collapsed	
	9.00	open joint	
	8.43	open joint	
	5.50	drain broken at top	
	4.50	junction enters to right	
	4.39	open joint	
	1.74	displaced	
Tracing and further investigation needed on this run			
S1 br1	0.51	root ingress	
	2.15	displaced root ingress	
	2.77	root ingress	
	3.18	root ingress	
	3.90	junction enters from right	
	4.83	root ingress	
	6.49	root ingress	
	9.74	junction enters from right	
	10.89	large displacement	
	11.64	enters gully	
S1 br2	11.62	enters gully	
S1 br3	3.08	enters gully	
S1 down stream	1.73	open joint	
	3.07	drain cracked at 3 o clock	
	3.38	open joint	
	4.36	junction enters from left	
	5.85	radial crack	
	7.83	displaced radial crack	
	8.88	very large displacement open joint root ingress	
	9.20	drain turns right	
	9.30	very large displacement	
	9.62	radial crack	
	10.46	very large displacement open joint	
	11.08	large displacement drain cracked	
	11.82	drain broken	
	12.14	drain broken	
	12.46	open joint	
	12.99	radial crack	
	15.56	radial crack	

DRAIN SERVICES UK

7 Sunbury Green, Leicester, LE5 2QL
Tel 07468412697, E paulflear@aol.com


Continued	16.73	open joint	page 4
	18.24	open joint	
	19.00	radial crack	
	20.41	junction enter from right	
	24.90	enter main drain	
S2 up stream	5.84	drain broken	
	4.91	junction enters from right	
	3.88	radial crack	
	2.02	large displacement	
	1.31	junction from top of drain	
		Holding water full length of drain	
S2 br1	0.51	drain collapsed	
	1.22	unable to pass	
S3 down stream	0.52	displaced open joint	
	1.03	radial crack	
	2.68	holding water full length of drain	
S3 br1	2.27	end of run	
	1.44	radial crack	
	1.03	large displacement radial crack	
	0.93	radial crack root ingress	
	0.31	radial crack root ingress	
S3 br2	0.01	drain broken	
	0.30	drain has multiple breaks	
	0.81	unable to pass	
S3 br3	0.02	radial crack	
	1.13	large displacement open joint	
	1.85	radial crack	
	2.47	radial crack	
	3.08	radial crack	
	4.84	radial crack	
	5.15	enters hidden manhole inside house	
	6.52	radial crack	
	7.55	radial crack	
	10.19	radial crack open joint	
	11.46	radial crack open joint	
	12.42	looks like concrete or hard silt in drain	

Intensive high pressure jetting road gullys carpark all drains need descaling and further investigation needed to trace some drains.

End of survey

DRAIN SERVICES UK

7 Sunbury Green, Leicester, LE5 2QL
Tel 07468412697, E paulflear@aol.com



DRAIN SERVICES UK

7 Sunbury Green, Leicester, LE5 2QL
Tel 07468412697, E paulflear@aol.com