



Label	CalcType	Units	Avg	Max	Min	MiniAvg	MiniMax
Building Perimeter	Illuminance	Lux	16.30	133	0	N.A.	N.A.
Car Park	Illuminance	Lux	21.78	104	6	0.28	0.06
Contour Lines	Illuminance	Lux	2.92	129	0	N.A.	N.A.
Main Entrance Path	Illuminance	Lux	26.46	138	7	0.29	0.05
Path From Car Park To Entrance	Illuminance	Lux	34.36	68	18	0.52	0.06
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	31.84	37	27	0.85	0.73
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	170.82	288	80	0.47	0.28
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	157.05	270	76	0.48	0.28
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	163.08	273	79	0.48	0.29
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	140.73	207	92	0.65	0.44
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	39.15	54	35	0.89	0.65
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	35.80	39	33	0.92	0.85
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	35.41	38	33	0.93	0.87
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	130.59	274	96	0.28	0.13
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Cd	N.A.	152.15	236	86	0.57	0.36
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.
Surrounding Buildings Verticals	Obtrusive Light - Ill	Lux	0.00	0	0	N.A.	N.A.

- Luminaire Schedule**
A Tamelite Lighting Explorer floodlight on 8m column
B Tamelite Lighting City BL bollard
C Tamelite Lighting Taurus wall fitting

B	02.03.18	Construction Issue.	
A	02.02.18	Construction Issue.	
ISSUE	DATE	DESCRIPTION	
184 Regent Street, Nantborough, Leicester LE19 2DT ☎ 0116 277 8687 🌐 www.acorn-mps.co.uk			
CLIENT: whetstone BAPTIST CHURCH			
PROJECT DESCRIPTION: New Church Building Dog & Glen Lane			
DRAWING TITLE: External Lighting Layout			
STATUS:		CONSTRUCTION	
JOB No:	10818	SCALE:	1:125
SIZE:	A0	DATE:	02.03.18
DRAWN:	DH	CHECKED:	MJ
DRG No:	E/001		