



GROUND FLOOR GENERAL ARRANGEMENT - STRUCTURE OVER

PAD FOUNDATIONS - FORMATION LEVEL TO BE AGREED ON SITE WITH BUILDING CONTROL OFFICER. MUST BE ONTO VIRGIN GROUND WITH A MINIMUM A.B.P OF 125kN/m²

TYPE 1 - 1.0m WIDEx0.75m LONGxMINIMUM 0.375m THK
1 LAYER A393 MESH TO BOTTOM (50mm COVER)

TYPE 2 - 0.6m WIDEx0.6m LONGxMINIMUM 0.30m THK

TYPE 3 - 0.65m WIDEx0.65m LONGxMINIMUM 0.325m THK
1 LAYER A393 MESH TO BOTTOM (50mm COVER)



PRELIMINARY FOR BUILDING REGS

NOTES

1. DO NOT SCALE.
2. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED. THE CONTRACTOR IS TO CHECK THAT ALL DIMENSIONS ARE IN ACCORDANCE WITH CURRENT ARCHITECT'S DRAWING BEFORE COMMENCING WORK OR ORDERING ANY MATERIALS.
3. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.
4. ANY DISCREPANCIES FOUND ON THIS DRAWING OR ANY OTHER RELEVANT INFORMATION ARE TO BE BROUGHT TO THE ATTENTION OF THE ENGINEER AS SOON AS THEY ARE DISCOVERED.
5. ALL CONSTRUCTION TO BE TO RELEVANT BRITISH STANDARDS, NHBC STANDARDS AND IN ACCORDANCE WITH CURRENT BUILDING REGULATIONS.
6. REINFORCED CONCRETE - LAPS TO MESH min. 400mm. LAPS TO BARS min. 40 x BAR DIAMETER. COVER TO REINFORCEMENT TO BE:
40mm TOP AND SHUTTERED FACES
75mm ELSEWHERE
7. BENDING SCHEDULE TO BE CHECKED BY CONTRACTOR BEFORE ORDERING REINFORCEMENT.

PRIOR ASSOCIATES
Consulting Engineers
1st Floor Offices
S.T.R.F.C.
Julius Martin Lane
Soham
Ely, Cambs.
CB7 5EQ
Tel 01353 722330
Email: mail@prior-associates.co.uk
Web Site: www.prior-associates.co.uk

Client		MR & MRS HARRIS	
Project		3 HIGH STREET, CLARE	
Section		PROPOSED GROUND FLOOR DESIGN	
Designed ML	Drawn CS	Checked /	Rev
Date SEPT 22	Scale 1:50 @ A3	Drawing No. 15617-01	