

From: Development Control
Subject: FW: Consultation request - 24/00032/HOUSE Twin Oaks Uplowman Tiverton

From: Developer Services Planning [REDACTED]
Sent: 24 January 2024 14:10
To: Development Control <devcon@middevon.gov.uk>
Subject: RE: Consultation request - 24/00032/HOUSE Twin Oaks Uplowman Tiverton

Good afternoon,

Thank you for the consultation request.

Location: Twin Oaks Uplowman Tiverton
Your ref: 24/00032/HOUSE
Our ref: PC240124EX167DP

Proposal: Erection of single storey extension to form ancillary accommodation and attached annexe

With reference to the planning application at the above address, the applicant/agent is advised to contact South West Water if they are unable to comply with our requirements as detailed below.

Surface Water Services

The applicant should demonstrate to your LPA that its prospective surface run-off will discharge as high up the hierarchy of drainage options as is reasonably practicable (with evidence that the Run-off Destination Hierarchy has been addressed, and reasoning as to why any preferred disposal route is not reasonably practicable):

1. Water re-use (smart water butts, rainwater harvesting, grey flushing toilets)
2. Discharge into the ground (infiltration); or where not reasonably practicable,
3. Discharge to a surface waterbody; or where not reasonably practicable,
4. Discharge to a surface water sewer, highway drain, or another drainage system; or where not reasonably practicable,
5. Discharge to a combined sewer. (Subject to Sewerage Undertaker carrying out capacity evaluation)

No surface water strategy details were provided with this planning application. Please note that a discharge into the ground (infiltration) is South West Water's favoured method and meets with the Run-off Destination Hierarchy. Should this method be unavailable, SWW will require clear evidence to demonstrate why the preferred methods listed within the Run-off Destination Hierarchy have been discounted by the applicant.

<https://eur01.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.southwestwater.co.uk%2Fbuilding-and-development%2Fservices%2Fpre-development-services&data=05%7C02%7Cdevcon%40middevon.gov.uk%7C0b034f1605e64e166a3c08dc1ce6380f%7C8ddf22c7b00e442982f6108505d03118%7C0%7C0%7C638417022315799713%7CUnknown%7CTWFpbGZsb3d8eyJWljojMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTiI6Iik1haWwiLCJXVCi6Mn0%3D%7C3000%7C%7C%7C&sdata=RSJg4YSGWYPLDiMcmPrh5HBc%2FNdmGzP4g9swuPz3o%2Fk%3D&reserved=0>

I trust this provides confirmation of our requirements, however should you have any questions or queries, please contact the Planning Team on [REDACTED]

Kind regards,

Peter

Peter Cox (he/him/they/them)
Technical Administrator