









GROUND FLOOR PLAN

FIRST FLOOR PLAN

ROOF PLAN

SPECIFICATION

DORMER ROOF CONSTRUCTION (V=0.15W/m2K)

12.5mm chippings on 3 layers bituminous felt on 18mm plywood on 50 x 50 s.v. battens across firrings (1 in 40) on s.w. joists @ 400pm crs. 80mm Celotex / Kingspan PIR insutation between and 30mm Actis Hybrid insulation / vapour barrier across underside of joists, Fixed with 38x25mm counter battens @ 600 crs with 12,5mm duplex Plasterboard & 5mm plaster skim ceiling.

DORMER CHEEK CONSTRUCTION (U=0.18W/m2K)
(Half hour fire resistant from both sides). Vertical tile/slate hanging to match existing on s.w. battens of building paper on 12,5 km plywood bracing (9mm masterboard within 1m of boundary) on 100x50mm studs @ 400mm ers (cross braced). 80mm Celotex/Kingspan PIR insulation between studs and 30mm ectis Hybrid insulation/vapour barrier across inside of studs fixed with 38x25mm counter battens @ 600 crs with 12 mm duplex plasterboard & 5 mm skim ceiling.

STAIRCASE

Rise=200mm, Going=225mm, Tread=250mm, Pitch=42, 2m clear Headroom. 900mm handrail, 900mm balustrade housed into newels or returned to adjacent wall. (100mm max gaps to risers & handrails). Artificial lighting with 2 way switch top and bottom. Any tapered Treads to comply with Part K. 50mm min going.

HALF HOUR PARTITION AROUND NEW STAIRCASE

75x50mm studding with 12.5mm duplex plasterboard & 5mm skim to both sides to give full half hour fire resistance.

FIRE REGULATIONS

All deers at ground and first floor off staircase enclosure to be 16 hour fire resistant (FD305). Any glazing to be wired glass (max 0.36m area). Steel beams to be encased in 2 layers of 12.5mm plasterboard (staggered joints) to give full half hour fire resistance. Timber beams have half hour fire resiatance to BS5268 part 4 section 41 1078 (sacrificial design method).

WINDOWS & ESCAPE WINDOWS

Escape window to be 750x450mm min clear opening (min 0.33m Opening area) max 1.1m above floor level. All new windows and Rooflights to be double glazed with min 16mm gap, low E glass N=0.15 for windows, n-0.05 for rooflights.. Windows to achieve Window U-Value to achieve min 1.4W/m2K

STRUCTURAL Multiple timber trimmers to be bolted together @ 600mm crs using

M12 bolts and 64mm dia tooth plate connectors.

Provide 8000mm background Ventilation to new habitable rooms and 5000mm to new bathroom/En-suites areas. New windows and French doors to achieve a purge ventilation rate of not less than 1/20th of the new floor area.

SMOKE DETECTORS

Denotes heat detector. Denotes mains wired interconnected smoke detectors with battery back up to BS5839:6:2004.

LIGHTING AND HEATINGThree in four lights to be energy efficient type. Extend existing Heating system to new rooms with zone and boiler interlock controls (Thermostatic Valves).

ELECTRICAL

All new electrical work to be in accordance with Part P "Competant Person Scheme" to BS7671. Certification to be provided upon completion.

Formation of habitable room in roofspace with front and rear rooflights.

CLIENT

Mr & Mrs. J. Brady, 8, St Thomas Close, Chilworth, GU4 BLQ.

SCALE 1:50 & 1:100 DATE 25:12:2023

EXISTING PLANS OF

DRAWN BY M. W. Justy

CONTRACT No. TLCC 598.



NOTE :- DO NOT SCALE OFF PLANS AS ACTUAL SIZES ON SITE MAY VARY SLIGHTLY

Guddford B.C. COUNCIL 01483 - 444609. FEET METRES