

## DER WorkSheet: New dwelling design stage

### User Details:

<b>Assessor Name:</b>	Sam Millard	<b>Stroma Number:</b>	STRO037385
<b>Software Name:</b>	Stroma FSAP 2012	<b>Software Version:</b>	Version: 1.0.5.18

Property Address: Plot 2

### Address :

#### 1. Overall dwelling dimensions:

	Area(m <sup>2</sup> )		Av. Height(m)		Volume(m <sup>3</sup> )
Ground floor	38	(1a) x	2.5	(2a) =	95 (3a)
First floor	38	(1b) x	2.7	(2b) =	102.6 (3b)
Second floor	34	(1c) x	2.4	(2c) =	81.6 (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+.....(1n)	110	(4)			
Dwelling volume				(3a)+(3b)+(3c)+(3d)+(3e)+.....(3n) =	279.2 (5)

#### 2. Ventilation rate:

	main heating		secondary heating		other		total		m <sup>3</sup> per hour
Number of chimneys	0	+	0	+	0	=	0	x 40 =	0 (6a)
Number of open flues	0	+	0	+	0	=	0	x 20 =	0 (6b)
Number of intermittent fans							0	x 10 =	0 (7a)
Number of passive vents							3	x 10 =	30 (7b)
Number of flueless gas fires							0	x 40 =	0 (7c)

#### Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	30	÷ (5) =	0.11 (8)
<i>If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)</i>			
Number of storeys in the dwelling (ns)			0 (9)
Additional infiltration		[(9)-1]x0.1 =	0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction <i>if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35</i>			0 (11)
If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0			0 (12)
If no draught lobby, enter 0.05, else enter 0			0 (13)
Percentage of windows and doors draught stripped			0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] =		0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) =		0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area			5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)			0.36 (18)
<i>Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used</i>			
Number of sides sheltered			0 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] =		1 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) =		0.36 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

<b>(22)m=</b>	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
---------------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

# DER WorkSheet: New dwelling design stage

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.46	0.45	0.44	0.39	0.38	0.34	0.34	0.33	0.36	0.38	0.4	0.42
------	------	------	------	------	------	------	------	------	------	-----	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0	(23a)
---	-------

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0	(23b)
---	-------

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0	(23c)
---	-------

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0	0	(24a)
---------	---	---	---	---	---	---	---	---	---	---	---	---	-------

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0	0	(24b)
---------	---	---	---	---	---	---	---	---	---	---	---	---	-------

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b) m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0	0	(24c)
---------	---	---	---	---	---	---	---	---	---	---	---	---	-------

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m<sup>2</sup> x 0.5]

(24d)m=	0.6	0.6	0.6	0.58	0.57	0.56	0.56	0.55	0.56	0.57	0.58	0.59	(24d)
---------	-----	-----	-----	------	------	------	------	------	------	------	------	------	-------

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.6	0.6	0.6	0.58	0.57	0.56	0.56	0.55	0.56	0.57	0.58	0.59	(25)
--------	-----	-----	-----	------	------	------	------	------	------	------	------	------	------

### 3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m <sup>2</sup> )	Openings m <sup>2</sup>	Net Area A ,m <sup>2</sup>	U-value W/m <sup>2</sup> K	A X U (W/K)	k-value kJ/m <sup>2</sup> -K	A X k kJ/K
Windows Type 1			4.55	x1/[1/( 1.4 )+ 0.04] =	6.03		(27)
Windows Type 2			10.25	x1/[1/( 1.4 )+ 0.04] =	13.59		(27)
Windows Type 3			3.1	x1/[1/( 1.4 )+ 0.04] =	4.11		(27)
Windows Type 4			3.6	x1/[1/( 1.4 )+ 0.04] =	4.77		(27)
Floor			38	x 0.11 =	4.18		(28)
Walls	123	21.5	101.5	x 0.18 =	18.27		(29)
Roof	38	0	38	x 0.15 =	5.7		(30)
Total area of elements, m <sup>2</sup>			199				(31)

\* for windows and roof windows, use effective window U-value calculated using formula 1/[(1/U-value)+0.04] as given in paragraph 3.2

\*\* include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 56.65 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 342 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m<sup>2</sup>K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 29.85 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 86.5 (37)

Ventilation heat loss calculated monthly

(38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

## DER WorkSheet: New dwelling design stage

(38)m= 

55.64	55.27	54.9	53.19	52.87	51.38	51.38	51.1	51.95	52.87	53.52	54.19
-------	-------	------	-------	-------	-------	-------	------	-------	-------	-------	-------

 (38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m= 

142.14	141.77	141.4	139.69	139.37	137.88	137.88	137.61	138.46	139.37	140.02	140.7
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	-------

Average = Sum(39)<sub>1...12</sub> /12= 

139.69
--------

 (39)

Heat loss parameter (HLP), W/m²K (40)m = (39)m ÷ (4)

(40)m= 

1.29	1.29	1.29	1.27	1.27	1.25	1.25	1.25	1.26	1.27	1.27	1.28
------	------	------	------	------	------	------	------	------	------	------	------

Average = Sum(40)<sub>1...12</sub> /12= 

1.27
------

 (40)

Number of days in month (Table 1a)

(41)m= 

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
31	28	31	30	31	30	31	31	30	31	30	31

 (41)

**4. Water heating energy requirement: kWh/year:**

Assumed occupancy, N 

2.81
------

 (42)  
 if TFA > 13.9, N = 1 + 1.76 x [1 - exp(-0.000349 x (TFA -13.9)²)] + 0.0013 x (TFA -13.9)  
 if TFA ≤ 13.9, N = 1

Annual average hot water usage in litres per day Vd,average = (25 x N) + 36 

101.05
--------

 (43)  
*Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)*

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
111.16	107.12	103.07	99.03	94.99	90.95	90.95	94.99	99.03	103.07	107.12	111.16

Total = Sum(44)<sub>1...12</sub> = 

1212.63
---------

 (44)

Energy content of hot water used - calculated monthly = 4.190 x Vd,m x nm x DTm / 3600 kWh/month (see Tables 1b, 1c, 1d)  
 (45)m= 

164.84	144.17	148.77	129.7	124.45	107.39	99.52	114.2	115.56	134.68	147.01	159.64
--------	--------	--------	-------	--------	--------	-------	-------	--------	--------	--------	--------

Total = Sum(45)<sub>1...12</sub> = 

1589.94
---------

 (45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)  
 (46)m= 

24.73	21.63	22.32	19.46	18.67	16.11	14.93	17.13	17.33	20.2	22.05	23.95
-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------

 (46)

Water storage loss:  
 Storage volume (litres) including any solar or WWHRS storage within same vessel 

150
-----

 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)  
 Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:  
 a) If manufacturer's declared loss factor is known (kWh/day): 

1.8
-----

 (48)

Temperature factor from Table 2b 

0.54
------

 (49)

Energy lost from water storage, kWh/year (48) x (49) = 

0.97
------

 (50)

b) If manufacturer's declared cylinder loss factor is not known:  
 Hot water storage loss factor from Table 2 (kWh/litre/day) 

0
---

 (51)

If community heating see section 4.3  
 Volume factor from Table 2a 

0
---

 (52)

Temperature factor from Table 2b 

0
---

 (53)

Energy lost from water storage, kWh/year (47) x (51) x (52) x (53) = 

0
---

 (54)

Enter (50) or (54) in (55) 

0.97
------

 (55)

Water storage loss calculated for each month ((56)m = (55) x (41)m

(56)m= 

30.13	27.22	30.13	29.16	30.13	29.16	30.13	30.13	29.16	30.13	29.16	30.13
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (56)

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) - (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m= 

30.13	27.22	30.13	29.16	30.13	29.16	30.13	30.13	29.16	30.13	29.16	30.13
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (57)

## DER WorkSheet: New dwelling design stage

Primary circuit loss (annual) from Table 3 0 (58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m= 

23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m= 

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m= 

218.24	192.4	202.17	181.38	177.85	159.07	152.91	167.59	167.23	188.07	198.68	213.04
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m= 

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (63)

Output from water heater

(64)m= 

218.24	192.4	202.17	181.38	177.85	159.07	152.91	167.59	167.23	188.07	198.68	213.04
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Output from water heater (annual)<sub>1...12</sub> 2218.62 (64)

Heat gains from water heating, kWh/month  $0.25 \times [0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m= 

97.53	86.52	92.18	84.46	84.1	77.05	75.8	80.69	79.76	87.5	90.22	95.8
-------	-------	-------	-------	------	-------	------	-------	-------	------	-------	------

 (65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

### 5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

(66)m= 

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74

 (66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m= 

24.44	21.71	17.66	13.37	9.99	8.44	9.11	11.85	15.9	20.19	23.57	25.12
-------	-------	-------	-------	------	------	------	-------	------	-------	-------	-------

 (67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m= 

271.56	274.37	267.27	252.16	233.07	215.14	203.16	200.34	207.44	222.56	241.64	259.57
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m= 

37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (69)

Pumps and fans gains (Table 5a)

(70)m= 

10	10	10	10	10	10	10	10	10	10	10	10
----	----	----	----	----	----	----	----	----	----	----	----

 (70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m= 

-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

 (71)

Water heating gains (Table 5)

(72)m= 

131.08	128.75	123.9	117.31	113.03	107.01	101.89	108.45	110.78	117.6	125.3	128.76
--------	--------	-------	--------	--------	--------	--------	--------	--------	-------	-------	--------

 (72)

**Total internal gains =** (66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m= 

502.3	500.05	484.05	458.06	431.32	405.8	389.38	395.86	409.34	435.57	465.73	488.68
-------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------

 (73)

### 6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m <sup>2</sup>	Flux Table 6a	g <sub>o</sub> Table 6b	FF Table 6c	Gains (W)
North	0.9x <span style="border: 1px solid black; padding: 2px 10px;">0.77</span>	x <span style="border: 1px solid black; padding: 2px 10px;">10.25</span>	x <span style="border: 1px solid black; padding: 2px 10px;">10.63</span>	x <span style="border: 1px solid black; padding: 2px 10px;">0.76</span>	x <span style="border: 1px solid black; padding: 2px 10px;">0.7</span>	= <span style="border: 1px solid black; padding: 2px 10px;">40.18</span> (74)
North	0.9x <span style="border: 1px solid black; padding: 2px 10px;">0.77</span>	x <span style="border: 1px solid black; padding: 2px 10px;">10.25</span>	x <span style="border: 1px solid black; padding: 2px 10px;">20.32</span>	x <span style="border: 1px solid black; padding: 2px 10px;">0.76</span>	x <span style="border: 1px solid black; padding: 2px 10px;">0.7</span>	= <span style="border: 1px solid black; padding: 2px 10px;">76.79</span> (74)

## DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	10.25	x	34.53	x	0.76	x	0.7	=	130.49	(74)
North	0.9x	0.77	x	10.25	x	55.46	x	0.76	x	0.7	=	209.6	(74)
North	0.9x	0.77	x	10.25	x	74.72	x	0.76	x	0.7	=	282.35	(74)
North	0.9x	0.77	x	10.25	x	79.99	x	0.76	x	0.7	=	302.26	(74)
North	0.9x	0.77	x	10.25	x	74.68	x	0.76	x	0.7	=	282.2	(74)
North	0.9x	0.77	x	10.25	x	59.25	x	0.76	x	0.7	=	223.89	(74)
North	0.9x	0.77	x	10.25	x	41.52	x	0.76	x	0.7	=	156.89	(74)
North	0.9x	0.77	x	10.25	x	24.19	x	0.76	x	0.7	=	91.41	(74)
North	0.9x	0.77	x	10.25	x	13.12	x	0.76	x	0.7	=	49.57	(74)
North	0.9x	0.77	x	10.25	x	8.86	x	0.76	x	0.7	=	33.5	(74)
Southeast	0.9x	0.77	x	3.6	x	36.79	x	0.76	x	0.7	=	48.83	(77)
Southeast	0.9x	0.77	x	3.6	x	62.67	x	0.76	x	0.7	=	83.18	(77)
Southeast	0.9x	0.77	x	3.6	x	85.75	x	0.76	x	0.7	=	113.81	(77)
Southeast	0.9x	0.77	x	3.6	x	106.25	x	0.76	x	0.7	=	141.02	(77)
Southeast	0.9x	0.77	x	3.6	x	119.01	x	0.76	x	0.7	=	157.95	(77)
Southeast	0.9x	0.77	x	3.6	x	118.15	x	0.76	x	0.7	=	156.81	(77)
Southeast	0.9x	0.77	x	3.6	x	113.91	x	0.76	x	0.7	=	151.18	(77)
Southeast	0.9x	0.77	x	3.6	x	104.39	x	0.76	x	0.7	=	138.55	(77)
Southeast	0.9x	0.77	x	3.6	x	92.85	x	0.76	x	0.7	=	123.24	(77)
Southeast	0.9x	0.77	x	3.6	x	69.27	x	0.76	x	0.7	=	91.93	(77)
Southeast	0.9x	0.77	x	3.6	x	44.07	x	0.76	x	0.7	=	58.49	(77)
Southeast	0.9x	0.77	x	3.6	x	31.49	x	0.76	x	0.7	=	41.79	(77)
South	0.9x	0.77	x	4.55	x	46.75	x	0.76	x	0.7	=	78.43	(78)
South	0.9x	0.77	x	4.55	x	76.57	x	0.76	x	0.7	=	128.44	(78)
South	0.9x	0.77	x	4.55	x	97.53	x	0.76	x	0.7	=	163.61	(78)
South	0.9x	0.77	x	4.55	x	110.23	x	0.76	x	0.7	=	184.92	(78)
South	0.9x	0.77	x	4.55	x	114.87	x	0.76	x	0.7	=	192.69	(78)
South	0.9x	0.77	x	4.55	x	110.55	x	0.76	x	0.7	=	185.44	(78)
South	0.9x	0.77	x	4.55	x	108.01	x	0.76	x	0.7	=	181.19	(78)
South	0.9x	0.77	x	4.55	x	104.89	x	0.76	x	0.7	=	175.96	(78)
South	0.9x	0.77	x	4.55	x	101.89	x	0.76	x	0.7	=	170.91	(78)
South	0.9x	0.77	x	4.55	x	82.59	x	0.76	x	0.7	=	138.54	(78)
South	0.9x	0.77	x	4.55	x	55.42	x	0.76	x	0.7	=	92.96	(78)
South	0.9x	0.77	x	4.55	x	40.4	x	0.76	x	0.7	=	67.77	(78)
West	0.9x	0.77	x	3.1	x	19.64	x	0.76	x	0.7	=	22.45	(80)
West	0.9x	0.77	x	3.1	x	38.42	x	0.76	x	0.7	=	43.91	(80)
West	0.9x	0.77	x	3.1	x	63.27	x	0.76	x	0.7	=	72.31	(80)
West	0.9x	0.77	x	3.1	x	92.28	x	0.76	x	0.7	=	105.47	(80)
West	0.9x	0.77	x	3.1	x	113.09	x	0.76	x	0.7	=	129.25	(80)
West	0.9x	0.77	x	3.1	x	115.77	x	0.76	x	0.7	=	132.31	(80)
West	0.9x	0.77	x	3.1	x	110.22	x	0.76	x	0.7	=	125.97	(80)

## DER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	3.1	x	94.68	x	0.76	x	0.7	=	108.2	(80)
West	0.9x	0.77	x	3.1	x	73.59	x	0.76	x	0.7	=	84.1	(80)
West	0.9x	0.77	x	3.1	x	45.59	x	0.76	x	0.7	=	52.1	(80)
West	0.9x	0.77	x	3.1	x	24.49	x	0.76	x	0.7	=	27.99	(80)
West	0.9x	0.77	x	3.1	x	16.15	x	0.76	x	0.7	=	18.46	(80)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

(83)m=	189.89	332.33	480.23	641	762.25	776.83	740.54	646.6	535.14	373.98	229.01	161.52	(83)
--------	--------	--------	--------	-----	--------	--------	--------	-------	--------	--------	--------	--------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	692.19	832.38	964.28	1099.05	1193.57	1182.63	1129.92	1042.46	944.48	809.55	694.74	650.19	(84)
--------	--------	--------	--------	---------	---------	---------	---------	---------	--------	--------	--------	--------	------

### 7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21 (85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

(86)m=	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(86)
	1	0.99	0.98	0.95	0.86	0.69	0.52	0.58	0.83	0.97	0.99	1	

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.6	19.79	20.08	20.46	20.77	20.94	20.99	20.98	20.86	20.44	19.95	19.57	(87)
--------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.85	19.85	19.85	19.86	19.87	19.88	19.88	19.88	19.87	19.87	19.86	19.86	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.98	0.93	0.8	0.59	0.4	0.45	0.75	0.95	0.99	1	(89)
--------	---	------	------	------	-----	------	-----	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	17.99	18.27	18.7	19.24	19.65	19.84	19.87	19.87	19.76	19.23	18.52	17.96	(90)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

fLA = Living area ÷ (4) =

0.14 (91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	18.21	18.48	18.89	19.41	19.8	19.99	20.02	20.02	19.91	19.4	18.71	18.18	(92)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.06	18.33	18.74	19.26	19.65	19.84	19.87	19.87	19.76	19.25	18.56	18.03	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

### 8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that Ti,m=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.99	0.97	0.91	0.79	0.59	0.4	0.45	0.74	0.94	0.99	1	(94)
--------	------	------	------	------	------	------	-----	------	------	------	------	---	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	688.36	821.79	934.17	1005.55	944.35	692.91	447.86	471.11	698.39	762.92	686.56	647.45	(95)
--------	--------	--------	--------	---------	--------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m – (96)m ]

(97)m=	1956.29	1903.71	1730.33	1446.57	1108	722.53	451.55	477.8	783.65	1205.13	1605.34	1945.56	(97)
--------	---------	---------	---------	---------	------	--------	--------	-------	--------	---------	---------	---------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	943.34	727.05	592.34	317.53	121.76	0	0	0	0	329	661.52	965.8	(98)
--------	--------	--------	--------	--------	--------	---	---	---	---	-----	--------	-------	------

Total per year (kWh/year) = Sum(98)<sub>1...5,9...12</sub> =

4658.35 (99)

Space heating requirement in kWh/m<sup>2</sup>/year

42.35 (99)

## DER WorkSheet: New dwelling design stage

### 9a. Energy requirements – Individual heating systems including micro-CHP

#### Space heating:

Fraction of space heat from secondary/supplementary system		0	(201)
Fraction of space heat from main system(s)	(202) = 1 – (201) =	1	(202)
Fraction of total heating from main system 1	(204) = (202) × [1 – (203)] =	1	(204)
Efficiency of main space heating system 1		73.6	(206)
Efficiency of secondary/supplementary heating system, %		0	(208)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

943.34	727.05	592.34	317.53	121.76	0	0	0	0	329	661.52	965.8
--------	--------	--------	--------	--------	---	---	---	---	-----	--------	-------

(211)<sub>m</sub> = {[ (98)<sub>m</sub> × (204) ] } × 100 ÷ (206) (211)

1281.71	987.84	804.81	431.43	165.43	0	0	0	0	447.02	898.8	1312.22
---------	--------	--------	--------	--------	---	---	---	---	--------	-------	---------

Total (kWh/year) = Sum(211)<sub>1...5,10...12</sub> = 6329.27 (211)

Space heating fuel (secondary), kWh/month

= {[ (98)<sub>m</sub> × (201) ] } × 100 ÷ (208)

(215)<sub>m</sub> = 

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

Total (kWh/year) = Sum(215)<sub>1...5,10...12</sub> = 0 (215)

#### Water heating

Output from water heater (calculated above)

218.24	192.4	202.17	181.38	177.85	159.07	152.91	167.59	167.23	188.07	198.68	213.04
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Efficiency of water heater 63.5 (216)

(217)<sub>m</sub> = 

71.46	71.23	70.74	69.58	67.25	63.5	63.5	63.5	63.5	69.57	70.99	71.54
-------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------

(217)

Fuel for water heating, kWh/month

(219)<sub>m</sub> = (64)<sub>m</sub> × 100 ÷ (217)<sub>m</sub>

(219)<sub>m</sub> = 

305.38	270.11	285.8	260.68	264.46	250.5	240.81	263.92	263.36	270.31	279.86	297.77
--------	--------	-------	--------	--------	-------	--------	--------	--------	--------	--------	--------

Total = Sum(219a)<sub>1...12</sub> = 3252.97 (219)

#### Annual totals

	<b>kWh/year</b>		<b>kWh/year</b>
Space heating fuel used, main system 1		6329.27	
Water heating fuel used		3252.97	

Electricity for pumps, fans and electric keep-hot

central heating pump: 120 (230c)

Total electricity for the above, kWh/year sum of (230a)...(230g) = 120 (231)

Electricity for lighting 431.66 (232)

Electricity generated by PVs -2098.6 (233)

Total delivered energy for all uses (211)...(221) + (231) + (232)...(237b) = 8035.31 (338)

### 12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year		Emission factor kg CO2/kWh		Emissions kg CO2/year
Space heating (main system 1)	(211) ×		0.216	=	1367.12 (261)
Space heating (secondary)	(215) ×		0.519	=	0 (263)
Water heating	(219) ×		0.216	=	702.64 (264)

## DER WorkSheet: New dwelling design stage

Space and water heating	(261) + (262) + (263) + (264) =			2069.76	(265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	=	62.28	(267)
Electricity for lighting	(232) x	0.519	=	224.03	(268)
Energy saving/generation technologies Item 1		0.519	=	-1089.17	(269)
Total CO2, kg/year		sum of (265)...(271) =		1266.91	(272)
<b>Dwelling CO2 Emission Rate</b>		(272) ÷ (4) =		11.52	(273)
El rating (section 14)				89	(274)



## TER WorkSheet: New dwelling design stage

### User Details:

<b>Assessor Name:</b>	Sam Millard	<b>Stroma Number:</b>	STRO037385
<b>Software Name:</b>	Stroma FSAP 2012	<b>Software Version:</b>	Version: 1.0.5.18

Property Address: Plot 2

### Address :

#### 1. Overall dwelling dimensions:

	Area(m <sup>2</sup> )		Av. Height(m)			Volume(m <sup>3</sup> )
Ground floor	38	(1a) x	2.5	(2a) =		95 (3a)
First floor	38	(1b) x	2.7	(2b) =		102.6 (3b)
Second floor	34	(1c) x	2.4	(2c) =		81.6 (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+.....(1n)	110	(4)				
Dwelling volume				(3a)+(3b)+(3c)+(3d)+(3e)+.....(3n) =		279.2 (5)

#### 2. Ventilation rate:

	main heating		secondary heating		other		total		m <sup>3</sup> per hour
Number of chimneys	0	+	0	+	0	=	0	x 40 =	0 (6a)
Number of open flues	0	+	0	+	0	=	0	x 20 =	0 (6b)
Number of intermittent fans							4	x 10 =	40 (7a)
Number of passive vents							0	x 10 =	0 (7b)
Number of flueless gas fires							0	x 40 =	0 (7c)

#### Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	40	÷ (5) =	0.14 (8)
<i>If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)</i>			
Number of storeys in the dwelling (ns)			0 (9)
Additional infiltration		[(9)-1]x0.1 =	0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction <i>if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35</i>			0 (11)
If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0			0 (12)
If no draught lobby, enter 0.05, else enter 0			0 (13)
Percentage of windows and doors draught stripped			0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] =		0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) =		0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area			5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)			0.39 (18)
<i>Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used</i>			
Number of sides sheltered			0 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] =		1 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) =		0.39 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

# TER WorkSheet: New dwelling design stage

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.5	0.49	0.48	0.43	0.42	0.37	0.37	0.36	0.39	0.42	0.44	0.46
-----	------	------	------	------	------	------	------	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b) m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m<sup>2</sup> x 0.5]

(24d)m=	0.63	0.62	0.62	0.59	0.59	0.57	0.57	0.57	0.58	0.59	0.6	0.61
---------	------	------	------	------	------	------	------	------	------	------	-----	------

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.63	0.62	0.62	0.59	0.59	0.57	0.57	0.57	0.58	0.59	0.6	0.61
--------	------	------	------	------	------	------	------	------	------	------	-----	------

### 3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m <sup>2</sup> )	Openings m <sup>2</sup>	Net Area A ,m <sup>2</sup>	U-value W/m <sup>2</sup> K	A X U (W/K)	k-value kJ/m <sup>2</sup> -K	A X k kJ/K
Windows Type 1			4.55	x1/[1/( 1.4 )+ 0.04] =	6.03		(27)
Windows Type 2			10.25	x1/[1/( 1.4 )+ 0.04] =	13.59		(27)
Windows Type 3			3.1	x1/[1/( 1.4 )+ 0.04] =	4.11		(27)
Windows Type 4			3.6	x1/[1/( 1.4 )+ 0.04] =	4.77		(27)
Floor			38	x 0.13 =	4.94		(28)
Walls	123	21.5	101.5	x 0.18 =	18.27		(29)
Roof	38	0	38	x 0.13 =	4.94		(30)
Total area of elements, m <sup>2</sup>			199				(31)

\* for windows and roof windows, use effective window U-value calculated using formula 1/[(1/U-value)+0.04] as given in paragraph 3.2

\*\* include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 56.65 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 342 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m<sup>2</sup>K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 9.95 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 66.6 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

## TER WorkSheet: New dwelling design stage

(38)m= 

57.65	57.2	56.76	54.69	54.3	52.5	52.5	52.16	53.19	54.3	55.09	55.9
-------	------	-------	-------	------	------	------	-------	-------	------	-------	------

 (38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m= 

124.25	123.8	123.36	121.29	120.91	119.1	119.1	118.77	119.8	120.91	121.69	122.51
--------	-------	--------	--------	--------	-------	-------	--------	-------	--------	--------	--------

Average = Sum(39)<sub>1...12</sub> / 12 = 

121.29
--------

 (39)

Heat loss parameter (HLP), W/m²K (40)m = (39)m ÷ (4)

(40)m= 

1.13	1.13	1.12	1.1	1.1	1.08	1.08	1.08	1.09	1.1	1.11	1.11
------	------	------	-----	-----	------	------	------	------	-----	------	------

Average = Sum(40)<sub>1...12</sub> / 12 = 

1.1
-----

 (40)

Number of days in month (Table 1a)

(41)m= 

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
31	28	31	30	31	30	31	31	30	31	30	31

 (41)

**4. Water heating energy requirement: kWh/year:**

Assumed occupancy, N 

2.81
------

 (42)  
 if TFA > 13.9, N = 1 + 1.76 x [1 - exp(-0.000349 x (TFA - 13.9)²)] + 0.0013 x (TFA - 13.9)  
 if TFA ≤ 13.9, N = 1

Annual average hot water usage in litres per day Vd,average = (25 x N) + 36 

101.05
--------

 (43)  
*Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)*

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
111.16	107.12	103.07	99.03	94.99	90.95	90.95	94.99	99.03	103.07	107.12	111.16

Total = Sum(44)<sub>1...12</sub> = 

1212.63
---------

 (44)

Energy content of hot water used - calculated monthly = 4.190 x Vd,m x nm x DTm / 3600 kWh/month (see Tables 1b, 1c, 1d)  
 (45)m= 

164.84	144.17	148.77	129.7	124.45	107.39	99.52	114.2	115.56	134.68	147.01	159.64
--------	--------	--------	-------	--------	--------	-------	-------	--------	--------	--------	--------

Total = Sum(45)<sub>1...12</sub> = 

1589.94
---------

 (45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)  
 (46)m= 

24.73	21.63	22.32	19.46	18.67	16.11	14.93	17.13	17.33	20.2	22.05	23.95
-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------

 (46)

Water storage loss:  
 Storage volume (litres) including any solar or WWHRS storage within same vessel 

150
-----

 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)  
 Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:  
 a) If manufacturer's declared loss factor is known (kWh/day): 

1.39
------

 (48)

Temperature factor from Table 2b 

0.54
------

 (49)

Energy lost from water storage, kWh/year (48) x (49) = 

0.75
------

 (50)

b) If manufacturer's declared cylinder loss factor is not known:  
 Hot water storage loss factor from Table 2 (kWh/litre/day) 

0
---

 (51)

If community heating see section 4.3  
 Volume factor from Table 2a 

0
---

 (52)

Temperature factor from Table 2b 

0
---

 (53)

Energy lost from water storage, kWh/year (47) x (51) x (52) x (53) = 

0
---

 (54)

Enter (50) or (54) in (55) 

0.75
------

 (55)

Water storage loss calculated for each month ((56)m = (55) x (41)m  
 (56)m= 

23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (56)

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) - (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H  
 (57)m= 

23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (57)

# TER WorkSheet: New dwelling design stage

Primary circuit loss (annual) from Table 3 0 (58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m= 

23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m= 

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m= 

211.44	186.26	195.37	174.8	171.05	152.49	146.11	160.79	160.65	181.27	192.1	206.24
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	-------	--------

 (62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m= 

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (63)

Output from water heater

(64)m= 

211.44	186.26	195.37	174.8	171.05	152.49	146.11	160.79	160.65	181.27	192.1	206.24
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	-------	--------

Output from water heater (annual)<sub>1...12</sub> 2138.56 (64)

Heat gains from water heating, kWh/month  $0.25 \times [0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m= 

92.09	81.61	86.74	79.2	78.66	71.78	70.37	75.25	74.5	82.06	84.95	90.36
-------	-------	-------	------	-------	-------	-------	-------	------	-------	-------	-------

 (65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

## 5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

(66)m= 

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74	140.74

 (66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m= 

24.44	21.71	17.66	13.37	9.99	8.44	9.11	11.85	15.9	20.19	23.57	25.12
-------	-------	-------	-------	------	------	------	-------	------	-------	-------	-------

 (67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m= 

271.56	274.37	267.27	252.16	233.07	215.14	203.16	200.34	207.44	222.56	241.64	259.57
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m= 

37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07	37.07
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (69)

Pumps and fans gains (Table 5a)

(70)m= 

3	3	3	3	3	3	3	3	3	3	3	3
---	---	---	---	---	---	---	---	---	---	---	---

 (70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m= 

-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59	-112.59
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

 (71)

Water heating gains (Table 5)

(72)m= 

123.77	121.44	116.59	110	105.72	99.7	94.58	101.14	103.47	110.29	117.99	121.45
--------	--------	--------	-----	--------	------	-------	--------	--------	--------	--------	--------

 (72)

**Total internal gains =** (66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m= 

487.99	485.74	469.74	443.74	417.01	391.49	375.07	381.55	395.03	421.26	451.42	474.37
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (73)

## 6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m <sup>2</sup>	Flux Table 6a	g <sub>-</sub> Table 6b	FF Table 6c	Gains (W)						
North	0.9x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>0.77</td></tr></table>	0.77	x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>10.25</td></tr></table>	10.25	x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>10.63</td></tr></table>	10.63	x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>0.63</td></tr></table>	0.63	x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>0.7</td></tr></table>	0.7	= <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>33.31</td></tr></table> (74)	33.31
0.77												
10.25												
10.63												
0.63												
0.7												
33.31												
North	0.9x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>0.77</td></tr></table>	0.77	x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>10.25</td></tr></table>	10.25	x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>20.32</td></tr></table>	20.32	x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>0.63</td></tr></table>	0.63	x <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>0.7</td></tr></table>	0.7	= <table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td>63.66</td></tr></table> (74)	63.66
0.77												
10.25												
20.32												
0.63												
0.7												
63.66												

## TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	10.25	x	34.53	x	0.63	x	0.7	=	108.17	(74)
North	0.9x	0.77	x	10.25	x	55.46	x	0.63	x	0.7	=	173.74	(74)
North	0.9x	0.77	x	10.25	x	74.72	x	0.63	x	0.7	=	234.05	(74)
North	0.9x	0.77	x	10.25	x	79.99	x	0.63	x	0.7	=	250.56	(74)
North	0.9x	0.77	x	10.25	x	74.68	x	0.63	x	0.7	=	233.93	(74)
North	0.9x	0.77	x	10.25	x	59.25	x	0.63	x	0.7	=	185.59	(74)
North	0.9x	0.77	x	10.25	x	41.52	x	0.63	x	0.7	=	130.05	(74)
North	0.9x	0.77	x	10.25	x	24.19	x	0.63	x	0.7	=	75.77	(74)
North	0.9x	0.77	x	10.25	x	13.12	x	0.63	x	0.7	=	41.09	(74)
North	0.9x	0.77	x	10.25	x	8.86	x	0.63	x	0.7	=	27.77	(74)
Southeast	0.9x	0.77	x	3.6	x	36.79	x	0.63	x	0.7	=	40.48	(77)
Southeast	0.9x	0.77	x	3.6	x	62.67	x	0.63	x	0.7	=	68.95	(77)
Southeast	0.9x	0.77	x	3.6	x	85.75	x	0.63	x	0.7	=	94.35	(77)
Southeast	0.9x	0.77	x	3.6	x	106.25	x	0.63	x	0.7	=	116.9	(77)
Southeast	0.9x	0.77	x	3.6	x	119.01	x	0.63	x	0.7	=	130.94	(77)
Southeast	0.9x	0.77	x	3.6	x	118.15	x	0.63	x	0.7	=	129.99	(77)
Southeast	0.9x	0.77	x	3.6	x	113.91	x	0.63	x	0.7	=	125.32	(77)
Southeast	0.9x	0.77	x	3.6	x	104.39	x	0.63	x	0.7	=	114.85	(77)
Southeast	0.9x	0.77	x	3.6	x	92.85	x	0.63	x	0.7	=	102.16	(77)
Southeast	0.9x	0.77	x	3.6	x	69.27	x	0.63	x	0.7	=	76.21	(77)
Southeast	0.9x	0.77	x	3.6	x	44.07	x	0.63	x	0.7	=	48.49	(77)
Southeast	0.9x	0.77	x	3.6	x	31.49	x	0.63	x	0.7	=	34.64	(77)
South	0.9x	0.77	x	4.55	x	46.75	x	0.63	x	0.7	=	65.01	(78)
South	0.9x	0.77	x	4.55	x	76.57	x	0.63	x	0.7	=	106.47	(78)
South	0.9x	0.77	x	4.55	x	97.53	x	0.63	x	0.7	=	135.62	(78)
South	0.9x	0.77	x	4.55	x	110.23	x	0.63	x	0.7	=	153.29	(78)
South	0.9x	0.77	x	4.55	x	114.87	x	0.63	x	0.7	=	159.73	(78)
South	0.9x	0.77	x	4.55	x	110.55	x	0.63	x	0.7	=	153.72	(78)
South	0.9x	0.77	x	4.55	x	108.01	x	0.63	x	0.7	=	150.19	(78)
South	0.9x	0.77	x	4.55	x	104.89	x	0.63	x	0.7	=	145.86	(78)
South	0.9x	0.77	x	4.55	x	101.89	x	0.63	x	0.7	=	141.68	(78)
South	0.9x	0.77	x	4.55	x	82.59	x	0.63	x	0.7	=	114.84	(78)
South	0.9x	0.77	x	4.55	x	55.42	x	0.63	x	0.7	=	77.06	(78)
South	0.9x	0.77	x	4.55	x	40.4	x	0.63	x	0.7	=	56.18	(78)
West	0.9x	0.77	x	3.1	x	19.64	x	0.63	x	0.7	=	18.61	(80)
West	0.9x	0.77	x	3.1	x	38.42	x	0.63	x	0.7	=	36.4	(80)
West	0.9x	0.77	x	3.1	x	63.27	x	0.63	x	0.7	=	59.94	(80)
West	0.9x	0.77	x	3.1	x	92.28	x	0.63	x	0.7	=	87.43	(80)
West	0.9x	0.77	x	3.1	x	113.09	x	0.63	x	0.7	=	107.14	(80)
West	0.9x	0.77	x	3.1	x	115.77	x	0.63	x	0.7	=	109.68	(80)
West	0.9x	0.77	x	3.1	x	110.22	x	0.63	x	0.7	=	104.42	(80)

## TER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	3.1	x	94.68	x	0.63	x	0.7	=	89.7	(80)
West	0.9x	0.77	x	3.1	x	73.59	x	0.63	x	0.7	=	69.72	(80)
West	0.9x	0.77	x	3.1	x	45.59	x	0.63	x	0.7	=	43.19	(80)
West	0.9x	0.77	x	3.1	x	24.49	x	0.63	x	0.7	=	23.2	(80)
West	0.9x	0.77	x	3.1	x	16.15	x	0.63	x	0.7	=	15.3	(80)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

(83)m=	157.41	275.48	398.08	531.35	631.86	643.95	613.87	536	443.6	310.01	189.84	133.89	(83)
--------	--------	--------	--------	--------	--------	--------	--------	-----	-------	--------	--------	--------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	645.4	761.22	867.82	975.1	1048.87	1035.44	988.94	917.54	838.63	731.27	641.26	608.25	(84)
--------	-------	--------	--------	-------	---------	---------	--------	--------	--------	--------	--------	--------	------

### 7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21 (85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

(86)m=	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(86)
	1	1	0.99	0.96	0.87	0.69	0.52	0.58	0.83	0.97	1	1	

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.77	19.94	20.2	20.54	20.81	20.96	20.99	20.99	20.89	20.53	20.09	19.75	(87)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.98	19.98	19.98	20	20	20.01	20.01	20.02	20.01	20	20	19.99	(88)
--------	-------	-------	-------	----	----	-------	-------	-------	-------	----	----	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.98	0.94	0.82	0.6	0.41	0.46	0.76	0.96	0.99	1	(89)
--------	---	------	------	------	------	-----	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.34	18.59	18.96	19.46	19.82	19.99	20.01	20.01	19.92	19.45	18.82	18.32	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

fLA = Living area ÷ (4) =

0.14 (91)

Mean internal temperature (for the whole dwelling) = fLA x T1 + (1 – fLA) x T2

(92)m=	18.54	18.77	19.13	19.6	19.96	20.12	20.15	20.15	20.05	19.6	18.99	18.51	(92)
--------	-------	-------	-------	------	-------	-------	-------	-------	-------	------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.54	18.77	19.13	19.6	19.96	20.12	20.15	20.15	20.05	19.6	18.99	18.51	(93)
--------	-------	-------	-------	------	-------	-------	-------	-------	-------	------	-------	-------	------

### 8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that Ti,m=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	1	0.99	0.98	0.93	0.82	0.61	0.42	0.48	0.77	0.95	0.99	1	(94)
--------	---	------	------	------	------	------	------	------	------	------	------	---	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	643	754.56	848.18	909.12	857.49	634.32	419.58	439.77	641.7	698.28	635.98	606.56	(95)
--------	-----	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m – (96)m ]

(97)m=	1768.82	1717.18	1558.44	1298.41	998.17	657.53	422.31	444.8	713.27	1088.29	1447.47	1753.65	(97)
--------	---------	---------	---------	---------	--------	--------	--------	-------	--------	---------	---------	---------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	837.61	646.88	528.44	280.29	104.67	0	0	0	0	290.17	584.27	853.44	(98)
--------	--------	--------	--------	--------	--------	---	---	---	---	--------	--------	--------	------

Total per year (kWh/year) = Sum(98)<sub>1...5,9...12</sub> =

4125.77 (99)

Space heating requirement in kWh/m<sup>2</sup>/year

37.51 (99)

# TER WorkSheet: New dwelling design stage

## 9a. Energy requirements – Individual heating systems including micro-CHP

### Space heating:

Fraction of space heat from secondary/supplementary system	0	(201)
Fraction of space heat from main system(s) <span style="float: right;">(202) = 1 – (201) =</span>	1	(202)
Fraction of total heating from main system 1 <span style="float: right;">(204) = (202) × [1 – (203)] =</span>	1	(204)
Efficiency of main space heating system 1	93.5	(206)
Efficiency of secondary/supplementary heating system, %	0	(208)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

837.61	646.88	528.44	280.29	104.67	0	0	0	0	290.17	584.27	853.44
--------	--------	--------	--------	--------	---	---	---	---	--------	--------	--------

(211)<sub>m</sub> = {[(98)<sub>m</sub> × (204)] } × 100 ÷ (206) (211)

895.84	691.85	565.17	299.78	111.94	0	0	0	0	310.35	624.89	912.77
--------	--------	--------	--------	--------	---	---	---	---	--------	--------	--------

Total (kWh/year) = Sum(211)<sub>1...5,10...12</sub> = 4412.59 (211)

Space heating fuel (secondary), kWh/month

= {[(98)<sub>m</sub> × (201)] } × 100 ÷ (208)

(215)<sub>m</sub> = 

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

Total (kWh/year) = Sum(215)<sub>1...5,10...12</sub> = 0 (215)

### Water heating

Output from water heater (calculated above)

211.44	186.26	195.37	174.8	171.05	152.49	146.11	160.79	160.65	181.27	192.1	206.24
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	-------	--------

Efficiency of water heater 79.8 (216)

(217)<sub>m</sub> = 

88.12	87.87	87.34	86.07	83.55	79.8	79.8	79.8	79.8	86.06	87.59	88.2
-------	-------	-------	-------	-------	------	------	------	------	-------	-------	------

(217)

Fuel for water heating, kWh/month

(219)<sub>m</sub> = (64)<sub>m</sub> × 100 ÷ (217)<sub>m</sub>

(219)<sub>m</sub> = 

239.95	211.98	223.69	203.09	204.73	191.09	183.1	201.49	201.32	210.62	219.31	233.83
--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------

Total = Sum(219a)<sub>1...12</sub> = 2524.2 (219)

### Annual totals

	<b>kWh/year</b>	<b>kWh/year</b>
Space heating fuel used, main system 1		<span style="border: 1px solid black; padding: 2px;">4412.59</span>
Water heating fuel used		<span style="border: 1px solid black; padding: 2px;">2524.2</span>

Electricity for pumps, fans and electric keep-hot

central heating pump: 30 (230c)

boiler with a fan-assisted flue 45 (230e)

Total electricity for the above, kWh/year sum of (230a)...(230g) = 75 (231)

Electricity for lighting 431.66 (232)

Total delivered energy for all uses (211)...(221) + (231) + (232)...(237b) = 7443.45 (338)

## 12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year		Emission factor kg CO2/kWh		Emissions kg CO2/year
Space heating (main system 1)	(211) ×		<span style="border: 1px solid black; padding: 2px;">0.216</span>	=	<span style="border: 1px solid black; padding: 2px;">953.12</span> (261)
Space heating (secondary)	(215) ×		<span style="border: 1px solid black; padding: 2px;">0.519</span>	=	<span style="border: 1px solid black; padding: 2px;">0</span> (263)
Water heating	(219) ×		<span style="border: 1px solid black; padding: 2px;">0.216</span>	=	<span style="border: 1px solid black; padding: 2px;">545.23</span> (264)

## TER WorkSheet: New dwelling design stage

Space and water heating	(261) + (262) + (263) + (264) =			1498.35	(265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	=	38.93	(267)
Electricity for lighting	(232) x	0.519	=	224.03	(268)
Total CO2, kg/year		sum of (265)...(271) =		1761.3	(272)
<b>TER =</b>				16.01	(273)