

- (6) Details of the projected noise levels (in dBA - L90 for 5 minutes) at 1 metre from the building or nearest residential facade. Details of the ambient (background) noise levels at 12.30am or just before the premises normally close.
- (7) Full details of the isolator unit to be provided separating the fan from the remainder of the duct in order to prevent transmission of vibration through the structure and other parts of the building.
- (8) Details of the terminus of the duct including the provision of a directional cowl in the direction of the prevailing winds in order to aid dispersion of the vitiated air.
- (9) Details of the treatment of the duct which should meet the requirements of the Planning Department regarding the appearance/blending with adjoining buildings and general character of the area.

In connection with item (6) above, it is recommended that you engage the services of a qualified acoustics engineer or ventilation engineer in order that an inspection/report can also be submitted to this Directorate with your scheme of particulars. This is to ensure that should your scheme be approved, no statutory noise or vibration nuisance is subsequently caused to adjoining residents.

Needless to say, if you should have any queries with regard to any of the above, please do not hesitate to contact the case officer whose name appears at the head of this letter who will be most pleased to be of further assistance.

Yours faithfully,

Environmental Health Officer.