KEY

- EX HV — EXISTING UKPN HV ELECTRIC CABLE/DUCT
- //EX HV// — EXISTING UKPN HV ELECTRIC CABLE/DUCT DIVERTED/DISCONNECTED
- EX LV — EXISTING UKPN LV ELECTRIC CABLE/DUCT
- //EX LV// — EXISTING UKPN LV ELECTRIC CABLE/DUCT DIVERTED/DISCONNECTED
- STREET FURNITURE
- TRANSFORMER CHAMBER
- DISCONNECTING BOX

NOTES

1. THE POSITIONS OF THE APPARATUS SHOWN THE PLANS ARE DEEMED TO BE ACCURATE BUT MAY HAVE BEEN ALTERED SINCE THEY WERE INSTALLED.
2. THE EXACT POSITION OF APPARATUS SHOULD BE VERIFIED BY CARRYING OUT A FULL SERVICES INVESTIGATION AND TRACE TO DEFINE THE FULL EXTENT OF EXISTING SERVICES BEFORE ANY WORKS ARE UNDER TAKEN.
3. IT MUST BE ASSUMED THAT THERE IS A SERVICE INTO EACH PROPERTY. IT SHOULD ALSO BE ASSUMED THAT THERE ARE OTHER SERVICES (SUCH AS LAMP COLUMNS, STREET SIGNS AND SERVICES BELONGING TO OTHERS ETC.) PRESENT THAT ARE NOT SHOWN ON THE PLANS.
4. SERVICE PIPES, VALVES, STUB CONNECTIONS ETC., ARE NOT SHOWN BUT THEIR PRESENCE SHOULD BE ANTICIPATED.
5. ALL CABLES AND PIPES SHALL BE ASSUMED TO BE LIVE OR IN-USE UNLESS INSTRUCTED OTHERWISE BY UTILITIES.

ROSEACRE AVENUE

PARK VIEW ROAD

DISCONNECTION OR DIVERSION OF SERVICES TO BE CONFIRMED

DISCONNECTION OR DIVERSION OF SERVICES TO BE CONFIRMED

DISCONNECTION OF SERVICE

DIVERSION OF SERIVCE TO BE CONFIRMED

Car Club

Car Club

Disabled Parking

Disabled Parking

Blue badge residential parking Entrance

Ambulatory vehicle parking Entrance

Players & Officials Entrance

Spectator Entrance

Spectator Entrance

Loading Bay

Bus Stop

Bus Stop

Commercial

Refuse

Substation

Circulation

Cycle Storage

LV Switch

Lift

M&E Riser

Bulk Refuse

Parking

Sprinkler Tank Below

Ambulance Parking

Reception

Circulation

Commercial Refuse

Club Refuse

Food Stall

Refuse

Disabled Seating

Wolfing United FC - Club Bar

Wolfing United FC - Shop & Tickets

Commercial

Energy Centre

Commercial Plant

Security Control Room

Water Tank Room

Public WC

Equipment Storage

Changing Room

Officials Room M

Officials Room W

Physiotherapy Room

General Storage

Core

First Aid

Public WC

Unallocated

Plant Room

Club Office

Changing Room

Soft Wellway

EXISTING STAND

STANDING

THIS DRAWING SHALL NOT BE RELIED UPON BY THE CONTRACTOR AS A WORKING DRAWING. THIS DRAWING HAS BEEN PRODUCED FOR DESIGN PURPOSES ONLY. ANY INSTALLATION BASED ON THIS DRAWING IS AT THE CONTRACTORS RISK.

© COPYRIGHT OF THIS DRAWING RESIDES WITH MENDICK WARING

NOTES

1. DO NOT SCALE FROM THIS DRAWING, USE FIGURED DIMENSIONS ONLY, AND CHECK ALL DIMENSIONS ON SITE.
2.

Rev	Date	CAD	Chkd	Description
P2	25.01.24	RB	SD	PRELIMINARY ISSUE
P1	04.10.23	RAD	SD	PRELIMINARY ISSUE

PRELIMINARY

Client: LITA HOMES

Architect: CREATE DESIGN

Project: WELLING UNITED FC

Drawing: SITE EXISTING ELECTRICAL SERVICES

Mendick Waring Limited
Lymehouse Studios, 30/31 Lyme Street, London NW1 0EE
Tel: 020 8446 9696 Web: www.mwl-group.com
E-Mail: enquiries@mwl-group.com

Scale	Size	Engineer	Date
1:200	A0	SD	SEPT '23

Drawing No. 2927-40-60-0S

Rev P2