

Certificate of Bacteriological Examination

Potable Water Sample



Laboratory Reference: 10240809
Your Reference: 08466
For the attention of: S Aiken
Received From: Aberdeenshire Council Environmental Health
Gordon House Blackhall Road Inverurie
Received On: 7 June 2023
Sample Name: Gairnshiel Schoolhouse, Glen Gairn, Ballater
Taken On: 7 June 2023
Date of Examination: 7 June 2023

Results of Examination

Method Code	Determination	Result	Units
i7404a	Total Coliforms	Not detected	Most Probable Number in 100 millilitre
i7404b	Escherichia coli	Not detected	Most Probable Number in 100 millilitre
i7604	Enterococci	Not detected	colony forming units per 100 millilitre


Comments: (1)

The above parameters comply with the requirements of the Private Water Supplies (Scotland) Regulations 2006.

This sample was examined in line with UKAS ISO 17025:2017 but not DWTS.

- (1) Comments and opinions are outside the scope of UKAS accreditation
- (4) The results reported relate to samples received by the laboratory and may not be representative of the whole batch
- (5) Customers are responsible for the information provided. If incorrect, it could affect the validity of results.
- (6) This report may not be reproduced, except in full, without the written permission of the laboratory.

Signature:



Name: Kerry Parrott HNC, MIFST,

Status: Principal Scientist

Official Address: Aberdeen Scientific Services Laboratory, James Hutton Institute Building, Craigiebuckler, AB15 8QH

Telephone Number: (01224) 767420

Date of Report: 13 June 2023

Issue Number: 1



1325