



CONSTRUCTION (DESIGN AND MANAGEMENT) REGULATIONS 2015

DESIGNERS HAZARD INFORMATION FOR CONSTRUCTION
 IF YOU CAN NOT FULLY UNDERSTAND THE RISKS FROM THE DRAWING, THE CONTRIBUTION OF THE
 FIRM INDICATED ON THIS DRAWING AND THE PROJECT MANAGER, HEALTH & SAFETY ADVISOR
 OR A MEMBER OF THE DESIGN TEAM BEFORE PROCEEDING.

THE ABOVE HAZARD INFORMATION IS SPECIFICALLY TO THE INFORMATION SHOWN ON THIS DRAWING.
 REFER TO THE HEALTH & SAFETY PLAN FOR FURTHER INFORMATION.

NOTES				REF	DESCRIPTION	DATE	BY	CLIENT													
1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTURAL & STRUCTURAL DRAWINGS.	5. ALL HEATING PIPEWORK SHALL BE HEAVY GRADE STEEL PIPEWORK TO BS EN 10255:2004.	8. HEATING PIPEWORK BRANCHES SHALL BE COMPLETE WITH ISOLATION VALVE ON THE FLOW AND DOUBLE REGULATING VALVE OR COMMISSIONING SET ON THE RETURN AS INDICATED.	9. ALL RADIATORS, EXCEPT IN CIRCULATION AREAS, TO BE COMPLETE WITH A THERMOSTATIC RADIATOR VALVE ON THE FLOW CONNECTION AND LOCKSHIELD VALVE ON THE RETURN CONNECTION. ALL CONNECTIONS TO BE TB06 UNLESS INDICATED OTHERWISE.					<p>PROJECT: ARCHBISHOP CRAMMER CE PRIMARY SCHOOL</p> <p>DRAWING TITLE: INDICATIVE HEATING LAYOUT</p>													
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT BUILDING SERVICES DRAWINGS & THE RELEVANT SECTIONS OF THE SPECIFICATIONS & SCHEDULES.	6. ALL HEATING PIPEWORK, WITH THE EXCEPTION OF FINAL DROPS TO RADIATORS, SHALL BE INSULATED.						<table border="1"> <thead> <tr> <th>DRN</th> <th>CHKD</th> <th>SCALE</th> <th>SHEET</th> <th>PROJECT NO.</th> <th>MECHANICAL</th> <th>ELECTRICAL</th> </tr> </thead> <tbody> <tr> <td>KG</td> <td>KG</td> <td>1:100</td> <td>A0</td> <td>230524</td> <td>KG</td> <td>KG</td> </tr> </tbody> </table> <p>STATUS: STAGE 3 - SUITABLE FOR REVIEW & COMMENT</p> <p>PROJECT: 230524-G&G-XX-XX-M-DR-1100</p> <p>PROJECT ORIGINATOR: G&G DESIGN SERVICES</p>		DRN	CHKD	SCALE	SHEET	PROJECT NO.	MECHANICAL	ELECTRICAL	KG	KG	1:100	A0	230524	KG
DRN	CHKD	SCALE	SHEET	PROJECT NO.	MECHANICAL	ELECTRICAL															
KG	KG	1:100	A0	230524	KG	KG															
3. THIS DRAWING IS NOT TO BE SCALED.	7. AUTOMATIC AIR VENTS TO BE FITTED AT ALL HIGH POINTS. DRAIN COCKS TO BE FITTED AT ALL LOW POINTS.							<table border="1"> <thead> <tr> <th>REV</th> <th>DESCRIPTION</th> <th>DATE</th> <th>BY</th> </tr> </thead> <tbody> <tr> <td>T01</td> <td>TENDER ISSUE</td> <td>20.10.23</td> <td>EG</td> </tr> </tbody> </table>	REV	DESCRIPTION	DATE	BY	T01	TENDER ISSUE	20.10.23	EG					
REV	DESCRIPTION	DATE	BY																		
T01	TENDER ISSUE	20.10.23	EG																		
4. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.								<p>THIS DRAWING IS A STAGE 3 INDICATIVE DRAWING. CONTRACTOR TO DEVELOP THE DESIGN INTENT TO FULL DETAILED DESIGN. ANY SIZING INFORMATION PROVIDED IS TO BE VERIFIED BY THE CONTRACTOR.</p>													

