


GGP Consult		Page 1
2 Hallam Road, Priory Park East Hull, Humberside HU4 7DY		
Date 15/02/2024 22:03 File Calcs 3.5ls.SRCX	Designed by GGPAeecOne Checked by	

Innovyze Source Control 2020.1.3

Summary of Results for 1 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Control (l/s)	Max Volume (m ³)	Status
15 min Summer	31.403	0.103	3.4	10.3	O K
30 min Summer	31.425	0.125	3.4	12.5	O K
60 min Summer	31.439	0.139	3.5	13.9	O K
120 min Summer	31.441	0.141	3.5	14.1	O K
180 min Summer	31.435	0.135	3.5	13.5	O K
240 min Summer	31.427	0.127	3.4	12.7	O K
360 min Summer	31.409	0.109	3.4	10.9	O K
480 min Summer	31.392	0.092	3.3	9.2	O K
600 min Summer	31.379	0.079	3.3	7.9	O K
720 min Summer	31.368	0.068	3.2	6.8	O K
960 min Summer	31.353	0.053	3.0	5.3	O K
1440 min Summer	31.336	0.036	2.5	3.6	O K
2160 min Summer	31.322	0.022	2.0	2.2	O K
2880 min Summer	31.314	0.014	1.7	1.4	O K
4320 min Summer	31.305	0.005	1.3	0.5	O K
5760 min Summer	31.300	0.000	1.1	0.0	O K
7200 min Summer	31.300	0.000	0.9	0.0	O K
8640 min Summer	31.300	0.000	0.8	0.0	O K
10080 min Summer	31.300	0.000	0.7	0.0	O K
15 min Winter	31.417	0.117	3.4	11.7	O K
30 min Winter	31.445	0.145	3.5	14.5	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m ³)	Discharge Volume (m ³)	Time-Peak (mins)
15 min Summer	41.703	0.0	13.1	19
30 min Summer	27.689	0.0	17.4	31
60 min Summer	17.920	0.0	22.5	48
120 min Summer	11.387	0.0	28.6	84
180 min Summer	8.699	0.0	32.8	118
240 min Summer	7.177	0.0	36.2	152
360 min Summer	5.419	0.0	40.9	216
480 min Summer	4.438	0.0	44.7	278
600 min Summer	3.801	0.0	47.8	338
720 min Summer	3.350	0.0	50.6	396
960 min Summer	2.744	0.0	55.3	514
1440 min Summer	2.074	0.0	62.7	754
2160 min Summer	1.564	0.0	70.9	1108
2880 min Summer	1.281	0.0	77.4	1472
4320 min Summer	0.968	0.0	87.8	2204
5760 min Summer	0.794	0.0	96.0	0
7200 min Summer	0.680	0.0	102.8	0
8640 min Summer	0.598	0.0	108.5	0
10080 min Summer	0.536	0.0	113.5	0
15 min Winter	41.703	0.0	14.7	19
30 min Winter	27.689	0.0	19.5	31

2 Hallam Road, Priory Park East
Hull, Humberside
HU4 7DY

Date 15/02/2024 22:03
File Calcs 3.5ls.SRCX

Designed by GGPAeecOne
Checked by



Innovyze

Source Control 2020.1.3

Summary of Results for 1 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Control (l/s)	Max Volume (m ³)	Status
60 min Winter	31.460	0.160	3.5	16.0	O K
120 min Winter	31.460	0.160	3.5	16.0	O K
180 min Winter	31.448	0.148	3.5	14.8	O K
240 min Winter	31.433	0.133	3.5	13.3	O K
360 min Winter	31.404	0.104	3.4	10.4	O K
480 min Winter	31.380	0.080	3.3	8.0	O K
600 min Winter	31.362	0.062	3.2	6.2	O K
720 min Winter	31.352	0.052	2.9	5.2	O K
960 min Winter	31.338	0.038	2.5	3.7	O K
1440 min Winter	31.322	0.022	2.0	2.2	O K
2160 min Winter	31.310	0.010	1.5	1.0	O K
2880 min Winter	31.303	0.003	1.3	0.3	O K
4320 min Winter	31.300	0.000	1.0	0.0	O K
5760 min Winter	31.300	0.000	0.8	0.0	O K
7200 min Winter	31.300	0.000	0.7	0.0	O K
8640 min Winter	31.300	0.000	0.6	0.0	O K
10080 min Winter	31.300	0.000	0.5	0.0	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m ³)	Discharge Volume (m ³)	Time-Peak (mins)
60 min Winter	17.920	0.0	25.3	52
120 min Winter	11.387	0.0	32.1	90
180 min Winter	8.699	0.0	36.8	128
240 min Winter	7.177	0.0	40.4	162
360 min Winter	5.419	0.0	45.9	228
480 min Winter	4.438	0.0	50.0	290
600 min Winter	3.801	0.0	53.6	344
720 min Winter	3.350	0.0	56.7	404
960 min Winter	2.744	0.0	61.9	522
1440 min Winter	2.074	0.0	70.2	756
2160 min Winter	1.564	0.0	79.4	1112
2880 min Winter	1.281	0.0	86.8	1496
4320 min Winter	0.968	0.0	98.3	0
5760 min Winter	0.794	0.0	107.6	0
7200 min Winter	0.680	0.0	115.2	0
8640 min Winter	0.598	0.0	121.5	0
10080 min Winter	0.536	0.0	127.1	0

2 Hallam Road, Priory Park East
Hull, Humberside
HU4 7DY



Date 15/02/2024 22:03
File Calcs 3.5ls.SRCX

Designed by GGPAeecOne
Checked by

Innovyze Source Control 2020.1.3

Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	1	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.000	Shortest Storm (mins)	15
Ratio R	0.355	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.168

Time (mins)	Area	Time (mins)	Area
From: To:	(ha)	From: To:	(ha)
0 4	0.084	4 8	0.084

2 Hallam Road, Priory Park East
 Hull, Humberside
 HU4 7DY



Date 15/02/2024 22:03
 File Calcs 3.5ls.SRCX

Designed by GGPAeecOne
 Checked by

Innovyze Source Control 2020.1.3

Model Details

Storage is Online Cover Level (m) 33.700

Tank or Pond Structure

Invert Level (m) 31.300

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	100.0	1.200	100.0	1.201	1.0	2.400	1.0

Hydro-Brake® Optimum Outflow Control

Unit Reference MD-SHE-0092-3500-0800-3500
 Design Head (m) 0.800
 Design Flow (l/s) 3.5
 Flush-Flo™ Calculated
 Objective Minimise upstream storage
 Application Surface
 Sump Available Yes
 Diameter (mm) 92
 Invert Level (m) 31.250
 Minimum Outlet Pipe Diameter (mm) 150
 Suggested Manhole Diameter (mm) 1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.800	3.5
Flush-Flo™	0.238	3.5
Kick-Flo®	0.521	2.9
Mean Flow over Head Range	-	3.0

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	2.9	1.200	4.2	3.000	6.5	7.000	9.7
0.200	3.5	1.400	4.5	3.500	7.0	7.500	10.0
0.300	3.5	1.600	4.8	4.000	7.4	8.000	10.3
0.400	3.3	1.800	5.1	4.500	7.8	8.500	10.6
0.500	3.0	2.000	5.3	5.000	8.2	9.000	10.9
0.600	3.1	2.200	5.6	5.500	8.6	9.500	11.2
0.800	3.5	2.400	5.8	6.000	9.0		
1.000	3.9	2.600	6.0	6.500	9.3		