



Polypipe Building Products Ltd		Page 1
Broomhouse Lane Edlington Doncaster DN12 1ES	98201 Alexandra Rd Frampton Cotterel 3m x 3.5m x 0.4	
Date 06/11/2023 File T-MD-98201_HP_MD4RevA.SRCX	Designed by HP Checked by	
Micro Drainage	Source Control 2020.1.3	

Summary of Results for 100 year Return Period (+45%)

Half Drain Time : 85 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m <sup>3</sup> )	Status
15 min Summer	98.829	0.229	0.4	2.3	O K
30 min Summer	98.889	0.289	0.4	2.9	O K
60 min Summer	98.929	0.329	0.4	3.3	O K
120 min Summer	98.940	0.340	0.4	3.4	O K
180 min Summer	98.930	0.330	0.4	3.3	O K
240 min Summer	98.914	0.314	0.4	3.1	O K
360 min Summer	98.883	0.283	0.4	2.8	O K
480 min Summer	98.853	0.253	0.4	2.5	O K
600 min Summer	98.825	0.225	0.4	2.2	O K
720 min Summer	98.800	0.200	0.4	2.0	O K
960 min Summer	98.755	0.155	0.4	1.5	O K
1440 min Summer	98.692	0.092	0.3	0.9	O K
2160 min Summer	98.650	0.050	0.3	0.5	O K
2880 min Summer	98.640	0.040	0.3	0.4	O K
4320 min Summer	98.629	0.029	0.2	0.3	O K
5760 min Summer	98.624	0.024	0.2	0.2	O K
7200 min Summer	98.620	0.020	0.1	0.2	O K
8640 min Summer	98.617	0.017	0.1	0.2	O K
10080 min Summer	98.615	0.015	0.1	0.2	O K
15 min Winter	98.858	0.258	0.4	2.6	O K


Storm Event	Rain (mm/hr)	Flooded Volume (m <sup>3</sup> )	Time-Peak (mins)
15 min Summer	136.560	0.0	17
30 min Summer	91.729	0.0	32
60 min Summer	58.739	0.0	58
120 min Summer	36.254	0.0	90
180 min Summer	26.900	0.0	124
240 min Summer	21.623	0.0	158
360 min Summer	15.914	0.0	228
480 min Summer	12.782	0.0	294
600 min Summer	10.774	0.0	358
720 min Summer	9.365	0.0	422
960 min Summer	7.499	0.0	542
1440 min Summer	5.473	0.0	778
2160 min Summer	3.985	0.0	1104
2880 min Summer	3.178	0.0	1468
4320 min Summer	2.306	0.0	2204
5760 min Summer	1.834	0.0	2936
7200 min Summer	1.536	0.0	3664
8640 min Summer	1.330	0.0	4352
10080 min Summer	1.178	0.0	5088
15 min Winter	136.560	0.0	17

Polypipe Building Products Ltd		Page 2
Broomhouse Lane Edlington Doncaster DN12 1ES	98201 Alexandra Rd Frampton Cotterel 3m x 3.5m x 0.4	
Date 06/11/2023 File T-MD-98201_HP_MD4RevA.SRCX	Designed by HP Checked by	
Micro Drainage	Source Control 2020.1.3	

Summary of Results for 100 year Return Period (+45%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m <sup>3</sup> )	Status
30 min Winter	98.929	0.329	0.4	3.3	O K
60 min Winter	98.979	0.379	0.4	3.8	O K
120 min Winter	98.990	0.390	0.4	3.9	O K
180 min Winter	98.975	0.375	0.4	3.7	O K
240 min Winter	98.952	0.352	0.4	3.5	O K
360 min Winter	98.904	0.304	0.4	3.0	O K
480 min Winter	98.858	0.258	0.4	2.6	O K
600 min Winter	98.817	0.217	0.4	2.2	O K
720 min Winter	98.780	0.180	0.4	1.8	O K
960 min Winter	98.719	0.119	0.3	1.2	O K
1440 min Winter	98.650	0.050	0.3	0.5	O K
2160 min Winter	98.637	0.037	0.2	0.4	O K
2880 min Winter	98.629	0.029	0.2	0.3	O K
4320 min Winter	98.621	0.021	0.1	0.2	O K
5760 min Winter	98.617	0.017	0.1	0.2	O K
7200 min Winter	98.614	0.014	0.1	0.1	O K
8640 min Winter	98.612	0.012	0.1	0.1	O K
10080 min Winter	98.611	0.011	0.1	0.1	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m <sup>3</sup> )	Time-Peak (mins)
30 min Winter	91.729	0.0	31
60 min Winter	58.739	0.0	58
120 min Winter	36.254	0.0	96
180 min Winter	26.900	0.0	134
240 min Winter	21.623	0.0	172
360 min Winter	15.914	0.0	246
480 min Winter	12.782	0.0	314
600 min Winter	10.774	0.0	380
720 min Winter	9.365	0.0	446
960 min Winter	7.499	0.0	566
1440 min Winter	5.473	0.0	748
2160 min Winter	3.985	0.0	1104
2880 min Winter	3.178	0.0	1472
4320 min Winter	2.306	0.0	2204
5760 min Winter	1.834	0.0	2888
7200 min Winter	1.536	0.0	3680
8640 min Winter	1.330	0.0	4408
10080 min Winter	1.178	0.0	5024

Polypipe Building Products Ltd		Page 3
Broomhouse Lane Edlington Doncaster DN12 1ES	98201 Alexandra Rd Frampton Cotterel 3m x 3.5m x 0.4	
Date 06/11/2023 File T-MD-98201_HP_MD4RevA.SRCX	Designed by HP Checked by	
Micro Drainage	Source Control 2020.1.3	


Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.000	Shortest Storm (mins)	15
Ratio R	0.350	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+45

Time Area Diagram

Total Area (ha) 0.010

Time (mins)		Area
From:	To:	(ha)
0	4	0.010

Polypipe Building Products Ltd		Page 4
Broomhouse Lane Edlington Doncaster DN12 1ES	98201 Alexandra Rd Frampton Cotterel 3m x 3.5m x 0.4	
Date 06/11/2023 File T-MD-98201_HP_MD4RevA.SRCX	Designed by HP Checked by	
Micro Drainage	Source Control 2020.1.3	

Model Details

Storage is Online Cover Level (m) 100.000

Cellular Storage Structure

Invert Level (m) 98.600 Safety Factor 2.0  
 Infiltration Coefficient Base (m/hr) 0.20570 Porosity 0.95  
 Infiltration Coefficient Side (m/hr) 0.20570

Depth (m)	Area (m <sup>2</sup> )	Inf. Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )	Inf. Area (m <sup>2</sup> )
0.000	10.5	10.5	0.500	0.0	15.7
0.400	10.5	15.7			