

EXISTING

SITE PLAN

Lay 100mm Supa sleeve pipes of minimum fall of 1 in 40 bedded and haunched in 100mm of concrete or 100mm underground pvc pipes on pea shingle may be used if agreed by Local Authority. Where drains run under building encase in 150mm concrete if required by Lay 600x300mm concrete foundations to minimum depth of 1m or as agreed on site by L.A. and to suit ground conditions where walls are within 1m of drains foundations to be taken down to

Ground floor finish as agreed with client on 75mm cement screed reinforced with chicken wire over 100mm GA4000 Celotex on 150mm site concrete with 1200 G d.p.m. under to be contiguous with existing house and new wall d.p.c. on 50mm sand blinding on 150mm hardcore

cavity is bridged provide stepped d.p.c horizontal d.p.c to be minimum 150mm above adjoining external ground level. Seal cavity at top of walls external render to have waterproof additive and 350mm cavity wall of two skins 100mm Celcon blocks with stainless steel wall ties at 450mm vertical and 750mm horizontal crs. 50mm clear cavity 100mm CW4000 Celotex insulation secured with wall tie clips to inner skin as manufacturers recommendations, walls rendered externally

Flat roof - warm deck construction to be covered with 12mm thick mineral chippings bedded in hot bitumen over 3 layers of roofing felt complying with B.S 747 all set in hot bitumen over 150mm Recticel Powerdeck F laid on a vapour control layer, firings to provide fall of 1 in 60 on joists sizes

Steel beams to be encased with 2 layers of 9.5mm plasterboard fixed with 1.6mm wire binding at 100mm pitch and set with 7mm plaster beams to rest on concrete padstone at each end. Minimum end bearing for beams 225mm or agreed with L.A twin steel beams to be diaphragm bolted together with spacers at 900mm crs, steel beams encased in concrete to be wrapped in 6mm dia. M.S links at 225mm horizontal centres and encased in minimum 50mm concrete cover

up to first floor and at max 1.2m crs above first floor level, fixing of straps to joists as per manufacturers recommendations according to exposure rating and to conform with BSCP112. Sanitary fittings to run in single stack to relevant s.v.p bath basin shower bidet and sink all to be fitted with 75mm deep seal traps. Waste pipes sizes as indicated on plan; all to have cleaning eyes at any change of direction no waste pipe to connect to s.v.p. within areas of 200mm of

habitable rooms by trickle vent 1.7m above F.F.L. Install extractor fan to new and extended kitchens, extractor fan to provide extract rate of 60 litres/se, alternatively provide cooker hood extractor to provide extract rate of 30litres/sec. install extractor fan to new bathroom or shower room, extractor fan to provide extract rate of 15 litres/sec. new utility extractor to provide extract rate of 30 litres/sec. provide Background ventilation of 4000mm.sq to kitchen, bathroom, shower room and utility room. All habitable rooms to be provided with windows supplying an open able

to be in safety glass to comply with B.S 6206 Class C. All new window and external doors to be

been complied with. This may require an appropriate B.S. 7671 installation certificate to be issued

thermostatic valves. If existing boiler is to be replaced new boiler to have a SEDBUK rating of There are no trees in vicinity of building. Where building within a distance of 3m from a drain