

**PAVING SPECIFICATIONS**

**CAR PARK (ASPHALT)**

**SURFACE COURSE** 40mm SMA 10 SURFACE COURSE 40/60 RECIPE TO COMPLY WITH BS EN 13108-1

**BINDER COURSE** 60mm ASPHALT CONCRETE 20 DENSE BINDER COURSE 40/60 RECIPE TO COMPLY WITH BS EN 13108-1, (1.25 PEN BITUMEN GRADE BINDER)

**BASE COURSE** 110mm ASPHALT CONCRETE 32 DENSE BASE COURSE 40/60 RECIPE TO COMPLY WITH BS EN 13108-1, (1.25 PEN BITUMEN GRADE BINDER)

**SUB-BASE** 250mm (MIN) Dtp TYPE 1

**CAR PARK (NO DIG)**

'CELLWEB' OR SIMILAR APPROVED NO-DIG CAR PARK CONSTRUCTION, FINAL SPECIFICATION TO BE AGREED.

NOTE: ENSURE NO FROST SUSCEPTIBLE MATERIAL IS WITHIN 450mm OF FINISHED SURFACE  
 CONTRACTOR TO ALLOW FOR CARRYING OUT CBR TESTS AT FORMATION LEVEL, LOCATIONS TO BE AGREED WITH CIVIL ENGINEER.

ALL CAPPING / SUB-BASE TO BE WELL ROLLED & COMPACTED FULLY IN ACCORDANCE WITH CURRENT HIGHWAYS MANUAL WITH REGARDS COMPACTION / NUMBER OF PASSES ETC.

© 2023 This drawing is copyright of Keith Simpson Associates Ltd and must not be copied or reproduced without prior written approval of Keith Simpson Associates Ltd. All rights reserved.

**NOTES:**  
 DO NOT SCALE. All dimensions to be checked / verified on site.  
 All drawings to be read in conjunction with Architects / Civil Engineers drawings & specification.

**EXTERNAL WORKS KEY**

- F.F.L = XX.XXX FINISHED FLOOR LEVEL
- XX.XXX PROPOSED LEVEL
- GRADIENT
- ROAD GULLY
- CHANNEL DRAIN



P5	25/10/23	SITE LAYOUT AMENDED	SR	NH
P4	17/10/23	SITE LAYOUT AMENDED	SR	NH
P3	12/09/23	SCHEME AMENDED	SR	NH
P2	10/02/23	SITE PLAN UPDATED	TB	NH
P1	01/02/23	PRELIMINARY ISSUE	TB	NH
Rev	Date	Description	Drwn	Chkd

7C Colwick Quays Business Park  
 Colwick  
 Nottingham  
 NG4 2JY

Consulting Engineers  
 • Structural • Civil •

Tel: 0115 967 3100  
 Web: www.ksastructures.co.uk

Client  
 RADFORD HOLDINGS

Project  
 PARK HOUSE  
 MILE END ROAD  
 COLWICK  
 NOTTINGHAM

Drawing Title  
 EXTERNAL WORKS LAYOUT

Managing Engineer NICK HUDSON

Scale	Date	Size
1:200	FEB 23	A1

Status  
 PRELIMINARY

Drw. No.	Rev.
6142-EW-01	P5