



**KEY:**

- EV Electric Charging Point
- ▲ Pole mounted Electric Dual Charging Point

Rev	Date	Details
A	14.07.23	Resubmission amendments to suit Planning comments.
B	05.09.23	EV chargers updated to plots 3, 39, 16/17, 44-55.
C	22.11.23	Reissue to suit revised site layout changes.
D	23.02.24	Amended to suit revised site layout changes.

**Notes:**

All proposed charging points to be capable of providing a minimum supply of 3.7kW.

Allocated parking spaces denoted 'EV' are a minimum of 2.8m wide, allocated tandem parking spaces are minimum 3.0m wide.

SCALE BAR 1:500

**Key**

— Site Boundary

○ Preliminary   ○ Design   ○ Information   ○ Comment   ● Planning   ○ Construction

**ophir**

Client: Vistry West Midlands

Project: Woodside Conference Centre, Kenilworth   Job No: BVA04   Drawing No: PL012

Title: EV Charging Plan   Date: 11.03.23   Rev: D

Scale: 1:500   Sheet Size: @ A1   Drawn: DM   Checked: MB

T: 0121 439 1151   Registered in England and Wales, Company No. 11129477

E: admin@ophirarchitecture.com   All architectural drawings and floor plans are subject to verification by Contractors on site. No drawings or designs are the copyright of Ophir Architecture Ltd. No reproduction or alteration is permitted without prior written consent.