

SPECIFICATION

- Applies to all landscape operations.

1 GENERAL

1.1 Preliminaries

Health and Safety considerations are as the Bloor Homes Trade Specifications.
The following specification is in line with the Trade Specifications, however, where there are specific requirements, these notes take precedence over the general guidance outlined within the Trade Specification. The Site Manager should possess and distribute information to the relevant contractors regarding all underground services, engineering, drainage, lighting and ecological constraints and current proposed landscaping operations.
Tree and hedgerow protection, subsoil cultivation, topsoiling and leveling/grading operations outlined above are the responsibility of the Site Agent unless stated otherwise.
Trees in hard surfaces will require engineering tree pits, which will require construction within curbs and service roads are being installed. Reference should be made to the appropriate tree pit detail drawing provided by the engineers and on the landscape drawings where applicable.
Where tree pits are within 5m of roads and services, and within 3m of other paved surfaces, a linear root barrier is to be installed in accordance with the manufacturer's instructions. The barrier should be as near as possible to the surface or service route to be protected so as much rooting as possible to the tree.
*Distances may vary according to requirements.

1.2 Soft Landscaping Considerations
All soft landscaping should be carried out by specialist landscape sub-contractor who is either British Association of Landscape Industries (BALI) accredited or can demonstrate a proven track record. All plants shall conform to the specification details shown on this drawing, which are taken from the National Plant Specification, and must be well rooted, healthy stock. Plants required for hedging or mowing must be uniform in every respect.
Plants must be in accordance with the relevant section of the current BS 3938 Nursery Stock Specification, and trees to the most current BS 8545 Trees: From Nursery to Independence in the Landscape. Supplying nurseries shall be registered under the HTA Nursery Certification Scheme.
All plants shall be packed, transported and handled in accordance with the Code of Practice for Plant Production and Transporting as produced by the Contractors for Plant Supply and Establishment (CPSE) and handling of trees to the most current BS 8545.

1.3 Tending and Impalement
Landscape Contractors are required to tender and implement as per the schedule and specification. It is recognised that there are seasonal variations in plant availability and so it may be necessary for plant specifications to be revised. However any substitutions should be with a suitable alternative of comparable size to meet the schedule requirements, and should be approved by the Bloor Homes Landscape Design/Commercial Department.
All landscape implementation will be audited. Plant material not approved will be rejected and replaced at the Landscape Contractor's own expense, as stated in 1.2.
The site should be bound in accordance with the Ground Workers Trade Specification document which includes the removal of all builder's debris and the hardcore base set for surfacing.

2 RETENTION OF EXISTING TREES AND HEDGEROWS
Precautions must be taken to ensure that trees and hedgerows shown for retention remain undisturbed with roots and branches protected with rootbarriers in accordance with the most current BS 5837 Trees in Relation to Design, 30mm clearances and the relevant sections of the current BS 3938 Recommendation for Tree Work and must comply with any Conservation Area, Tree Preservation Orders or specific planning conditions where appropriate.
Reference must be made to Tree Protection Drawings.

3 PRE-PLANTING AND PRE-TURNING GROUND PREPARATION (Groundworking)
3.1 Subsoil Cultivation
Prior to any topsoiling all subsoil should be thoroughly 'rippled' to relieve compaction using suitable machinery, or by hand in confined areas or in proximity to existing tree roots to a depth of 150mm.

3.2 Imported and Stored Topsoil
Wherever possible store and spread existing topsoil to POS areas to encourage re-generation of localised native species.
Topsoil, topsoiling and soil storage operations are to be carried out in accordance with the current BS 3883 Specification for Topsoil. Topsoil spreading should be carried out to the depths shown below and all topsoiled areas should be cleared of all extraneous matter such as perennial weeds, plastic, wood, metal and stones greater than 50mm in any dimension which should be removed from site to a licensing facility. Maximum depth of topsoil after forming and before subsoil cultivation to be achieved:
Type of Soft Landscaping Topsoil Depth Depth of subsoil to be broken up
Planted areas* 100mm 150mm
Grass Areas 150mm 150mm
Rear Gardens 150mm 150mm
* Remove extraneous matter within cultivated subsoil above 75mm in any dimension.

3.3 Leveling/Grading
In final grading operations finished soil levels adjacent to buildings are to be 150mm below damp proof course. For planted areas where 75mm depth bark mulch is specified the soil should be graded down towards adjacent paved areas to a minimum of 10mm. This allows for full depth of bark mulch with 15mm clearance. For turfed areas final soil levels should be 30mm above the adjacent paving ready to receive the turf and level seeded areas at least 30mm above.
3.4 Weed Treatment
Only where necessary, because significant weed growth has started to establish, treat existing weeds with a non-residual broad herbicide using a suitable product as recommended by the manufacturer for this to take effect. Herbicides should be used strictly in accordance with the Pesticides Act 1999 (or otherwise updated legislation), according to manufacturer's instructions and only by qualified staff. Use products that are approved by the Soil Conservation Society.
Remove small amounts of weed growth within shrub beds by hand at time of planting.

4 PLANTING
4.1 Ground Preparation
Planting shall not be carried out when the ground is waterlogged, frost bound or during periods of cold dry weather.
All planting, weeding and watering operations are to be in accordance with latest BS 4428 Code of Practice for General Landscaping Operations.
A general purpose organic slow release fertilizer at the rate of 100g/m² is to be incorporated into the top 150mm of topsoil during final subsoiling.
4.2 Setting Out
Shrubs and hedges are to be set out on the drawing at the specified densities and centres. The operatives carrying out the works should be able to interpret drawings, set out landscaping areas and communicate any discrepancies with our Site Manager.
Ornamental hedges are to be planted in a single row unless otherwise stated.
Trees are to be planted in the positions shown on the drawing ensuring that they are at the correct distances from adjacent buildings and 1.5m from drainage runs.
It is imperative that trees are planted with the correct species and location as specified in the drawings in accordance with the Hortic Standards Chapter 4.2, or the LABC Standards, whichever is applicable. It is the contractor's responsibility to ensure that all underground services have been located and identified in advance of tree excavation to avoid damage to any underground services or cables.

4.3 Planting
Bare rooted and root balled stock to be planted between mid-November and mid-February.
Planting pits are to be dug to the container size or root ball of the plant and shall be sufficiently large enough to accommodate the plants without root damage and to allow for backfill of topsoil and planting compost.
All ornamental hedgerow boundary plants are to be 'topped' out to form a level edge across each section of new hedging.
Plants are to be planted into the prepared soil incorporating great tree care and shrub control in quantities shown below, and formed in.
Quantities of great tree and shrub planting compost:
2.5 Shrubs and Herbaceous 3 litres
5.0 Shrubs 5 litres
25.0 Specimens 10 litres
Trees 20.0 litres plus 100g/m² organic slow release fertiliser and 150ml mycorrhizal dressing such as 'Rootgrow'

4.4 Mulch
All trees and shrubs are to be watered thoroughly, to full ground capacity, immediately after planting and before the application of mulch. The landscape contractor shall allow for provision of all equipment to complete this initial watering, using water supply point as directed on site.

4.4 Tree Planting
Tree planting operations should be in accordance with part 30 of the current BS 8545 Trees from Nursery to Independence in the Landscape.
Trees are to be excavated to a minimum of 1m x 1x600mm with sides well sorted to prevent overswing, the base of tree pits are to remain undisturbed and should only be broken up if there is a drainage problem and/or soil gain. If conditions make drainage increases this should be provided away from the tree, with the base of the pit sloped to direct water into a drainage pipe.
Backfill of tree pits should be formed by hand using topsoil followed by layers of topsoil with compost etc. as shown above.
Root flare of the newly planted tree should be clearly visible at the soil surface. It should not be buried by excess soil or by mulch.
Ensure trees in hard surfaces and in restricted areas are planted in accordance with the appropriate tree planting detail with sufficient volume of tree soil.
At trees are to be watered thoroughly, immediately after planting. The landscape contractor shall allow for provision of all equipment to complete this initial watering, using water supply point as directed on site.
Each tree is to receive at least 30 gallons when watered.

4.5 Tree Support
All heavy standard trees shall be double staked with 100mm diameter stakes and a half round timber cross brace fitted to the windward side of the tree within 25mm of the top of the stakes ensuring that the tree is vertical and straight.
Stakes are to be securely driven into the ground prior to planting to a height above ground that is one third of the height above ground of the tree when planted to allow free movement of the crown. Secure street trees to be securely driven into the ground prior to planting to a height above and buckle (buckle end to be nailed to stake).
Secure POS trees with a double galvanized stainless tree tie, wrapping the material round itself to form a spacer and railing to the stake or cross brace.
Each tree should be fitted with a tree irrigation/eration system unit fitted to fully surround the root ball in accordance with the details. Refer to specific tree planting details.
Linear root barriers where required should be installed as per the manufacturer's instructions to be installed as per the manufacturer's instructions to be installed as per the manufacturer's instructions. Ensure that there are no sharp objects close to either side of the barrier and that the top edge of the root barrier remains 10mm above the surface on the tree side with no growing medium over the top of the barrier. Overlapping ends should be joined by taping both sides with joining tape.

4.6 Mulch
All trees and shrubs are to be watered thoroughly, to full ground capacity, immediately after planting and before the application of mulch. The landscape contractor shall allow for provision of all equipment to complete this initial watering, using water supply point as directed on site.
Ensure the area to be mulched is entirely free from annual and perennial weeds and has been watered prior to applying an even grade of mulch to planting areas to control weeds and retain moisture.
Unless instructed otherwise apply good quality bark mulch to a depth of 75mm to planting beds, hedgerows and tree trunks.
Where extra mulch is requested by the regional office apply 400mm of stone over Planting Gosselin membrane or equivalent geotextile sheet with metal pegs.
Finished soil levels adjacent to buildings are to be 150mm below damp proof course. For planted areas where 75mm depth bark mulch is specified the soil should be graded down to adjacent paved or grass surfaces 300mm below the paving or grass. This allows for full depth of bark mulch with 15mm clearance.
Where 40mm depth stone mulch is specified with grass below, membrane grade to 15mm below adjacent paving or grass levels within 50mm.
Finished mulch levels should be no higher than 15mm below adjacent paving or grass levels to avoid any spillages.

4.7 Whip Planting
Bare root plants are to be notch planted, ensuring the notch is vertical and deep enough for the roots to hang freely. The notch is to be closed and the soil well firmed around the roots. Any container grown or root balled plants are to be pit planted. All stock is to be fitted with a 600mm minimum size clear plastic spiral rabbit guard secured to a bamboo cane, or a tree shelter secured to a stake as appropriate.
4.8 Native Hedge Planting
Hedges are to be notch planted in a trench 450mm wide x 300mm deep planting in a double staggered row at 330mm centres with 300mm between rows, backfilling with the excavated material incorporated with a general purpose slow release fertilizer at a rate of 100g/m². Each plant is to be fitted with a clear plastic spiral rabbit guard secured to a bamboo cane support. Any container grown or root balled plants are to be fitted with a suitable tree shelter secured to a stake.

5 GRASS
5.1 Turf Preparation
The area to be turfed shall be cultivated to a minimum depth of 150mm removing all weeds, debris and stones over 25mm diameter which should be placed in waste skips provided or as directed by the site manager. The surface shall be sealed to smooth flowing contours with a fine 100, incorporating pre-turf fertilizer at 50g/m².
5.2 Delivery and Storage
Turf shall be supplied in accordance with the most current BS 3909 Recommendations for Turf for General Purposes.
Turf shall be cultivated high grade turf well rooted, washed turf free from stones, weeds and coarse grasses. It shall be close textured, green in colour and be sufficiently fibrous to withstand handling. Turf rolls shall be regular in shape, 1000mm wide and of uniform thickness (minimum 25mm). The grass shall be closely mown and shall not exceed 25mm in height.
Turf shall be stacked in piles up to 1 metre. It shall not be laid in frosty or waterlogged conditions and shall not be stacked in rolls for more than three days. Any turf deemed to be substandard shall be replaced at the landscape sub-contractors cost.
5.3 Turf
Turfing operations shall be in accordance with the most current BS 4428.
Turf should be laid when weather conditions are suitable and not during exceptionally frosty or dry weather conditions.
Turf is to be laid with staggered joints, well butted together, and in firm contact with the soil working from planks positioned on turves already laid. At no time should freshly laid turf be walked on without the use of boards.
The turf shall be watered immediately on completion. The landscape contractor shall allow for provision of all equipment to complete this initial watering, using water supply point as directed on site.
Any unweeded shall be made good by filling the turf and adjusting the levels. Should blowlage occur, the topsoil shall be brushed into the joints.
Where trees are planted in turfed areas a 700mm diameter circle around each tree is to be kept clear of turf.

5.4 Seeding Preparation
The area to be seeded shall be cultivated to a minimum depth of 150mm removing all weeds, debris and stones over 25mm diameter which should be placed in waste skips or as directed by the site manager. The surface shall be sealed to smooth flowing contours with a fine 100, incorporating pre-turf fertilizer at 50g/m² unless otherwise stated and work into top 100mm during final subsoiling.
5.5 Seeding
All Grass seed shall be sown in March / April or September during calm weather conditions and not when the ground is frost bound or waterlogged. Seed shall be sown in two equal sowings in traverse directions at 50g/m² total unless otherwise stated. After sowing the contractor shall gently rake the seed into intimate contact with the soil.
5.6 Wildflower Seeding
All wildflower seed mixes are to be from a certified source with local provenance seed stock. Ground preparation to be as supplier's specification/guidance. Sowing applications may vary but are likely to be carried out in early spring or late autumn.
6 MAINTENANCE
The landscape contractor shall maintain all new private landscape areas for a period of 12 months following practical completion to ensure satisfactory completion. All stock deemed to be dead, dying or diseased within the 12 months defects period shall be replaced by the contractor at own cost.
The contractor should factor in 12 months of repeat visits, sufficient for the establishment and aftercare of all planting. None private areas can be identified for each site.
Private site landscaping will be handed over to the householders and when each house is occupied, the site will be responsible for watering until handover.

6.1 Weed Clearance
All planting areas are to be kept weed free by hand weeding unless otherwise specified. Providing adequate mulch, as specified, should also this. Mulch should also be topped up as required.
6.2 Litter Clearance
All areas are to be kept litter free.
6.3 Weeding
Watering to planted areas is to be undertaken as necessary to ensure plants become established. All trees and shrubs are to be watered thoroughly, to full ground capacity, immediately after planting and before the application of mulch. The landscape contractor shall allow for provision of all equipment to complete this initial watering, using water supply point as directed on site.
Each tree is to receive at least 30 gallons when watered.
During maintenance visits, watering should take place as required. Weeding visits should be factored in within the 12 months defects period, especially during times of prolonged dry weather.

6.4 Checking Ties
All tree ties and stakes are to be checked, adjusted (if too loose, too tight or if chaffing is occurring) and replaced if damaged or missing. Any broken stakes are to be replaced.
6.5 Formative Pruning
Any damaged shoots/branches are to be pruned back to healthy wood. Plants are to be pruned in accordance with good horticultural practice to maintain healthy well-shaped specimens. Shrubs grown for their coloured stems, such as Cornus, are to be cut back each spring to encourage new growth.
6.6 Turfed and Seeded Areas
When newly turfed & seeded areas reach 50mm they should be lightly rolled and cut to a height of 60mm. All arising's shall be removed. Any bare patches shall be made good so this time. Lawn areas should then be cut at appropriate intervals during the growing season to maintain a 40mm high sward. Watering, weeding and repair of all erosion and settlement with re-seeding or turfing shall be undertaken as required to establish a uniform and healthy sward of grass.

PLANTING SCHEDULE

- All areas

NON-NATIVE STREET TREES - Extra Heavy Standard

Number	Abbreviation Species	Girth	Height	Pot Size	Density Specification
4	ACEPLDR	Acer platanoides 'Drummondii'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
7	BETULT	Betula utilis 'jacquemontii'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
20	CARBETFF	Carpinus betulus 'Francis Fontaine'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
3	LIRTU	Liriodendron tulipifera	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
2	MALVEY	Malus 'Eve's apple'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
1	MALGOH	Malus 'Golden Hornet'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
9	PRUSAG	Prunus 'Baccata 'Street Parade'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
20	PRUSNG	Prunus 'Snow Goose'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
2	PRUSJU	Prunus x subhirtella 'Autumnalis'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
12	PYRACH	Pyrus 'Chantrelle'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
1	SORLU	Sorbus aria 'Lutescens'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm
1	TILCOGR	Tilia cordata 'Greenspire'	14-16cm	400-450cm	45-85L Extra Heavy Standard; 5 brks; C: Clear Stem 175-200cm

Total : 90

NATIVE POS TREES - Extra Heavy Standard

Number	Abbreviation Species	Girth	Height	Specification
10	BETPE	Betula pendula	14-16cm	400-450cm Extra Heavy Standard; 5 brks; 3x: RB: Clear Stem 175-200cm
4	CARBET	Carpinus betulus	14-16cm	400-450cm Extra Heavy Standard; 5 brks; 3x: RB: Clear Stem 175-200cm
4	FAGSY	Fagus sylvatica	14-16cm	400-450cm Extra Heavy Standard; 5 brks; 3x: RB: Clear Stem 175-200cm
4	PRUAV	Prunus avium	14-16cm	400-450cm Extra Heavy Standard; 5 brks; 3x: RB: Clear Stem 175-200cm
4	QUERO	Quercus robur	14-16cm	400-450cm Extra Heavy Standard; 5 brks; 3x: RB: Clear Stem 175-200cm
2	SALCAP	Salix caprea	14-16cm	400-450cm Extra Heavy Standard; 5 brks; 3x: RB: Clear Stem 175-200cm
8	SORAR	Sorbus aria	14-16cm	400-450cm Extra Heavy Standard; 5 brks; 3x: RB: Clear Stem 175-200cm
5	TILCO	Tilia cordata	14-16cm	400-450cm Extra Heavy Standard; 5 brks; 3x: RB: Clear Stem 175-200cm

Total : 43

NON-NATIVE SPECIMENS

Number	Abbreviation Species	Height	Diameter	Pot Size	Density Specification
3	BUDDA	Buddleja davidii	40-60cm	3L	Branched; 4 brks; C
3	PHYFL	Phyllostachys flexuosus	150-200cm	15L	Several Shoots; 10 brks; C

Total : 6

NATIVE ORNAMENTAL HEDGES - planted 5/1m

Number	Abbreviation Species	Height	Diameter	Pot Size	Density Specification
1505	CARBET	Carpinus betulus	80-100cm	3-7.5L	5/m ² 1+1: Transplant - seed raised; Branched; 5 Brks; C
1095	ILEAJUT	Ilex aquifolium 'J. C. van Tol'	40-60cm	5-7.5L	5/m ² Leader with Lateralis; C
2485	LIGVU	Ligustrum vulgare	60-80cm	3L	5/m ² Branched; 4 brks; C

Total : 5085

NON-NATIVE ORNAMENTAL SHRUBS

Number	Abbreviation Species	Height	Diameter	Pot Size	Density Specification	
55	ABEGRFM	Abelia x grandiflora 'Francis Mason'	40-60cm	10L	2/m ² Bushy; 5 brks; C	
85	AUCJAGR	Aucuba japonica 'Crotanifolia'	40-60cm	10L	2/m ² Bushy; 4 brks; C	
39	BRASU	Brachyglottis 'Sunshine'	40-60cm	5-7.5L	2.5/m ² Branched; 6 brks; C	
74	CHOAP	Choisya 'Aztec Pearl'	40-60cm	7.5L	2/m ² Bushy; 6 brks; C	
127	CHOTE	Choisya ternata	40-60cm	10L	2/m ² Bushy; 7 brks; C	
61	CHOTES	Choisya ternata 'Sundance'	40-60cm	10L	2/m ² Bushy; 7 brks; C	
23	CISCO	Cistus x corbanensis	40-60cm	5-7.5L	3/m ² Bushy; 6 brks; C	
51	ELAEELI	Elaeagnus x ebbingei 'Limelight'	40-60cm	10L	2/m ² Branched; 4 brks; C	
179	EUOFOEG	Euomyia fortunei 'Emerald Gaiety'	25-30cm	30-40cm	5-7.5L	3.5/m ² Branched; 4 brks; C
102	EUGADA	Elaeagnus x ebbingei 'Goldflake'	40-60cm	10L	2/m ² Bushy; 6 brks; C	
18	HEBGO	Hebe 'Great Orme'	40-60cm	10L	2/m ² Bushy; 7 brks; C	
61	HEBMAR	Hebe 'Marjorie'	30-40cm	5-7.5L	5/m ² Bushy; 7 brks; C	
99	HEBWW	Hebe 'Mrs Winder'	40-60cm	5-7.5L	5/m ² Bushy; 7 brks; C	
45	HEBRA	Hebe rakaiensis	40-60cm	20-30cm	5-7.5L	3/m ² Bushy; 7 brks; C
96	HYPPUC	Hypericum 'Hidcote'	40-60cm	7.5L	2.5/m ² Bushy; 7 brks; C	
57	LONNIBG	Lonicera nitida 'Baggesen's Gold'	40-60cm	10L	2/m ² Bushy; 7 brks; C	
57	LONNIMG	Lonicera nitida 'Maigrun'	40-60cm	40-60cm	10L	2/m ² Bushy; 10 brks; C
22	MAHAQ	Malva aquatica	40-60cm	10L	2/m ² Branched; 4 brks; C	
129	OLEHA	Olearia x hasati	40-60cm	10L	2/m ² Bushy; 9 brks; C	
93	OSMBU	Osmunda x burkwoodii	60-80cm	10L	2/m ² Bushy; 7 brks; C	
93	PIEFLS	Pieris 'Flaming Silver'	30-40cm	5L	3/m ² Bushy; 5 brks; C	
127	POTFRRAE	Potentilla fruticosa 'Red Ace'	25-30cm	30-40cm	5-7.5L	2/m ² Bushy; 5 brks; C
88	PRULAQ	Prunus laurocerasus 'Oto Lyuken'	40-60cm	10L	2/m ² Bushy; 6 brks; C	
80	ROSOFF	Rosmarinus officinalis	40-60cm	5L	3/m ² Bushy; 5 brks; C	
45	SARCO	Sarcocolla confusa	40-60cm	10L	2/m ² Bushy; 8 brks; C	
127	SPIJAGO	Spiraea japonica 'Goldflame'	40-60cm	10L	2/m ² Bushy; 9 brks; C	
106	VIDBA	Viburnum davidii	30-40cm	5-7.5L	3/m ² Bushy; 4 brks; C	
50	VISTEVP	Viburnum tinus 'Eve Price'	40-60cm	10L	2/m ² Bushy; 7 brks; C	
127	VIBBU	Viburnum x burkwoodii	80-80cm	10L	2/m ² Branched; 5 brks; C	

Total : 2229

NON-NATIVE ORNAMENTAL GRASSES

Number	Abbreviation Species	Pot Size	Density Specification
172	CARMOID	Carex mormorii 'Ice Dance'	2L 6/m ² Full Pot C

Total : 72

NATIVE HEDGE MIX - Individual species to be planted together in groups of 3-7

Number	Abbreviation Species	Height	Pot Size	Density Specification
18	ACECAM	Acer campestre	6/1m	1+1: Transplant - seed raised; B
398	CORSA	Cornus sanguinea	60-80cm	6/1m 1+1: Transplant - seed raised; B
201	CORAV	Corylus avellana	60-80cm	6/1m 1+2: Transplant - seed raised; Branched; 3 brks; B
201	PRUSP	Prunus spinosa	60-80cm	6/1m 1+1: Transplant - seed raised; Branched; 2 brks; B
102	SAMNI	Sambucus nigra	60-80cm	6/1m 1+1: Transplant - seed raised; Branched; 2 brks; B

Total : 1004

NATIVE SCRUB MIX - Individual species to be planted together in groups of 3-7

Number	Abbreviation Species	Height	Pot Size	Density Specification
570	CORSA	Cornus sanguinea	60-80cm	6/1m 1+1: Transplant - seed raised; Branched; 3 brks; B
148	ILEAQ	Ilex aquifolium	60-80cm	3L 1/m ² Leader with Lateralis; C
850	PRUSP	Prunus spinosa	40-60cm	1/m ² 1+1: Transplant - seed raised; Branched; 2 brks; B
148	ROSCA	Rosa canina	60-80cm	1/m ² 1+1: Transplant - seed raised; Branched; 3 brks; B
570	SAMNI	Sambucus nigra	60-80cm	1/m ² 1+1: Transplant - seed raised; Branched; 3 brks; B
570	VIBOP	Viburnum opulus	60-80cm	1/m ² 1+2: Transplant - seed raised; Branched; 3 brks; B

Total : 2882

NON-NATIVE SENSORY MIX - Individual species to be planted together in groups of 3-7

Number	Abbreviation Species	Height	Pot Size	Density Specification
18	BERCO	Bergenia cordifolia	3L	5/m ² Full Pot; C
35	BRIMA	Britia maxima	2L	5/m ² Full Pot; C
18	HEICHR	Heuchera 'Choccolate Ruffles'	2L	5/m ² Full Pot; C
18	HY			