

Notes  
 All dimensions must be checked on site and not scaled from this drawing, any discrepancies to be reported.  
 The Contractor shall make a survey of the site and shall be responsible for obtaining all dimensions and levels necessary for the proper construction of works as indicated.  
 Please note that this drawing is COPYRIGHT and shall not be used or copied for purposes unauthorised by Innovation Architecture Ltd.  
 Ordnance Survey - 100059706

Client  
**BEERCOCK**

Job Title  
**PROPOSED REPLACEMENT DWELLING**  
**26 STATION ROAD, SOUTH CAVE, HU15 2AA**


Drawing Title  
**PROPOSED DRAINAGE**

**Innovation architecture**

**ia**

Innovation Architecture Ltd  
 110 Beverley Road, Hessle, East Yorkshire, HU13 9BU  
 t: 01482 650215  
 e: info@ia1.co.uk  
 w: www.ia1.co.uk

Revisions	Date	Description	DR	CH



Status  
**CONDITION RELEASE**

Scale  
 A1 - 1:100

Date  
 27-02-2024

Drawn By  
 RL

Checked  
 Approved

Drawing No.  
**816/PL-07**

Rev



**Proposed Drainage Plan - 1:100@A1**

SCALE OF METRES - 1:100

**PT1 & PT2**  
 - Location of percolation tests

Following excavation of the test holes, they were filled with water with a view to the test being undertaken once drained. The initial fill however had not drained away 24 hours later. As such it was considered that soakaways would not be feasible.

- New Foul drainage connecting into existing on site foul drainage.

- New surface water drainage to discharge into surface water attenuation tank and then into existing drainage system

**KEY**

SWG = Surface water trapped roddable gully  
 SVP = Soil and vent pipe  
 BIG = Back inlet gully  
 SP = 100mm soil pipe with stub stack & air admittance valve  
 PPIC = Polypropylene inspection chamber  
 RE = Rodding eye  
 TD = Threshold drain  
 CD = Channel drain