



15m x 32mm PE LP Service,
3.5m x 1" ST & 0.5m x 3/4" ST Riser.

Valve.

Meter location internally
within first floor flat.

Connection Point.
E 349182, N 312479.
180mm PE LP Main.

QUOTATION PLAN

QUOTATION REFERENCE - 130033486
SALES ORDER REFERENCE - 0033298651

We will connect onto the existing 180mm PE LP Main and lay 1 x new gas service including steel riser by 15m x 32mm PE, 3.5m x 1" ST & 0.5m x 3/4" ST.

Service to terminate internally within first floor flat with a 3/4" ECV, isolation valve to be installed as per plan.

Cadent to complete all excavations works.

Listed Property - Customer to obtain relevant listed building consent from local planning officer or English Heritage as appearance will be affected by steel riser.

Conservation Area – Customer to obtain relevant consent from local planning officer as appearance will be affected by steel riser.

LP SYSTEM.

SCALE: 1:300 @ A4
USER ID: grace.buften
DATE: 14-Feb-2024 11:17:45
INTERNAL USE ONLY
OS Ref: 349203, 312481
CENTRE: <Centre>

L/P GAS MAIN
M/P GAS MAIN
I/P GAS MAIN
H/P GAS MAIN
N/H/P GAS MAIN
PROPOSED PIPE - LP
PROPOSED PIPE - MP
PROPOSED PIPE - IP
ABANDON - LP
ABANDON - MP
Out Of Standard Service

SCHEME: <NG GDFO Scheme Name>
DESIGN: <NG GDFO Design Number>
REVISION: <NG GDFO Revision>

This plan shows those pipes owned by Cadent in its role as a Licensed Gas Transporter (GT). Gas pipes owned by other GTs, or otherwise privately owned, may be present in this area. Information with regard to such pipes should be obtained from the relevant owners. The information shown on this plans given without warranty, the accuracy thereof cannot be guaranteed. Service pipes, valves, syphons, stub connections, etc., are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Cadent Gas Limited or their agents, servants or contractors for any error or omission. Safe digging practices, in accordance with HS(G)47, must be used to verify and establish the actual position of mains, pipes, services and any other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that this information is provided to all persons (either direct labour or contractors) working for you on or near gas apparatus. The information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

16
FLAT
HIGH STREET
SHREWSBURY
SY1 1SP

Cadent

This plan is reproduced from or based on the OS map by Cadent Gas Limited, with the sanction of the controller of HM Stationery Office. Crown Copyright Reserved..

