

## Project name

**Peter Symonds College Music School**

As designed

Date: Tue Oct 24 15:48:39 2023

## Administrative information

## Building Details

Address: Owens Road, Winchester, SO22 6RX

## Certifier details

Name: Ridge &amp; Partners LLP

Telephone number: Phone

Address: 1 Royal Court, Kings Worthy, Winchester, SO23 7TW

## Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m<sup>2</sup>]: 616.06The CO<sub>2</sub> emission and primary energy rates of the building must not exceed the targets

Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> annum	4.3
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> annum	3.54
Target primary energy rate (TPER), kWh <sub>PE</sub> /m <sup>2</sup> annum	45.59
Building primary energy rate (BPER), kWh <sub>PE</sub> /m <sup>2</sup> annum	37.1
Do the building's emission and primary energy rates exceed the targets?	BER =< TER   BPER =< TPER

## The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U <sub>a-Limit</sub>	U <sub>a-Calc</sub>	U <sub>i-Calc</sub>	First surface with maximum value
Walls*	0.26	0.15	0.15	GF000001:Surf[2]
Floors	0.18	0.13	0.13	GF000001:Surf[0]
Pitched roofs	0.16	-	-	No pitched roofs in building
Flat roofs	0.18	0.12	0.12	GF00000F:Surf[0]
Windows** and roof windows	1.6	1.3	1.3	GF000001:Surf[1]
Rooflights***	2.2	-	-	No roof lights in building
Personnel doors <sup>^</sup>	1.6	-	-	No personnel doors in building
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building

U<sub>a-Limit</sub> = Limiting area-weighted average U-values [W/(m<sup>2</sup>K)]U<sub>i-Calc</sub> = Calculated maximum individual element U-values [W/(m<sup>2</sup>K)]U<sub>a-Calc</sub> = Calculated area-weighted average U-values [W/(m<sup>2</sup>K)]

\* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

\*\* Display windows and similar glazing are excluded from the U-value check. \*\*\* Values for rooflights refer to the horizontal position.

<sup>^</sup> For fire doors, limiting U-value is 1.8 W/m<sup>2</sup>K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	8	4

## Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	>0.95

### 1- VRF Heating & Cooling System

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	3.8	6	0	-	0.8
<b>Standard value</b>	2.5*	5	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					NO

\* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

### 2- Electric Panel Heater System

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	1	-	0	-	0.8
<b>Standard value</b>	N/A	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					NO

### 1- Domestic Hot Water

	Water heating efficiency	Storage loss factor [kWh/litre per day]
<b>This building</b>	0.81	-
<b>Standard value</b>	1	N/A

### Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

Zone name	ID of system type	SFP [W/(l/s)]									HR efficiency	
		A	B	C	D	E	F	G	H	I	Zone	Standard
	<b>Standard value</b>	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1		
GF - Classrooms		-	-	-	1.7	-	-	-	-	-	-	N/A
GF - Office Spaces		-	-	-	1.7	-	-	-	-	-	-	N/A
GF - Band Rehearsal		-	-	-	1.7	-	-	-	-	-	-	N/A
GF - Chamber		-	-	-	1.7	-	-	-	-	-	-	N/A
GF - Stores & WC		-	-	-	1.3	-	-	-	-	-	-	N/A
GF - Recital		-	-	-	1.4	-	-	-	-	-	-	N/A
FF - Classroom		-	-	-	1.7	-	-	-	-	-	-	N/A
FF - Chamber		-	-	-	1.7	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency		
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
	Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1		
FF - WCs		-	-	-	1.3	-	-	-	-	-	-	N/A
FF - Stores & WCs		-	-	-	1.3	-	-	-	-	-	-	N/A
FF - Tech & Control		-	-	-	1.4	-	-	-	-	-	-	N/A

General lighting and display lighting		General luminaire		Display light source	
Zone name		Efficacy [lm/W]		Efficacy [lm/W]	Power density [W/m <sup>2</sup> ]
	Standard value	95		80	0.3
GF - Classrooms		90		-	-
GF - Office Spaces		90		-	-
GF - Band Rehearsal		90		-	-
GF - Chamber		90		-	-
GF - Plant Room		90		-	-
GF - Stores & WC		100		-	-
GF - Circulation & Lobbys		100		-	-
GF - Recital		90		-	-
FF - Classroom		90		-	-
FF - Chamber		90		-	-
FF - WCs		100		-	-
FF - Stores & WCs		100		-	-
FF - Tech & Control		90		-	-
FF - Server		90		-	-
FF - Circulation & Lobbys		100		-	-
FF - Elec Cupd		90		-	-

**The spaces in the building should have appropriate passive control measures to limit solar gains in summer**

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
GF - Classrooms	NO (-25.7%)	NO
GF - Office Spaces	NO (-46.7%)	NO
GF - Band Rehearsal	NO (-45.8%)	NO
GF - Chamber	NO (-73.4%)	NO
GF - Recital	NO (-30.2%)	NO
FF - Classroom	NO (-38.6%)	NO
FF - Chamber	NO (-88.2%)	NO
FF - Tech & Control	NO (-84.7%)	NO

**Regulation 25A: Consideration of high efficiency alternative energy systems**

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Floor area [m <sup>2</sup> ]	1240.7	1240.7
External area [m <sup>2</sup> ]	2408.8	2408.8
Weather	SOU	SOU
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	4	3
Average conductance [W/K]	536.94	773.27
Average U-value [W/m <sup>2</sup> K]	0.22	0.32
Alpha value* [%]	24.81	10

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

Retail/Financial and Professional Services  
 Restaurants and Cafes/Drinking Establishments/Takeaways  
 Offices and Workshop Businesses  
 General Industrial and Special Industrial Groups  
 Storage or Distribution  
 Hotels  
 Residential Institutions: Hospitals and Care Homes  
 Residential Institutions: Residential Schools

**100 Residential Institutions: Universities and Colleges**

Secure Residential Institutions  
 Residential Spaces  
 Non-residential Institutions: Community/Day Centre  
 Non-residential Institutions: Libraries, Museums, and Galleries  
 Non-residential Institutions: Education  
 Non-residential Institutions: Primary Health Care Building  
 Non-residential Institutions: Crown and County Courts  
 General Assembly and Leisure, Night Clubs, and Theatres  
 Others: Passenger Terminals  
 Others: Emergency Services  
 Others: Miscellaneous 24hr Activities  
 Others: Car Parks 24 hrs  
 Others: Stand Alone Utility Block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	5.02	10.53
Cooling	2.39	2.79
Auxiliary	8.31	1.94
Lighting	8.31	8.4
Hot water	20.95	12.72
Equipment*	25.48	25.48
<b>TOTAL**</b>	<b>44.97</b>	<b>36.38</b>

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	19.9	5.81
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>19.9</i>	<i>5.81</i>

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	66.99	112.77
Primary energy [kWh <sub>PE</sub> /m <sup>2</sup> ]	37.1	45.59
Total emissions [kg/m <sup>2</sup> ]	3.54	4.3

## HVAC Systems Performance

System Type	Heat dem MJ/m <sup>2</sup>	Cool dem MJ/m <sup>2</sup>	Heat con kWh/m <sup>2</sup>	Cool con kWh/m <sup>2</sup>	Aux con kWh/m <sup>2</sup>	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
<b>[ST] Split or multi-split system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
<b>Actual</b>	30.6	55	2.4	3.6	11.5	3.54	4.26	3.8	6
<b>Notional</b>	39.1	69.5	3.9	4.2	2.3	2.78	4.63	----	----
<b>[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity</b>									
<b>Actual</b>	31.9	0	11.1	0	2	0.8	0	1	0
<b>Notional</b>	130.4	0	25.7	0	1.3	1.41	0	----	----
<b>[ST] No Heating or Cooling</b>									
<b>Actual</b>	0	0	0	0	0	0	0	0	0
<b>Notional</b>	0	0	0	0	0	0	0	----	----

### Key to terms

Heat dem [MJ/m <sup>2</sup> ]	= Heating energy demand
Cool dem [MJ/m <sup>2</sup> ]	= Cooling energy demand
Heat con [kWh/m <sup>2</sup> ]	= Heating energy consumption
Cool con [kWh/m <sup>2</sup> ]	= Cooling energy consumption
Aux con [kWh/m <sup>2</sup> ]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type