V3 Drawing Register									
Sheet Number	Sheet Name	Rev	Revision Date						
1045-300	Cover Page & Design Risk Register	Α	Feb 2024						
1045-310	Foundation & Sub-Floor Plans	Α	Feb 2024						
1045-320	Floor Plans	Α	Feb 2024						
1045-330	MEP Plans	Α	Feb 2024						
1045-340	Elevations	Α	Feb 2024						
1045-350	Sections	Α	Feb 2024						



Design Risk Register						
Element	Comments					
Lifting Operations	To avoid injury when handling heavy components, specialist handling equipment is to be utilised for the positioning of heavy objects/materials. Large glazing to be installed with specialist lifting equipment by trained personnel. Protection barriers to be provided to prevent mechanical damage following installation.					
Craneage	Crane supplier to be satisfied of adequate support to outriggers, correct lifting positions to be established to avoid slippage of sheet materials during lifting and placement. Sub-contractors and suppliers to 'design in' lifting eyes and identify weights of heavy items at drawing approval stage. All RAMS to be obtained and approved prior to any lifting operations being carried out.					
Ground Floor Construction	Mechanical Lifting equipment to be utilised to position pre-cast concrete floor planks. Manual handling assessment to be carried out.					
Working at Height	Install temporary scaffolding barrier to exposed edges of upper floors including toe boards throughout the build period. Provide scaffolding to all areas requiring placement of materials and finishing to all areas above ground level. Scaffolding to be positioned to avoid the need to overreach causing strain injury when placing materials. Protect areas below high level working from falling debris. Ensure space required for crane is achievable and suitable hard standing is provided. Ensure maximum fall height when fixing trusses into position is 2 metres by utilising appropriate safety measures and equipment.					
Stairs	To prevent falls provide temporary guarding and edge protection to open well areas and keep clear during construction, eliminating the possibility of trip hazards. Stairs to be erected as early as possible during the construction process to provide vertical circulation and means of escape in case of fire.					
Masonry Construction	When working at height mechanical lifting measures required to lift brick and block packs into position to reduce manual handling.					
Lintels	Manual Handling Assessments to be carried out for all lintels, light craneage to be utilised for lintels considered too heavy for manual handling.					
Structural Steelwork	Mechanical lifting measures required to reduce manual handling. Ensure required space for crane is achievable and suitable hard standing is provided.					
Windows / Structural Openings	Any structural apertures below 800mm to be fitted with temporary guarding to prevent falls. Any structural apertures below 800mm and extending to floor level to be fitted with temporary guarding and edge protection to prevent falls. Mechanical lifting measures and frame and glazing fitted separately to be considered for installation of large windows and combination door & window frames. Window manufacturer to be consulted regarding best means of installation.					
Window Cleaning & Maintanence	'Easy Clean' hinges are not an option due to the top hung design to a majority of the windows, as such windows should be cleaned from ground level using a telescopic 'reach & wash' system. All windows used to be Aluminium or UPVC frames to eliminate the need for future decoration.					
Roof Construction	Ensure space required for crane is achievable and suitable hard standing is provided. Ensure maximum fall height when fixing trusses into position is 2 metres by utilising appropriate safety measures and equipment.					

1045-V3-X (As)

General updates as detailed within issue email dated 02.02.2024	Feb 2024
Construction Issue	July 2023
Description	Date

NORTHSTONE

Peel L&P Salford M50 2TG

CONSTRUCTION

PROJECT

Gen2 House Type Portfolio

DRAWING NAME

1045-V3-X (As) Cover Page & Design Risk Register

DRAWING NUMBER		DESIGNATION	DRAWN BY
1045-300		X	Design
DATE	SCALE (@ A3	3)	REV
June 2023			Α

lotes:

- All dimensions to structure unless otherwise stated.
- Drawing to be read in conjunction with Northstone specification & all other project related design information and drawings.
- other project related design information and drawings.
 Any discrepancies to be reported to Northstone Technical prior to commencement of works.
- All materials and workmanship to be in accordance with current NHBC Technical Standards and Building Regulations.

DO NOT SCALE FROM THIS DRAWING. ALWAYS PRINT IN COLOUR.

FOUNDATION & SUB-FLOOR LEGEND Brick Face External Wall OUTSIDE - 102.5mm clay facing brickwork as site specific materials plan - 125mm clear cavity - 100mm block as specification INSIDE 100mm Sleeper Wall - 100mm concrete block as engineers details 215mm Sleeper Wall - 100mm concrete block as engineers details - 15mm cavity fully filled with mortar - 100mm concrete block as engineers details Trench Block - 350mm concrete trench block as engineers details Services & Ventilation OSVP 110mm Soil and Vent Pipe ORWP Rainwater pipe as specification OGULLY Sealed floor gully for level access shower → ^{Water} Water Entry Point Data Lead In _____ Data Entry Point E ── Electric Entry Point G — Gas Entry Point Sub-Floor Telescopic Vent Floor Finish & Span Extent of Floor Screed Span of Ground Floor Construction 1. Refer to engineers details and specification for all block


strengths. Key to be read in conjunction with construction specification. Expansion and movement joints, bed reinforcement and wind posts to engineers details.

Always refer to site investigation report and engineers details for any gas membrane requirements.


Sub-Floor Void Ventilation Schedule

Building Building Ventilation Minimum Number of Vents Required of Vents Required Vents Provided

40.01 m² | 26.65 | 39970 mm² | 8 * Based on 500mm2/m2 of Floor Area




310. Foundation Plan





398. Golden Brick Elevation


1:100



311. Sub-Floor Setting Out








340. Second Floor Setting Out 1:50


External Door Schedule													
Floor	Door Ref	Width	Height	Door Width	Reveal Depth	U-Value (Door / Sidelight)	Toughened Glass	Glazing Specification	MF Width	Sidelight MF Width	MF Height	Area of Glazing	Notes
Ground Floor FFL/DPC	ED01	1360	2110	1000	50	0.45W/m²K / 0.55W/m²K	Yes	Tripple Glazed	984	344	2061	0.451 m ²	
Ground Floor FFL/DPC	ED02	2260	2110	1000	70	0.90W/m²K / 0.55W/m²K	Yes	Tripple Glazed	984	1244	2061	3.508 m ²	Trickle Vent in Sidelight
First Floor FFL	ED03	2260	1960	1000	70	0.90W/m²K / 0.55W/m²K	Yes	Tripple Glazed	984	1244	1911	3.233 m²	Trickle Vent in Sidelight
Third Floor FFL	ED04	2260	1960	1000	70	0.90W/m²K / 0.55W/m²K	Yes	Tripple Glazed	984	1244	1911	3.233 m ²	

V3 Window Schedule												
Floor	Window Ref	Width	Height	Toughened Glass	U-Value	Reveal Depth	Obscure Glazing	Escape Window	Trickle Vents	Glazing Specification	Area of Glazing	Notes
First Floor FFL	W01	1360	2110	Yes	0.55W/m²K	70	No	Yes	Yes	Tripple Glazed	2.096 m ²	
First Floor FFL	W05	685	2110	Yes	0.55W/m²K	70	No	Yes	Yes	Tripple Glazed	1.021 m²	
Second Floor FFL	W03	2260	2110	Yes	0.55W/m²K	70	No	Yes	Yes	Tripple Glazed	3.882 m²	
Second Floor FFL	W02	1360	2110	Yes	0.55W/m²K	70	No	Yes	Yes	Tripple Glazed	2.096 m²	
Second Floor FFL	W06	685	2110	Yes	0.55W/m²K	70	No	Yes	Yes	Tripple Glazed	1.021 m²	
Third Floor FFL	W04	1360	2110	Yes	0.55W/m²K	70	No	No	Yes	Tripple Glazed	2.096 m ²	

Internal Door Schedule										
Floor	Door Ref	From Room	To Room	Structural Width	Structural Height	Leaf Width	Casing Depth	Fire Rating	Self Closer	Notes
Ground Floor FFL/DPC	D01	Living Room	Hall	910	2326	838	96	FD30	No	
Ground Floor FFL/DPC	D02	Hall	WC	910	2326	838	96	Not Fire Rated	No	
First Floor FFL	D03	Bedroom 1	Landing	910	2017	838	96	FD30	No	
First Floor FFL	D04	En-Suite	Bedroom 1	910	2017	838	96	Not Fire Rated	No	
First Floor FFL	D05	Dressing	Bedroom 1	910	2017	838	96	Not Fire Rated	No	
Second Floor FFL	D06	Landing	Store	910	2017	838	96	FD30	No	
Second Floor FFL	D07	Bedroom 2	Landing	910	2017	838	96	FD30	No	
Second Floor FFL	D08	En-Suite	Bedroom 2	910	2017	838	96	Not Fire Rated	No	





330. First Floor Setting Out



350. Third Floor Setting Out

1:50





WALL TYPE LEGEND Brick Face External Wall - 102.5mm clay facing brickwork to site specific materials plan

- 125mm cavity fully filled with insulation as specification
- 100mm block as specification - 100mm block as specification

INSIDE - 12.5mm plasterboard on 10mm adhesive dabs, all joints taped and filled before wet plaster skim finish

NON LOADBEARING STUD PARTITIONS General Partition

- 63x38mm C16 studwork at max 600mm centres with suitable noggins - Pattress between stud with 12mm Ply where required for MEP fixtures and fittings

- 1no. layer of 12.5mm plasterboard mechanically fixed to stud both sides of wall with all joints taped and filled before wet plaster skim finish Patressed Partition Wall

- 63x38mm C16 studwork at max 600mm centres with suitable noggins

- 12mm ply mechanically fixed to stud on load-bearing side of wall, (Kitchens etc.) - 1no. layer of 12.5mm plasterboard mechanically fixed to stud both sides of wall with all joints taped and filled before wet plaster skim finish

Acoustic & Fire Rated Partition

30 Min
- 63x38mm C16 studwork at max 600mm centres

with suitable noggins - Voids between studwork fully filled with 60mm Rockwool Flexi or similar approved mineral wool. - Pattress between stud with 12mm Ply where required for MEP fixtures and fittings - 1no. layer of 12.5mm plasterboard mechanically fixed to stud both sides of wall with all joints taped and filled before wet plaster skim finish - Achieves R_w40dB in accordance with AD:E

- Achieves REI 30 fire resistance in accordance with British Gypsum White Book

Wet-Room Partition (WC / Bathroom / En-suite)

- 63x38mm C16 studwork at max 400mm centres with suitable noggins

- Pattress between stud with 12mm Ply where required for MEP fixtures and fittings

- 12.5mm moisture resistant plasterboard mechanically fixed to stud onwet-room side of wall with all joints taped and filled prepared for - 12.5mm standard plasterboard mechanically fixed to stud on **dry-room side** of wall where required with all joints taped and filled before wet

Framing Wall

- 63x38mm C16 studwork wide face out at max 400 400 400 400 400 400 with suitable noggins

- 1no. layer of 12.5mm plasterboard mechanically fixed to stud on room side of wall with all joints taped and filled before wet plaster skim finish

Anchored/Buttress Stud Partition

Refer to structural engineers details and , 400 , 400 , Northstone construction details.

Centres Centres

Buttress Studs and Windposts not required on party walls.

Insulation Between Studs

As Above Wall Types
As Abo - Achieves R_w40dB in accordance with AD:E - Achieves REI 30 fire resistance in accordance with British Gypsum White Book


Refer to engineers details and specification for all block strengths.
 Key to be read in conjunction with construction specification.
 Expansion and movement joints, bed reinforcement and wind posts to

engineers details. 4. All dimensions are to structure unless otherwise noted.

FLOORING LEGEND

LVT Flooring

- Vinyl flooring applied as Northstone finishes specification and relevant customer options



NORTHSTONE

Peel L&P Salford M50 2TG

CONSTRUCTION

Gen2 House Type Portfolio

DRAWING NAME 1045-V3-X (As)

Floor Plans DRAWING NUMBER DESIGNATION DRAWN BY 1045-320 Design

SCALE (@ A1)

June 2023 As indicated Notes:
All dimensions to structure unless otherwise stated.
Drawing to be read in conjunction with Northstone specification & all other project related design information and drawings.
Any discrepancies to be reported to Northstone Technical prior to

 commencement of works.
 All materials and workmanship to be in accordance with current NHBC Technical Standards and Building Regulations. DO NOT SCALE FROM THIS DRAWING. ALWAYS PRINT IN COLOUR.


Electrical Fixture Schedule Electrical Item External Wall Light External Wall Light Recessed spot light Consumer Unit M&E - Refer to Detail Double Socket Recessed spot light Single gang light switch - single way Triple gang light switch - two way Wondrwall thermostat Ceiling mounted fan CV2-GIP Kitchen gang plate with appliance Recessed spot light 13A Unwitched Fused Spur Ceiling mounted fan CV2-GIP Cooker Control Box Double Socket Double Socket with USB Kitchen gang plate with appliance names Pendant light Living Room 2-Way Data Module with CAT6 & TV 13A Switched Fused Spur Double gang light switch - two way Double Socket Internal Wall Light Wondrwall switch Smoke Detector Triple gang light switch - two way 2-Way Data Module with CAT6 & TV 13A Switched Fused Spur Double gang light switch - two way Double Socket Double Socket with USB Pendant light Single gang light switch - single way Single gang light switch - two way Recessed spot light Single gang light switch - single way Triple gang light switch - two way Wondrwall thermostat Store Internal Wall Light Bedroom 2 13A Switched Fused Spur Double Socket Double Socket with USB Single gang light switch - single way En-Suite Ceiling mounted fan CV2-GIP Recessed spot light

Ventilation Fixture So	chedule

Triple gang light switch - two way


 Ventilation Item
 Quant

 Single air brick for CV2.GIP fan
 4




325. Ground Floor MEP

1:50




345. Second Floor MEP

1:50




359. Roof Plan

1:50




335. First Floor MEP


1 : 50



355. Third Floor MEP1:50

or MEP___









ANCILLARY EQUIPMENT


▲ IP67 Rated Rotary Pole Isolator Switch
WB IP66 Rated External Whisper Box

Note: Air Source Heat Pump, (ASHP), and ancillary equipment shown indicatively. Refer to independent third party designs for exact details of ASHP System

SS Panasonic Smart Control Switch







All glazing in critical locations should:


a) If broken, will break safely.
b) Be sufficiently robust to resist breaking.

Schedules to be read in conjunction with all project specification documents, floor plans and elevations
Structural opening size includes any sidelights
Frame set back is taken from front face of brick Refer to manufactures information for detailed lintel schedules
All accessible windows and doors to be PAS24 tested to comply with Part Q of building regulations
All dimensions to be checked on site prior to manufacture

Escape from upper storey a maximum of 4.5m above ground level: ALL inner rooms where applicable and all first floor habitable rooms (excluding kitchens) to be provided with an escape window (or external door) which complies with Approved Document B1 Section 2 Paragraph 2.2.

Dwellings with one storey more than 4.5m above ground level: A protected stairway should be provided with minimum 30 minute fire resisting construction at all storey's to comply with Approved Document B1 Section 2 Paragraphs 2.5.


Unobstructed opening casement area to be at least 0.33M² and at least 450mm high and 450mm wide. Bottom of windows to be not more than 1100mm and not less than 800mm above the floor. Escape windows to have non lockable fasteners and hinged to achieve the minimum required opening.




EXTERNAL M&E HEIGHTS

361. LHS Elevation

1:50





A General updates as detailed within issue email dated 02.02.2024 - Construction Issue NORTHSTONE Peel L&P Salford M50 2TG CONSTRUCTION Gen2 House Type Portfolio DRAWING NAME 1045-V3-X (As) **Elevations** DRAWING NUMBER DESIGNATION DRAWN BY 1045-340 Design SCALE (@ A1) June 2023 As indicated Notes:
• All dimensions to structure unless otherwise stated.

Drawing to be read in conjunction with Northstone specification & all other project related design information and drawings.
 Any discrepancies to be reported to Northstone Technical prior to

commencement of works.

All materials and workmanship to be in accordance with current NHBC Technical Standards and Building Regulations. DO NOT SCALE FROM THIS DRAWING. ALWAYS PRINT IN COLOUR


MEMBRANE KEY


Damp Proof Course (DPC)

Damp Proof Membrane (DPM)

Roof Underlay

Breather Membrane





372. Section C-C
1:50

