

CERTIFICATE FOR PROPOSED FOUL WATER SUB-SURFACE SOAKAWAY

Two tests are normally required to demonstrate the suitability of the proposed drainage scheme:

1. A trial pit must be excavated to a depth of 1 metre below the proposed invert of the drain to establish whether or not the water table will interfere with the operation of the soakaway; and
2. A percolation test must be carried out to determine the area of the ground required.

Certificate

Applicant's name Mr A Craig
 (name of person applying for planning permission)
 Address Downiehills Farm Blackhills Peterhead AB42 3LB
 Site address Site adjacent to Lochhead Cottage Rora
 Date of test 15-3-17 Time 10.20
 Weather conditions Dry, sunny & windy

Trial Pit Test (see attached location plan and drainage report identifying test pit and all wells within 100 metres of test pit)

Depth of drain 0.5m.....m
 Depth of excavation 1.5m.....m
 Water table present ~~Yes~~ / No (delete)

Percolation Test

Time taken (means of three) 1200.....s
 Percolation value Vp 8.....s
 Number of persons 6
 Floor area of soakaway 25 sq.m......m²

I hereby certify that I have carried out the above tests in accordance with procedures specified in British Standard BS6297:1983, as amended by AMD6150 1990, and in conjunction with the full requirements set out within the Domestic Scottish Building Standards Technical Handbook (Environment Standard 3.9 Infiltration Systems), the result of which are tabulated above, and that the proposed drainage scheme detailed on the attached plans and report has been designed taking into account the recommendations mentioned standards.

Signed [Signature] Date 20-3-23
 Name/Company Philip Baxter, Arcus Design Ltd
 Address Mavisbank, Old Deer, Peterhead
AB42 5JT
 Qualification MCIAT