



SOIL DRAINAGE
 All drainage to comply with BS 6305 (RBD)
 Pipes are to be 110mm Omega upvc type bedded & surrounded by 100mm granular material.
 Pipes are to be laid at a minimum gradient of 1:80 & a max. gradient of 1:50.
 Inspection points up to 600 deep are to be of Omega 250 dia. polypropylene, up to 900 deep are to be 450 dia. & over 900 deep will be made of class I engineering brickwork with a cover of 1200x750.
 Drains passing through walls or foundations to be sleeved or have conc. lintels over.

CONSTRUCTIONAL NOTES

FOUNDATIONS
 600x300 trench fill footing to a min. depth of 1000.
 Foundation trenches adjacent to internal walls to be backfilled with compacted hardcore.
 Cavity construction up to DPC to be 2 skins of brickwork with weak mix concrete fill 1:1:6 to finished ground level.
 Excavations to be trimmed prior to placing concrete & checked by local Building Inspector.

DPC
 2000 gauge black polythene to be used for the horizontal DPC 150 min. above ground level.
 All vertical and horizontal cavity closures are to incorporate a 2000 gauge DPC to BS6019.

EXTERNAL DWARF WALLS
 External skin to be 100 coursed brickwork (no match) and 150 cavity with and total fill Pilkington Dri-Therm insulation fitted to their instructions with 100 Celcon Solar Block inner skin to give a U value of .18 W/M2K.
 Cavity to be formed using stainless vert-truss wall ties at 750 horizontal and 450 vertical centres 300 centres within 150 of vertical reveals.

GROUND FLOOR STRUCTURE
 1:2:4 concrete slab 100 thick with 50 screed finish on 1200 gauge polythene DPM linked to DPC in walls & on 100 consolidated & sand bladed hardcore, 100mm Kingspan Terraflor TF70 with 30mm upstand to the perimeter of the floor below floor slab to give a U value of .18 W/M2K.
 Primary protection of Radon gas must be implemented by rapping horizontal dpm in slab to horizontal dpc in walls including sumps.

ROOF
 Refer to Section for details

VENTILATION
 All habitable rooms to have window openings at least one twentieth of the rooms floor area and background ventilation of 6000mm squared by way of trickle vents.

STORMWATER DRAINAGE
 To tie existing storm system but if impractical then to a sump 5000 from dwelling a permission here must be done and results forwarded to building control department.

GLAZING
 Generally to BS6262 & 6206.
 All doors & windows below 1200 from Finished Floor level to have safety glass to BS6202 (R9).
 All external glazing to be double glazed with 16mm air gap & a low-E coating to give a U value of 1.8 W/m2K.

LINTELS
 All lintels to be by Keystone Ltd. & to BS 5477 pt. 2
 All lintels to have 150 and bearing & fitted strictly to manufacturers instructions

ALL MEASUREMENTS, ROOF PITCHES ETC. TO BE CHECKED ON SITE & RUTLAND PLANNING INFORMED OF ANY DISCREPANCIES.

Energy efficient light fittings to be fitted
 Switches and sockets to be sited between 450 & 1200 from ffl
 Electricals by a Part-P qualified electrician, certificate must be handed to building control on completion
 Heating details to building control before installation.

Proposed Ground Floor Plan 1:50