






PROPOSED SECTION



LOCATION PLAN - 1:1250



BLOCK PLAN - 1:500



GENERAL :

Provide ridge ventilation equiv to 5mm x length of ridge.
Provide eaves / low level ventilation equiv to 25mm continuously.
Unless stated otherwise : timber = C24 grade, steel = S355 grade.

NEW LOFT FLOOR :

New flooring = 22mm T+G moisture resistant flooring grade chipboard.
New beams and / or joists to support new structure to span to existing outside walls to achieve min 100mm bearing. Use 100mm Rockwool quilt between new floor joists for sound insulation & additional fire resistance. Existing ceiling joists / truss bottom chord strapped to new floor joists and / or beams where existing support removed. New steel floor trimmers to be treated to provide 1/2hr fire protection to manufacturer's instructions.

DORMER ROOF :

AA fire rated long life rubberised membrane on 18mm exterior grade ply on sw firing strips set to fall 1 in 80 on new sw roof joists - see PROPOSED SECTION for joist size and insulation spec.
New uPVC rainwater goods to discharge via new downpipe(s) onto existing roof. Maintain 50mm cross ventilation air gap above insulation between joists (either front to back into ventilated roof void or side to side). Insect proof mesh over.

DORMER CHEEKS / FACE :

New external dormer finish to match colour of existing as closely as possible on sw battens on breather paper on 12mm ply bracing on 50x100mm sw studding @ 600mm cts, 100x100mm sw corner & reveal posts 100mm PIR insulation between studding, SuperQuilt across studding, 25mm sw battens, 12.5mm plaster'd & skim. Code 4 lead flashing to fully weatherproof the dormer externally.
Where dormer cheeks are within 1m of the boundary, they are to achieve 1/2hr fire by using 12.5mm cement-based board fixed to external face before applying finishes or similar as approved by Building Inspector.

NEW ROOFLIGHTS :

All new rooflights to be rated AA, AB or AC.
Trim out rooflights using doubled rafters each side to manufacturer's instructions.

GLAZING :

New glazing to have a U-value 1.4W/m² k.
Install one new energy efficient light fitting per 25m² floor area.

STAIRCASE :

Max tread rise = 220mm : Min tread going = 220mm.
Max pitch = 42 degrees : Min headroom = 2.0m from pitch line of new stairs.
900mm high handrail / balustrades with max 100mm gaps anywhere.
Any tapered treads to have a min going of 50mm.
New stairs to be manufactured from new floor to floor measurement taken from site. All to current Building Regulations, Part K.

DRAINAGE :

New 100mm dia uPVC waste to WC : new 40mm dia uPVC waste to shower & WHB.
All to have 75mm deep seal traps with anti-vac if required. All to connect to extg SVP with rodding access to any changes in direction. If necessary, divert / extend extg SVP to terminate min 900mm above any adjacent windows withing 3.0m Suitable bird cage over.

INTERNAL STUD WALLS :

50x100mm sw studding @ 400mm cts with 12.5mm plaster'd & skim internal finish. Internal walls to include 25mm Rockwool infill.

DWAF WALLS :

Double 50x100mm sw studding @ same centres as extg rafters, 100mm PIR insulation between studs, SuperQuilt insulation, 25mm sw battens, 12.5 plasterboard & skim finish.

MECHANICAL EXTRACTION :

Provide mechanical extractor to extract at a rate of not less than 15 litres / second, operable intermittently. Where no rapid ventilation is provided to new room, extractor to be connected to light switch and to provide 20 minute overrun.

OTHER FIRE RESISTANCE NOTES :

Existing ceiling = 12.5mm plasterboard & skim. New circulation space at loft level to be fully 1/2hr fire resistant. Existing doors to be min 32mm thick and to be of sound construction and be well fitting and be fitted with steel hinges - replace if necessary. To extg party wall(s), always ensure min 1/2hr fire separation between adjoining properties.
Any glazing to stairwell to be replaced with fire-proof glazing or overboarded with 12.5mm plaster'd & skim. Glazed doors to be replaced.

ELECTRICS - PART P :


Electrical installation to be designed and carried out by a competent person and in accordance with Part P of the Building Regulations.
A Certificate of Compliance to be supplied to the Building Inspectors upon completion.

HEATING :

New heating system elements to meet the requirements of PART L, Building Regulations. New radiator(s) to be fitted with TRV.


LIGHTING :

Lighting to Building Regulations, PART L.




PROPOSED FIRST FLOOR PLAN

Divide extg bathroom with new 1/2hr fire res partition to create bathroom & ensuite. New door from extg bedroom with Catnic (or equiv) lintol. Final position of new fittings to be agreed with client. All new drainage to be agreed on site with Building Inspector. All to current Building Regulations.



PROPOSED FIRST FLOOR PLAN - LOFT FLOOR CONSTRUCTION SUPERIMPOSED -



PROPOSED ROOF / SECOND FLOOR PLAN

Reinstate 30x5mm ms galv straps @ 1.5m cts across and screwed to 3No. min rafters / floor joists & returned and screwed to gable wall. Additional bracing may be required, to maintain overall structural stability, to be agreed on site as necessary.

Dormer cheeks built off doubled 72x145mm sw rafters.

Position of new shower room fittings to be agreed with client. All new drainage to be agreed on site with Building Inspector. All to current Building Regulations.

- (S) Interconnected mains operated smoke detector with battery back-up. 300mm min from any light fitting
- (H) Interconnected mains operated optical smoke detector with battery back-up. 300mm min from any light fitting

Grade D1 Category LD2 AFD SYSTEM (IN ACCORDANCE WITH BS 5839-6 : 2019) TO BE INSTALLED INCORPORATING DETECTORS IN ALL CIRCULATION SPACES THAT FORM PART OF THE ESCAPE ROUTES FROM THE DWELLING & IN ALL ROOMS THAT REPRESENT A HIGH RISK TO OCCUPANTS INCLUDING A HEAT DETECTOR IN THE KITCHEN



Mr & Mrs PARMAR

15 Thornage Close, Luton, Bedfordshire. LU2 7AT

PROPOSED LOFT CONVERSION

SCALE : 1:50, 1:500, 1:1250	Drawing number :
DATE : Feb 2024	2206 / 02 - 24
BY : A. Lloyd	B. Insp. Revision : Sheet :
SHEET : 1 of 2	Alpha 0 A1

Copyright Adrian Lloyd. All dimensions to be verified on site. As this plan does not form part of the contract, any items shown which are not on the signed small works order, will be subject to additional charge. Any internal room dimensions are approximate and for guidance only.