

# Consultee Comments for Planning Application 24/00074/FUL

## Application Summary

Application Number: 24/00074/FUL

Address: Chichester Racquets And Fitness Club Oaklands Way Chichester West Sussex PO19 6AR

Proposal: Replace 24 flood lights on tennis courts with LED lights. No changes to height or location.

Case Officer: Annie Gietzold

## Consultee Details

Name: ?-? Environmental Strategy Unit

Address: Chichester District Council, East Pallant House, 1 East Pallant Chichester, West Sussex PO19 1TY

Email: Not Available

On Behalf Of: CD-PLS Div-Environmental Strategy Unit

## Comments

App No: 24/00074/FUL

Proposal: Replace 24 flood lights on tennis courts with LED lights. No changes to height or location.

Address: Chichester Racquets And Fitness Club Oaklands Way Chichester West Sussex PO19 6AR

### Bats

We are concerned about the proposed use of flood lighting on the site due to the presence of bats within the local area and the location of the site within the Singleton and Cocking Tunnel SAC buffer zone. We require that more work is undertaken to determine the potential impact this lighting may cause and the restrictions which may be required. We also require the following information regarding the lighting scheme;

The type of luminaire

The frequency of the light spectrum which will need to be below 3000K

Kind Regards

Liz

Liz Annalls

Environment Officer

Environmental Protection

Chichester District Council

Ext: 24229 | Tel: 01243 785166 | [eannalls@chichester.gov.uk](mailto:eannalls@chichester.gov.uk) | Fax: 01243776766

<http://www.chichester.gov.uk>