Title: 109 Church Road, SE19 2PR | JOB NO: 8500103567 | PROPOSAL PLOT

Customer's Responsibilities

To carry out all on-site excavation & reinstatement of the cable trench.

The trench for the 4c 35H will be a minimum of 450mm deep and will include a 50mm black solid ridgiduct (smooth inner and corrugates outer embossed ELECTRICITY CABLE DUCT).

All ducts installed will have no acute bends, where an acute bend is unavoidable then a draw pit must be provided. The ducts will be installed complete with draw cord and in accordance with UK Power Networks drawing ES 10-0190-1.
To supply and install electrical Tile Tape 0.1m above the ridgiduct.

To provide a new suitable size intake position within the communal area.

To install a distribution board.

UK Power Network's Responsibilities

To carry out all off-site excavation & reinstatement of the cable trench and all associated joint bays.

Branch joint a 4c 35H cable onto the existing 185H Cable and run this into the internal communal intake position to terminate into a 100A 3ph cut-out for a BNO supply.

Connect the customer's 35mm double insulated tails from their isolator into the cut-out and install 100A fuses.

Disconnect the existing 2c 35H service.

Contestable closing joint.
185H / 4c 35H Branch joint.
Point of Connection onto UKPN Network.

Disconnect existing 2c 35H service.

Site Boundary.

To be the BNO for the new metered services; these will be supplied from your Ryefield styled multiway board. Please refer to ENA's G87 document for supplies to multi-occupied buildings for further guidance.

Description	Existing	Proposed
LV Cable or Line		
HV Cable or Line		
EHV Cable or Line Approx. position		
Ductline	[ ]	[ ]
Pole & Street Furniture		
Substation & Link Box		

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.

0m 5m 10m 15m 20m 25m 30m 35m 40m 45m 50m 55m 60m 65m 70m

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
2. The exact position of the apparatus should be verified – use approved cable avoidance tools prior to excavation using suitable hand tools.
3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all cables have been determined.
4. It must be assumed that each property and item of street furniture has an electricity supply. Service cables shown only where known.
5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
6. The information provided must be given to all people working near UK Power Networks plant & equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

VISITING AN OPEN POINT? Please mark on this plan all locations visited and open points as found, then return updated map to your Business Unit – Thank You.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
2. UK Power Networks does not exclude or limit its liability if it causes the death of any person or causes personal injury to a person where such death or personal injury is caused by its negligence.
3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever.
4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and you must return it to the sender of the letter.
5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

Contact UK Power Networks on 0800 056 5866 for details of EHV Cable routes before commencing work.

Grid Ref: TQ 33510 70405
Scale: 1:500
(when Plotted at A3)
Plotted on: 12/11/2018
Plotted by: Mitchell Ranger

UK Power Networks

Plan Provision

CHECK IT OUT BEFORE YOU DIG IT OUT
CALL 0800 056 5866
EMERGENCY– If you damage a cable or line
Phone 0800 096 3766 (24hrs) URGENTLY

LOOK OUT LOOK UP
ALWAYS LOOK UP BEFORE YOU START WORK
Refer To HSE Guidance note GS6

Maps produced at 1:2500 scale are LV Geo-Schematics which show LV mains cables and overhead lines (in some cases all voltages). Prior to carrying out excavations you must refer to the 1:500 records to determine the location of all known underground plant and equipment.

Reproduced by permission of Ordnance Survey on behalf of HMSO. (c) Crown copyright and database right 2018. All rights reserved. Ordnance Survey Licence number 100019450. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of (c) South Eastern Power Networks plc or London Power Networks plc each being a distribution licensee under section 6(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.