


A Library Plant Enclosure Section A  
1 : 50



B Library Plant Enclosure Section B  
1 : 50

- GENERAL NOTES**
- This drawing is to be read in conjunction with all other MXF documents (drawings, schedules and specification) along with other design team documentation.
  - Print this drawing in colour
  - Do not scale from this drawing

- PROJECT SPECIFIC NOTES**
- All new penetrations through walls, floors & ceilings shall be fire stopped to Architect's specification by an approved third party certified fire-stopping specialist.
  - Dimensions shown in red are critical clearance dimensions for ASHP enclosure in order to meet the ASHP manufacturer's warranty requirements. These dimensions are not provided for setting out, which is to be as per the Architect's information.

- PIPED SERVICES**
- LTHW Flow
  - LTHW Return
- ELECTRICAL**
- Data
  - LV Distribution
  - Clearance Zone
  - ASHP.X Air Source Heat Pump

1 McGowin Library Roof  
1 : 50