

All Steelwork to be blast cleaned to SA 2.5 and primed 75micron DFT high build zinc phosphate. Steelwork to be designed fabricated erected in accordance with NSS and BS 5950.

Steelwork below ground shall be encased in 100mm C35 concrete with D49 mesh in centre of cover.
Grouting shall be 25mm nom and comprise 3:1 Cement:sand with expander such as combex 100.

Concrete quality for Reinforced Concrete shall be RC35 to BS5328 pt 2.
Concrete quality for Foundations in Clay FND2 to BS5328 pt 2.

Stuart Thomas Associates Limited Structural and Civil Engineers Consulting Engineers	High Street Olney Bucks Tel. (01 234	6 Osborns Court High Street South Olney Bucks MK46 4LA Tel. (01 234) 712010 Fax. (01 234) 713336	
^{project}	drawn	^{date}	_{scale}
Manor Hill Cottage, Great Brickhill	MFJT	09/23	1/50
drawing	project no.	drawing no.	revision
Foundation & Retaining Wall GA.	6881		A