EXTRACT SYSTEM DETAILS

Typical problems encountered with commercial kitchen ventilation systems;

Ventilation systems are used;

linear extract method: each linear meter of active filter length is assigned a vent rate depending on the vent canopy type. Recommended canony typ

(tootinininiada dariop) ()po)					
Source of Noise	How/Why Noise Arises				
Extract/supply fan	Fan motor noise, Fan impeller turning				

The dimensions of a canopy are dictated by the size of the catering equipment that it is serving, the two criteria that have the most influence on the amount of air required for effective ventilation are the plan dimensions and height. unless restricted by walls etc., the plan dimensions of the canopy should always exceed the plan dimensions of the catering equipment by a minimum of 200mm on each free side and by 300mm at the front and rear, dimensions at the side may need to be increased where high output equipment is located at the end of the cooking line-up.

Where combination steamer and certain types of baking ovens are used, the overhang at the front should be 600mm to cope with steam or fumes that arise when the doors of the appliance are opened

The height of the canopy is governed by the height of the ceiling and the underside of the canopy should be located between 2000 and 2100 mm above the finished floor level, the efficiency of canopies less than 400mm high are less beneficial zoo and because the color molecular in manded because in these situations, the face velocity may need to be increased to 0.5m/s to compensate, where the ideal flow rate cannot be achieved the size of the canopy may be increased to aid capture. the ideal distance between the lowest edge of the grease filter and the top of the cooking surface should be between 450mm to 1350mm, this is to avoid the risk of excessive temperatures or fire in the filter that could cause the extracted grease to

vaporise and pass through to the ductwork. this dimension will vary with the type of cooking appliance and can be reduced where fire suppression equipment is installed, but should never be below 1350mm where mesh filters are installed

Canopy type	opy type Light duty		Medium duty			Extra heavy duty	
Wall mounted	0.23-0.31 (m3/s)	0.31-0.46(m	3/S)	0.31-0.62 (m	3/S)	>0.54 (m 3/s)	
types of system are available:							

cassette system: is an integrated system incorporating partitioned or dedicated extract and partitioned or dedicated supply. the systems are modular and contain a number of cassettes of proprietary design, which filter and separate grease from the air prior to its exhaust, the grease is normally collected in a non-drip integral or perimeter trough for removal and cleaning. materials of construction of canopy;

the food safety (general food hygiene) regulations[20] requires that in food preparation areas:

ceilings and overhead fixtures must be designed, constructed and finished to prevent the accumulation of dirt and reduce condensation, the growth of undesirable moulds and the shedding of particles.' in relation to canopies, it is best practice to use stainless steel especially if the relevant surface comes directly into contact with food. typically canopies and other overhead fixtures are fabricated using ultra fine-grained stainless steel (grade 304). higher grades of stainless steel may also be specified.

Other best practice guidelines include:

where air must be equalised within a supply plenum of a canopy 0.8 mm perforated stainless steel sheet should be used. in addition, care should be taken to ensure that the face velocity is about 0.7 m/s. noise generation increases when velocities of 0.9 m/s are exceeded. discharge grills on make-up air system should be fabricated with 1mm perforated stainless steel sheet. condensation should be avoided in canopies that are provided with supply plenum, where insulation is used it should: be a rigid foil faced non fibrous slab, with a class 1 spread of flame; and
not be fibre based as this could contaminate food. kitchen ventilation systems often have relatively high resistance against which a fan has to operate. therefore, fans need to be sized to cope with a design pressure of a minimum additional 10% pressure margin. care must to be taken: • to ensure operational changes e.g. build up of dirt on mesh filters are taken into account: and If changes are made to the ventilation system that may alter the operating pressure. to overcome such changes variable speed control or balancing dampers may be used, a range of impeller designs is available as follows: · backward curved centrifugal, mixed flow or axial flow impellers are preferred as they are less prone to imbalance and are easier to clean and maintain due to their open construction. • fixed or adjustable metal impellers are recommended. lightweight multi-vane or plastic-type impellers can warp and are prone to collecting grease. although plastic bladed fans can be used in non-grease, low temperature situation. the fan must be able to operate at between 400 and 600 at 95% relative humidity.

motors should be rated to ip55. where fan motors sit within warm moist air streams, they should be upgraded to withstand more onerous conditions. to avoid excessive temperature build-up, temperature detectors should be fitted. drain holes should be provided at the lowest point in the fan housing to remove condensation. care needs to be taken to ensure that the drain hole does not downgrade the index of protection (ip) of the motor.

dual or variable speed regulation are widely used, the fan must always operate at its design duty, especially when grease is being produced, a minimum extract level should be set within the speed regulator to ensure that, even at low speed, an adequate rate of ventilation is maintained. speed regulation should be applied to both make-up air and extraction air. speed regulation cannot be employed with water wash/cartridge systems as flow rates are fixed.

make-up and extract fan operation should be interlocked with gas supply, so that gas supply is switched off if the fans fail. fans should be isolated when fire a suppression system is activated. the connection between ductwork and fan housing should be suitable for use in

grease-laden atmospheres and at duct temperature. joints must be clamped or bonded to prevent air leakage. under fire conditions the material should have a minimum integrity of at least 15 minutes.

Fan type	Advantages	Disadvantages		
Roof Extract Fans (Vertical Jet Discharge with Centrifugal Impellers)	Good temp range when motor is outside of air stream Easy removal for cleaning and maintenance No space restrictions Good external appearance No discharge ductwork required	Temperature limitations, but suitable for kitchen use. Requires good roof access for maintenance More expensive than inline/ axial models		

Cartridge filters Installed horizontally, cartridge filters comprise a high velocity slot opening on to a series of baffles which cause air to change direction four times compared to only twice in a conventional baffle filter. The cartridge filters are installed over the ful length of the extract plenum and should be sloped to allow trapped grease to fail through a drain to a grease drawer. These filters are intended for heavy grease loads. Having a higher velocity enables lower air volumes to be used. Air balancing is required to prevent carry over of grease.

Fine filtration

A basic filtration system can be used to deal with a low intensity odour problem but more usually will form a protective pre-treatment step before an activated carbon sten

Recommendations for maintenance of odour control system For a system employing fine filtration and carbon filtration; • Change fine filters every two weeks Change carbon filters every 4 to 6 months For a system employing ESP and other in line abatement systems: Clean every 2-6 months

Noise reduction methods for various noise sources and transmission paths; Reflected sound from walls, ceiling, and walls.Direct sound can be controlled only by selecting quiet equipment. Reflected sound is controlled by adding sound absorption to room and to location of equipment.

Noise reduction methods for various noise sources and

transmission paths	lission paths						
Description	Noise reduction method						
Direct sound radiated from sound source to ear. Reflected sound from walls, ceiling, and walls.	Direct sound can be controlled only by selecting quiet equipment. Reflected sound controlled by adding sound absorption to room and to location of equipment.						

Inadequate height of the discharge stack is one of the main reasons the emissions from a kitchen gives rise to odour nuisance. The stack design is paramount to achieving good dispersion. Good stack dispersion requires: The effective stack height (discharge height plus plume rise) must be high enough to ensure that adequate dilution takes place before the plume interacts with a receptor. Discharge velocity influences the plume rise and therefore the effective stack height. The effective stack height can be estimated from: ÄH = 3W.d/U where, W (m/s) is the efflux speed at the chimney tor U (m/s) is the wind speed at the height of the stack d (m) is the internal diameter of the stack Ideally W/U should be greater than 4. If W/V is less than 1.5, then down wash will occur resulting in a reduced effective stack height. • The discharge to be outside the wake of nearby buildings. Discharging ventilation air below a roof ridge may result in excessive entrainment within building down wash. In certain situations, the use of high velocity discharge systems can force the discharging plume out of the building wake. • The flow to be unimpeded. Cowls can increase the static pressure, noise potential down draught and risk of re-entry of the exhaust back into the building. Alternative stack terminals are available and include: terminals without integral drains e.g. reducing cone, solid top cones; and • terminals with integral drains e.g. open top cone and drain, induction types and

sleeve type. sleeve type. • Straight and vertical discharge. Figure 4.5 shows examples of best stack design. Guidance on stack requirements for commercial kitchens varies between Local Authorities. The range of guidance issued by Local Authorities is summarised below: Guidance on the minimum stack height ranges from:
1 m above the eaves of the premises and/or above any dormer window 1 m above ridge height of any building within 15 m; and
low level discharge should be avoided.
The height of external ground level should be taken into account when setting stack height. This is particularly important on rising ground where houses may be located above the discharge. · A stack should be positioned to be as far as possible from the nearest residential accommodation. A stack discharging into a semi-enclosed area such as a courtvard or the area between back additions should be avoided. Use of Ohinaman's hals or other cowls is not recommended.
The prevailing wind direction should also be considered in the ducting positioning.

 The ducting should be rigid in construction and resiliently mounted.
Large section ducts may need bracing or stiffeners to prevent drumming. In certain instances restriction on stack height might arise for example Where an A3 premises is a listed building and a visible stack is prohibited; Where an A3 premises is located within a conservation area and a visible stack is prohibited; and • Operators of the A3 premises do not have legal right to attach a stack to upper

floors of building.

Motor Frame Size and type




Silencer Type: Helios Flanged Circular Attenuator - RSD 450-800

Coarse or Grease filtration	

	Disadvantages						
or is	Temperature limitations, but suitable for kitchen use. Requires good roof access for maintenance More expensive than inline/ axial models	Filter type	Recommended Face Velocity (m/s)	Typical Eficiency	Advantages	Disadvantages	
d		Cartridge	4.5-5.5 (at entry)	90-95%	Higher efficiency Non-overloading pressure drop	High pressure drop Special plenum fabrication required	
red							

01 Cooking particulates Our ESP units fit in-line with the 03 ESP - Particulate kitchen ducting and can be con figured modularly to cope with all extract volume requirements. 02 Canopy Grease Filter 04 Airflow OUR SERVICES X D. 吻 Design Manufacture Maintair





Air Eloy

%

Eliminates up to 99% of particles

1- This drawing is prepared solely for design and planning submission purposes. It is not intended or suitable for either Building Regulations or Construction purposes and should not be used for such. 2- All Dimensions are in millimeter

3- Dimensions are not to be scaled directly from drawings other than for Planning Purposes.

4- All dimensions are to be checked on site and the Architect is to be informed

of any discrepancies before construction commences.
5- All references to drawings refer to current revision of that drawing.

6- The Copyright of this drawing belongs to Archpl Ltd.

	-				
Rev. Date	Revisions				
PLANNING					
ARCHITECTURAL DESIGN STUDIO 400 West Green Road, West Green, London, N15 3PX Tel Web: www.archpl.co.uk					
Client Mr.	Guvenc Cocelli				
Project 31 F	Rosemary Road, (Clacton-on-Sea	a CO15 1PA		
Scale N	TS @A3	Date	03/2024		
Drawn By RG Checked By					
Project No. Drawing No. Revision 24015 P104 -					
Drawing title Proposed Extract System-2					