



Hussein Panjwani
Andrew Firebrace Partnership Ltd
Stable Barn
Park End
Cambridge
United Kingdom
CB25 0NA

Anglian Water Services Limited
Development Services
PO Box 495
Huntingdon
PE29 6YY
0345 60 66 087
developmentservices@anglianwater.co.uk

05 April 2024

Dear Hussein

Section 106 Water Industry Act 1991 – Sewer Connection

Application Reference: ALD-0206287

Site: 77, Hauxton Road, Cambridge

Thank you for your application for a sewer connection to serve the above premises.

I can confirm that Anglian Water has no objection to a direct foul water connection to the 150mm foul water sewer located in Hauxton Road via a preformed 'y' branch junction insertion. In addition, I can confirm that Anglian Water also has no objection to a direct surface water connection to the foul water sewer with the use of attenuation storage tanks for the surface water and this is to be restricted to no more than 1l/sec. This approval is to be read in conjunction with drawing number 23/0692/100 Rev P1 dated 03/04/24.

Please note that our approval is based upon the public sewer records. No physical surveys have been carried out by Anglian Water to ascertain the existence or position of the sewer(s) to which you are intending to connect. The actual position of all apparatus should be established by trial holes. On this occasion we have decided not to exercise our right under section 107(1) Water Industry Act 1991 to undertake the sewer connection ourselves.

We will inspect work carried out on the public sewer and we may have to issue permits to your contractor. Please follow the necessary steps on InFlow to arrange an appointment for a Developer Services Representative to visit site. Alternatively, a visit can be arranged by contacting Emma Burton directly on 07813548879 giving 5 working days notice of when the work on the public sewer will commence.

The property will be billed for sewerage charges three months from the date of this approval letter if we have not had notification of the connection date or that the connection is not proceeding.

An infrastructure charge will also be applicable in addition to the connection fee. The sewerage infrastructure charge for 2024/25 is set at £403.00. This will be billed by the water company either before or shortly after the connection has taken place. For further information regarding this charge, please see the Development Services Charging Arrangements document on our [website](#).

Please be advised that whilst this letter confirms that we have no objection to the type of connection proposed, it should not be issued to the Planning Authority as proof that a drainage strategy has been agreed with Anglian Water. If we have placed a drainage condition at the planning stage, you are still required to comply with any stipulations we have made regarding the point of connection or discharge rates before we will confirm to the Planning Authority that the condition has been satisfied.

If your application is for a non-household property then please be aware, at the point of

connection, you will need to have selected a retailer. To find out more and for guidance on how to select a retailer go to www.Open-water.org.uk/Customers/.

Finally, please be aware of your obligation under the Construction (Design and Management) Regulations 2015, more information can be found at www.hse.gov.uk.

Yours sincerely,

Alpesh Makwana

Development Services