

[REDACTED]

As discussed your connection at the above address has been completed 03/01/2024 as planned however our team installed wrapped PE within the footpath instead of Barrier Pipe - they will be returning to amend this.

I can confirm the pipework laid on the private side was laid in Barrier Pipe and inspection passed to regulatory standards.

If you require any further information please let me know.

If you would like to discuss this by phone, please give me a call on 01925 429006. Alternatively, you can reply to this email and I will get back to you as soon as possible.

[REDACTED]

Did you know we now have a live chat facility available to you between 8am and 5pm Monday to Friday. Just click on the link on our webpage and one of our advisors will be ready to chat to you and help you with your enquiry
<https://www.unitedutilities.com/builders-developers/>