


**ELECTRICAL LEGEND**

- B** DOUBLE 13 AMP ELECTRICAL SOCKET  
(sockets to be a minimum of 400mm above finished floor level and be located a minimum of 350mm from internal corners and a minimum of 150mm above worktops)
- B+** DOUBLE 13 AMP ELECTRICAL SOCKET (Metal back boxes with intumescent seals) to provide 60 minutes fire resistance.  
(sockets to be a minimum of 400mm above finished floor level and be located a minimum of 350mm from internal corners and a minimum of 150mm above worktops)
- ⌚** SWITCH
- ⌚** SWITCH (TWO WAY)  
(switches to be installed a minimum of 900mm above floor level and a maximum of 1100mm above floor level)
- ⊕** CEILING LIGHT ( low energy)
- ⊕** CEILING MOUNTED EXTRACTOR FAN LINKED TO LIGHT SWITCH AND DUCTED TO THE EXTERNAL AIR Extraction rate 60 litres / second
- ⊕** DOWN- LIGHT ( low energy and fire rated)  
  
All downlighters will be less than 100mm diameter, the junction between the ceiling board and the downlighters are well sealed. Minimum distance between each downlighter is greater than 750mm.
- H** HEAT DETECTOR (with battery back up) INTERLINKED WITH MAINS OPERATED ALARMS THROUGHOUT THE DWELLING TO CONFORM TO BS 5446 PART 2 2003
- ⊙** CARBON MONOXIDE DETECTOR ( Installed within 1 - 3m of the appliance)
- NEW MAINS OPERATED SMOKE ALARM (WITH BATTERY BACK UP) INTERLINKED WITH ALL SMOKE DETECTORS . ALARM TO BE INSTALLED IN ACCORDANCE WITH BS5839 Part 6 2019 GRADE D TYPE LD3 SYSTEM
- TH** ALL ELECTRICAL WORK WILL BE CARRIED OUT IN ACCORDANCE WITH BS 7671 2019 AND A TEST CERTIFICATE( SELECT OR NICEIC ) WILL BE PROVIDE ON COMPLETION OF WORKS. ALL NEW WORKS TO BE INSTALLED AND OR TESTED BY AN APPROVED ELECTRICIAN.
- \*** NEW 30 MINUTE FIRE RESISTANT SELF CLOSING DOOR WITH INTUMESCENT STRIPS AND COLD SMOKE SEALS

PROPOSED GROUND FLOOR PLAN 1:50 @ A7



THIS IS THE PLAN REFERRED TO IN THE APPLICATION BY .....

ISABELL HENDRY  
65 BENTS ROAD  
CHAPELTON  
STRATHAVEN  
ML10 6SA