
From: dcplanning
Subject: Planning consultations, 24/00770/REM Plot F - Unit 4, Fuel Depot Bognor Road Chichester West Sussex PO20 1EJ

From: FRS Water and Access [REDACTED]
Sent: Monday, April 22, 2024 12:26 PM
To: dcplanning <dcplanning@chichester.gov.uk>
Subject: Planning consultations, 24/00770/REM Plot F - Unit 4, Fuel Depot Bognor Road Chichester West Sussex PO20 1EJ

FAO: Joanne Prichard

Dear Joanne,

Having viewed the plans submitted for this site for Unit 4 on Plot F on the former fuel depot site, WSFRS consulted with Portsmouth water and three fire hydrants have been installed on the site and therefore access and the supply of water for firefighting meet with requirements.

Regards

Ian



Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service



Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his 

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
