



FUTURE KITCHEN EXTRACT FAN INSTALLATION BY TENANT. IT IS ASSUMED THE GREASE/CARBON TREATMENT WILL BE PROVIDED WITHIN RETAIL DEMISE

1300X600 FIRE RATED KITCHEN EXTRACT DUCT TO ROOF LEVEL CAPPED OFF AT A3 RETAIL UNIT DEMISE. DUCT & RISER INSTALLATION PART OF SHELL & CORE PROVISION. ACCESS TO BE PROVIDED AT EACH FLOOR FROM LANDLORD AREAS.

- NOTES:**
- THIS DRAWING MUST NOT BE USED FOR CONSTRUCTION OR INSTALLATION PURPOSES UNLESS EXPRESSLY STATED.
  - DO NOT SCALE OFF THIS DRAWING. ALWAYS WORK TO NOTED DIMENSIONS.
  - ALL DIMENSIONS MUST BE VERIFIED ON SITE BEFORE COMPLETING SHOP DRAWINGS OR SETTING OUT THE WORKS.
  - REFER TO SMOKE VENTILATION SPECIALIST DRAWINGS FOR ALL SMOKE VENTILATION REQUIREMENTS.

**LEGEND:**

FLOW (m <sup>3</sup> /s)	VELOCITY (m/s)
PRESSURE (Pa/m)	DUCT SIZE (mm)
LOSS (Pa/m)	WxD (mm)

Designed	By	Drawn	CS	Approved	GC
14.07.22				14.07.22	14.07.22
Date	Date	Date	Date	Date	Date
14.07.22	14.07.22	14.07.22	14.07.22	14.07.22	14.07.22
Rev	Description				
C01	CONSTRUCTION ISSUE				

**LJ Ltd**  
Mechanical & Electrical Contractors

Downing House, Wellington Road, Cressex Business Park, High Wycombe, Bucks, HP12 3PS  
Tel: 0494 472323 Fax: 01494 536633  
E-mail: info@ljcontractors.co.uk  
Web Site: www.ljcontractors.co.uk

Status	CONSTRUCTION ISSUE
Client	CONCORD LONDON
Project	204 GREAT PORTLAND STREET
Title	MECHANICAL SERVICES VENTILATION SCHEMATIC
Scale at A0	NTS
Date	23/12/2022
Draw No	5084-LJ-XX-XX-DR-M-1003
Rev	C01

Z:\PROJECTS\5142\_204 GREAT PORTLAND STREET\03 - MECHANICAL\CONSTRUCTION - SCHEMATICS\5084-LJ-XX-XX-DR-M-1003